



THOMAS J. PASTUSZKA
CMC, CCB
EXECUTIVE OFFICER/CLERK

County of San Diego
AIR POLLUTION CONTROL DISTRICT HEARING BOARD
1600 PACIFIC HIGHWAY, ROOM 402, SAN DIEGO, CALIFORNIA 92101-2471

TELEPHONE (619) 531-5434
FAX (619) 531-6098

STATEMENT OF PROCEEDINGS
SAN DIEGO COUNTY
AIR POLLUTION CONTROL DISTRICT HEARING BOARD
Regular Meeting, Thursday, June 27, 2013

ADMINISTRATIVE ITEM:

- A. Approval of Minute Orders of June 13, 2013.

ACTION:

ON MOTION of Member Gabrielson, seconded by Member Smith, the Air Pollution Control District Hearing Board approved the minutes of June 13, 2013.

- B. Submission of Quarterly Progress Report, dated June 20, 2013 from Granite Construction Incorporated, pertaining to Petition No. 4376.

ACTION:

ON MOTION of Member Gabrielson, seconded by Member Smith, the Air Pollution Control District Hearing Board accepted the item pertaining to Petition No. 4376.

- C. Motion to adjourn the APCD Hearing on July 11, 2013.

ACTION:

ON MOTION of Member Tonner, seconded by Member Smith, the Air Pollution Control District Hearing Board adjourned the Air Pollution Control District hearing on July 11, 2013.

Petition No.

- 4393 AIR POLLUTION CONTROL DISTRICT, COUNTY OF SAN DIEGO:** Hearing Board will rehear the Abatement Order (filed 4-10-2013) stipulated between Petitioner San Diego County Air Pollution Control District and Respondent ESCONDIDO ENERGY CENTER, LLC. On July 2, 2008, the District issued Authority to Construct (ATC) No. 985693, for the replacement of an existing Pratt & Whitney FT4 Twin Pack turbine with one GE LM6000 turbine at an existing peaker plant located at 1968 Don Lee Place, Escondido, California. The ATC was amended in 2009, 2011 and 2012 and will expire on July 2, 2013. The turbine replacement will not be completed by July 2, 2013, so Respondent will be in violation of Rule 10. The Proposed Order would allow Respondent to install and commission the replacement turbines until the earlier of January 31, 2014 or District issuance of a Startup Authorization. The requested Abatement Order is not intended to act as a Variance.

PUBLIC SPEAKER: Todd Cardiff

ACTION:

ON MOTION of Member Gabrielson, seconded by Vice-Chair Rodriguez, the Air Pollution Control District Hearing Board closed the hearing and approved the stipulated Abatement Order originally issued on April 25, 2013.

4399 CITY OF SAN DIEGO, PUBLIC UTILITIES DEPT: Request the Interim portion of an Interim/Regular Variance (filed June 17, 2013) from Rule 21, Condition No. 4 as applied to Permit to Operate No. APCD2006-PT0-931030, regarding an anaerobic digester, located at 5240 Convoy St, San Diego, CA 92111. Variance requested from the hydrogen sulfide concentration limit until equipment is in compliance.

ACTION:

ON MOTION of Member Gabrielson, seconded by Vice-Chair Rodriguez, the Air Pollution Control District Hearing Board granted the Interim variance.

LAST MATTER OF BUSINESS:

Opportunity for members of the Public to speak to the Board on any subject matter within the Board's jurisdiction but not on an item on today's Agenda. (Five minutes total will be allocated; each speaker's presentation may not exceed one minute and may not relate to pending litigation.)

ASSISTANCE FOR THE DISABLED:

Agendas and records are available in alternative formats upon request. Contact the Clerk's office at **(619) 531-5434 (voice) or (619) 531-4803 (TTY)**. Assistive Listening Devices (ALDs) are available from the Clerk of the Board in Room 402 prior to the meeting, and are to be returned at the end of the meeting. Individuals requiring sign language interpreters should contact the Americans with Disabilities Coordinator at **(619) 531-5205**, in advance of the meeting so that arrangements may be made. An area in the front of the chamber is designated for individuals requiring the use of wheelchair or other accessible devices.