

FOR YOUR INFORMATION

The Following Notice was Published by the District

**NOTICE OF PRELIMINARY DECISION BY THE
SAN DIEGO COUNTY AIR POLLUTION CONTROL DISTRICT
TO APPROVE A SOURCE OF AIR POLLUTION**

The San Diego Air Pollution Control District has made a preliminary decision to approve an Authority to Construct for a 2930 horsepower backup engine generator under application number APCD2016-APP-004389 for Lilly Biotechnology to be operated at 10920 Campus Point Dr in San Diego.

An evaluation of the air pollution impacts of this proposal was performed by the District and it was determined that all applicable District Rules and Regulations will be met when the equipment complies with conditions prescribed by the District. An Air Quality Impact Analysis was conducted for oxides of nitrogen (NOx). Results indicate that the operation of this equipment will not result in the violation of any State or Federal ambient air quality standard or interfere with the attainment or maintenance of any State or Federal ambient air quality standard. The potential to emit for this equipment is 26 pounds per hour, and 0.65 tons per year of NOx.

The Air Quality Impact Analysis is available for review at the Air Pollution Control District, 10124 Old Grove Road, San Diego, CA 92131. Please refer to Application No. APCD2016-APP-004389 on all correspondence regarding this project. Written comments concerning the District's proposed action may be submitted for a period of 30 days commencing 07/08/2016, and ending on 08/08/2016. Questions regarding this notice may be directed to Evariste Haury at (858) 586-2745 or at evariste.haury@sdcounty.ca.gov.

.....

Published: July 8, 2016
EH:cm – 07/05/2016