

**SAN DIEGO AIR POLLUTION CONTROL DISTRICT
10124 OLD GROVE ROAD, SAN DIEGO, CA 92131-1649
PHONE (858) 586-2600 • FAX (858) 586-2601**

CERTIFICATE OF COMPLIANCE & CERTIFICATE OF REGISTRATION
RULE 12
BEC/FS: 12844/34W

<i>San Diego APCD Use Only</i>
APP/Reg. No.:
ID No.:
Existing P/O No.:

Existing Diesel Internal Combustion Emergency Standby Engines
(PM > 0.4 g/BHP-hr)

Certificate Holder (DBA): _____

Legal Owner (if different from DBA): _____

Equipment Location: _____

Equipment Description: Manufacturer: _____

Model No.: _____ Serial No.: _____

HP Rating: _____ Type of Fuel: _____

Date first operated in San Diego County: _____ Year of Manufacture: _____

Emission Control, if any: _____

I, _____, certify that I will be in compliance with all applicable District Rules and
(Print or type name)

Regulations and the following conditions:

1. Engine operation for maintenance and testing purposes conducted prior to January 1, 2006, shall not exceed 52 hours per calendar year. (Rule 12)
2. Engine operation for maintenance & testing purposes conducted on and after January 1, 2006, shall not exceed 20 hours per calendar year. (17 CCR §93115 / ATCM Reportable)
3. This engine shall use only California Air Resources Board (CARB) certified diesel fuel. (Rule 12, 17 CCR §93115)
4. The registrant shall notify the Air Pollution Control District Compliance Division immediately upon detection of any violation of a condition identified as "ATCM Reportable." Such violations shall be subject to Air Pollution Control District compliance action. (17 CCR §93115)
5. Visible emissions, including crank case smoke, shall comply with Air Pollution Control District Rule 50.
6. The equipment described above shall not cause or contribute to public nuisance. (Rule 51)
7. This engine shall not operate for non-emergency use during the following periods, as applicable:
 - (A) Whenever there is any school sponsored activity, if the engine is located on school grounds; or
 - (B) Between 7:30 AM and 3:30 PM on days when school is in session, if the engine is located within 500 feet of, but not on, school grounds.

This condition shall not apply to an engine located at or near any school grounds that also serve as the students' place of residence. (17 CCR §93115 / ATCM Reportable)
8. Engine operation in response to notification of an impending rotating outage, shall be restricted to the following conditions:
 - (A) The utility distribution company has ordered rotating outages in the control area where the engine is located;
 - (B) The engine is operated no more than 30 minutes prior to the time when the utility distribution company officially forecasts a rotating outage in the cited control area; and
 - (C) The engine operation is terminated immediately after the utility distribution company advises that a rotating outage is no longer in effect.

This condition shall not apply to engines operating pursuant to the rolling blackout reduction program as defined in 17 CCR §93115 and operating in accordance with 17 CCR §93115 (E) (2) (F). (ATCM Reportable)
9. A non-resettable engine hour meter shall be installed on this engine, maintained in good working order, and used for recording engine operating hours. If a meter is replaced, the Air Pollution Control District's Compliance Division shall be notified in writing within 10 calendar days. The written notification shall include the following information:
 - (A) Old meter's hour reading;
 - (B) Replacement meter's manufacturer name, model and serial number, if available, and current hour reading on replacement meter;
 - (C) Copy of receipt of new meter or of installation work order.

Certificate of Compliance & Certificate of Registration – Rule 12

A copy of the meter replacement notification shall be maintained onsite and made available to the Air Pollution Control District upon request. (Rule 12, 17 CCR §93115)

- 10. The owner or operator of this engine shall conduct periodic maintenance of each engine and add-on control equipment, if any, as recommended by the engine and control equipment manufacturers or as specified by the engine servicing company’s maintenance procedures. The periodic maintenance shall be conducted at least once each calendar year. (Rule 12)
- 11. The owner or operator of the engine shall maintain the following records onsite for at least the same period of time as the engine to which the records apply is located at the site:
 - (A) Documentation identifying the fuel used as CARB certified diesel fuel;
 - (B) Manual of recommended maintenance provided by the manufacturer, or maintenance procedures specified by the engine servicing company; and
 - (C) Records of annual engine maintenance, including the date the maintenance was performed.
 These records shall be made available to the Air Pollution Control District upon request. (Rule 12, 17 CCR §93115)
- 12. The owner or operator of this engine shall maintain a monthly operating log containing, at a minimum, the following:
 - (A) Dates and times of engine operation, including whether the operation was for maintenance & testing purposes or emergency use and the nature of the emergency, if known;
 - (B) Hours of operation for all uses other than those specified above and identification of the nature of that use. (Rule 12, 17 CCR §93115)
- 13. The owner or operator shall document fuel use through the retention of fuel purchase records that account for all fuel used in the engine and all fuel purchased for use in the engine and, at a minimum, contain the following information:
 - (A) Amount of fuel purchased;
 - (B) Date when fuel was purchased;
 - (C) Signature of owner, operator, or representative of owner or operator who received the fuel;
 - (D) Signature of fuel provider indicating fuel was delivered; and
 - (E) Amount of fuel added to the engine tank. (17 CCR §93115)
- 14. All operational and maintenance logs, records fuel use and type of fuel, and purchase records required by this Certificate of Registration shall be kept for a minimum of 36 months from their date of creation unless otherwise indicated by the conditions of this Certificate of Registration. The records shall be maintained onsite for a minimum of 24 months from their date of creation. Records of the last 24 months of operation shall be made available to the Air Pollution Control District upon request. Records of operation for the last 25 to 36 months shall be made available to the Air Pollution Control District within 5 working days of request. (Rule 12, 17 CCR §93115)
- 15. The registrant shall provide access, facilities, utilities and any necessary safety equipment, with the exception of personal protective equipment requiring individual fitting or specialized training, for source testing and inspection upon request of the Air Pollution Control District. (Rule 19)

Signature: _____

Date: _____

Title: _____

Affiliation: _____

CERTIFICATE OF REGISTRATION (FIRST YEAR)

A copy of this registration certificate must be kept with the equipment and presented upon request to the Air Pollution Control District. Every person who operates this equipment is required to comply with all Air Pollution Control District Rules and Regulations, including Rule 12. Any person who violates a rule or regulation of the Air Pollution Control District or any of the conditions listed above is guilty of a misdemeanor and may be subject to civil and criminal penalties. To remain valid, this certificate must be renewed annually in accordance with District Rule 12.

Approved by: _____
(APCD Engineer’s Signature)

Date: _____