
San Diego County Air Pollution Control District

10124 Old Grove Rd
San Diego, CA 92131
(858) 586-2600

TITLE V OPERATING PERMIT APCD2002-PTO-961008

Issued To:

City of San Diego, Point Loma Wastewater Treatment Plant
Site ID: APCD1976-SITE-02083

Site Address

1902 Gatchell Rd.
San Diego, CA 92106
(619) 421-5192

Mailing Address

4918 North Harbor Drive, No. 201
San Diego, CA 92106

Responsible Officials:

Cheryl Lester, Deputy Director, Wastewater Treatment & Disposal Division;
Robert Mulvey, Assistant Director, Public Utilities Department;
Halla Razak, Director, Public Utilities Department

Facility Contact: K.C. Shankles

Permit Information Contact: Salvador Coria

Issued by the San Diego County Air Pollution Control District on _____.

This Title V Operating Permit expires on _____.

Signed by: _____

Jim Swaney, P.E., Chief of Engineering

Date: _____

TABLE OF CONTENTS

	PAGE
PREAMBLE	1
SECTION I. REGULATION XIV PERMIT REQUIREMENTS	2
A. ADMINISTRATIVE PERMIT TERMS	2
B. RENEWAL REQUIREMENTS AND TERMS	2
C. MONITORING, RECORDKEEPING & REPORTING REQUIREMENTS	3
D. GENERAL PERMIT REQUIREMENTS	4
SECTION II. FACILITY-WIDE REQUIREMENTS	4
A. GENERAL PERMIT PROGRAM APPLICABLE REQUIREMENTS	4
B. GENERAL PROHIBITORY APPLICABLE REQUIREMENTS	5
C. PERMIT SHIELDS	6
D. ADDITIONAL TERMS	6
SECTION III. EMISSION UNIT REQUIREMENTS	6
A. DISTRICT PERMITTED EMISSION UNITS	6
B. REGISTERED AND LEASED EMISSION UNITS	6
C. INSIGNIFICANT EMISSION UNITS AND ACTIVITIES	6
SECTION IV. DISTRICT-ONLY PROVISIONS	7
SECTION V. APPENDICES	A-1
A. DISTRICT PERMITS AND REGISTERED UNITS	A-1
B. RULE REFERENCE TABLE	B-1
C. ABBREVIATIONS	C-1

PREAMBLE

This Title V Operating Permit consists of this document and all appendices, including District permits incorporated by reference. The facility is subject to all applicable requirements identified within this permit, unless a specific permit shield is specified within this permit. If an applicable requirement is omitted from this permit, the facility is still obligated to comply with such an applicable requirement. The permittee must comply with all of the terms listed in each section of this permit.

This permit contains five major sections: Section I contains the Regulation XIV requirements required to carry out the Title V Operating Permit program. Section II contains the requirements that are applicable to the facility on a facility-wide basis. Section III contains the requirements that are applicable to individual emission units which have been issued District permits or District registration, or which have been determined to be insignificant emission units. Section IV contains terms and requirements pertaining to variance procedures and compliance schedules, if applicable to the facility. Section V contains three appendices. Appendix A contains all the District permits incorporated within this permit. Appendix B contains a table of all SIP approved and District approved rules. Appendix C contains a list of abbreviations used within this permit.

Copies of the Rules and Regulations of the Air Pollution Control District of San Diego County and the Rules and Regulations for San Diego County contained in the State Implementation Plan (SIP) approved by EPA may be obtained at the District. Copies are also available for review at the following locations:

SD Air Pollution Control District (Library & Public Review Area)	County of SD Law Library (Downtown)	County of SD Law Library (North County)
10124 Old Grove Rd.	1105 Front St.	325 S. Melrose Suite 300
San Diego, CA 92131	San Diego, CA 92101	Vista, CA 92083
(858) 586-2600	(619) 531-3900	(760) 940-4386

The current Rules and Regulations of the Air Pollution Control District of San Diego County may also be viewed and downloaded using the following internet address:

<http://www.sdapcd.org/>

The following addresses should be used to submit any certifications, reports or other information required by this permit:

SD Air Pollution Control District Compliance Division 10124 Old Grove Rd. San Diego, CA 92131	USEPA Region IX Director of the Air Division Attn: Air-3 75 Hawthorne Street San Francisco, CA 94105
--	---

SECTION I. REGULATION XIV PERMIT REQUIREMENTS

A. ADMINISTRATIVE PERMIT TERMS

1. This Title V Operating Permit expires 5 years from the date of issuance. [Rule 1410]
2. Commencing or continuing operation under this permit to operate shall be deemed acceptance of all terms and conditions specified within this permit. This does not limit the right of the applicant to seek judicial review or seek federal EPA review of a permit term or condition. [Rule 1421]
3. This permit may be modified, revoked, reopened and reissued, or terminated by the District for cause. [Rule 1421]
4. The filing of a request by the facility for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay the applicability of any permit condition. [Rule 1421]
5. This permit does not convey any property rights of any sort, or any exclusive privilege. [Rule 1421]
6. The need for the permittee to halt or reduce a permitted activity in order to maintain compliance with any term or condition of this permit shall not be a defense for any enforcement action brought as a result of a violation of any such term or condition. [Rule 1421]
7. In the event of challenge to any portion of this permit, the rest of the permit remains valid. [Rule 1421]
8. For the purpose of submitting compliance certifications or establishing whether or not a person has violated or is in violation of any applicable requirement in this permit, nothing in this permit shall preclude the use, including the exclusive use, of any credible evidence or information, relevant to whether a source would have been in compliance with applicable requirements if the appropriate performance or compliance test or procedure had been performed. [Rule 1421]

B. RENEWAL REQUIREMENTS AND TERMS

1. The permittee shall submit a complete application for renewal of this permit to the Air Pollution Control Officer at least 12 months, but not more than 18 months prior to permit expiration. [Rule 1410]
2. If an administratively complete application for renewal of this permit has been submitted to the Air Pollution Control Officer within the dates specified in Section I.B.1., the terms and conditions of this permit shall remain in effect and the source may continue operations under these terms and conditions until the Air Pollution Control Officer issues or denies the permit renewal. [Rule 1410]

C. MONITORING, RECORDKEEPING & REPORTING REQUIREMENTS

1. The permittee shall provide the District access to the facility and all equipment subject to this permit, and access to all required records pursuant to CA H&S Code Section 41510. [Rule 1421]
2. The permittee shall maintain all records required by this permit including any calibration, maintenance, and other supporting information and copies of all reports required by this permit for at least five years from their date of creation. Such records shall be maintained on-site for a minimum of one year. Any additional records must be maintained at a location to be specified by the source and made readily available to the District upon request. [Rule 1421]
3. The permittee shall submit monitoring and recordkeeping summary reports and all other monitoring and recordkeeping reports required by this permit to the District every six months, unless a shorter time frame is required by a specific permit condition contained in Section III of this permit. Unless other dates are specified in Section III, reports for data required to be collected from January 1 through June 30, shall be submitted no later than September 1 of the calendar year, and reports for data required to be collected from July 1 through December 31, shall be submitted no later than March 1 of the following calendar year. The report for the final six months of the year may be consolidated with the annual compliance certification required below. All instances of noncompliance from federally enforceable applicable requirements shall be clearly identified in these reports. (Timely completion of District Certification Reports Form J1 and Form J2, if applicable, and all indicated attachments, fulfills the requirements of this condition.)
[Rule 1421]
4. Each calendar year, the permittee shall submit to the District and to the federal EPA an annual compliance certification, in a manner and form approved in writing by the District, for the previous calendar year that includes the identification of each applicable term or condition of the final permit for which the compliance status is being certified, the compliance status and whether the facility was in continuous or intermittent compliance during the previous calendar year, identification of the method used to determine compliance during the previous calendar year, and any other information required by the District to determine the compliance status. The annual compliance certification for a calendar year shall be submitted no later than March 1 of the following calendar year and may be consolidated with the monitoring and recordkeeping report for the last six months of the year for which compliance is certified. (Timely completion of District Certification Reports Form J1 and Form J2, if applicable, and all indicated attachments, fulfills the requirements of this condition.)
[Rule 1421]
5. Any report submitted to the District or federal EPA pursuant to this permit to comply with a federally enforceable applicable requirement, shall be certified by a responsible official stating that, based on information and belief formed after reasonable inquiry, the report is true, accurate and complete. [Rule 1421]

6. The permittee shall make any trade secret designations of records, documents, or other information submitted to the District or federal EPA in accordance with District Rule 176. [Rule 176]
7. The permittee shall report all deviations from any and all federally enforceable permit terms and conditions including: (a) breakdowns, whether or not they result in excess emissions, (b) deviations that result in excess emissions of any regulated air pollutant, and (c) deviations from monitoring, recordkeeping, reporting and other administrative requirements that do not result in excess emissions. For deviations that result from breakdowns under District Rule 98, the permittee shall report the breakdown within two hours of detection of the breakdown and provide a follow-up written report after corrective actions have been taken. For deviations not due to a breakdown but which result in excess emissions, the permittee shall report the deviation within ten calendar days of detection. For all other deviations where no specific time frame for reporting deviation applies, the permittee shall report the deviation at the time of the next semi-annual monitoring summary or annual compliance certification, whichever occurs first. If an underlying applicable requirement contains a definition of prompt or otherwise specifies a time frame for reporting deviations, then the criteria for the applicable requirement shall apply. The report must include the probable cause of such deviations and any corrective actions or preventive measures taken. [Rule 1421]

D. GENERAL PERMIT REQUIREMENTS

1. The permittee shall comply with all terms and conditions of this permit. This permit consists of this document and Appendixes A, B and C. Any noncompliance with the federally applicable terms and conditions of this permit shall constitute a violation of the federal Clean Air Act. Noncompliance with any federally applicable permit term or condition of this permit is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application. Noncompliance with any District permit term or condition is grounds for enforcement action by the District. [Rule 1421]
2. Upon a written request by the District, the permittee shall furnish to the District any information needed to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit; any information required to determine compliance with this permit; or any records required to be maintained pursuant to this permit. Such information shall be provided within a reasonable time, as specified within the District's written request. [Rule 1421]
3. The permittee shall pay annual fees in accordance with District Rule 40. [Rule 1421]
4. The permittee shall provide access, facilities, utilities and any necessary safety equipment for source testing and inspection upon request of the District. [Rule 19]
5. This permit shall be maintained on-site at all times and be made available to the District upon request. [Rule 1410]
6. The Rule Reference Table provided in Appendix B shall be used to determine whether a cited rule is a federally and District enforceable requirement or a District only enforceable requirement. Any new or revised District rule shall not be considered

federally enforceable until the rule is approved by EPA into the SIP. In cases where SIP approval is pending for a revised District rule, the rule citation shall refer to both the current SIP approved rule and the revised District rule. [Rule 1421]

SECTION II. FACILITY-WIDE REQUIREMENTS

A. GENERAL PERMIT PROGRAM APPLICABLE REQUIREMENTS

The permittee shall comply with the applicable requirements specified in the Rules and Regulations cited below, unless specifically exempted by the same Rule or Regulation.

Regulation	Rule Citation	Title
SDCAPCD Reg. II	10	Permits Required
SDCAPCD Reg. II	19	Provision of Sampling & Testing Facilities
SDCAPCD Reg. II	19.3	Emission Information
SDCAPCD Reg. II	21	Permit Conditions
SDCAPCD Reg. IV	60	Circumvention
SDCAPCD Reg. V	98	Breakdown Conditions: Emergency Variance

B. GENERAL PROHIBITORY APPLICABLE REQUIREMENTS

The permittee shall comply with the generally applicable requirements specified in the Rules and Regulations cited below, unless specifically exempted by the same Rule or Regulation. These generally applicable requirements apply on a facility-wide basis to all permitted equipment, registered equipment, and insignificant activities. In cases where a requirement, in addition to being generally applicable, is also specifically applicable to one or more permitted emission units, the requirement is also included in Section III.A. of this permit.

Regulation	Rule Citation	Title
SDCAPCD Reg. IV	50	Visible Emissions
SDCAPCD Reg. IV	51	Nuisance
SDCAPCD Reg. IV	67.0	Architectural Coatings
SDCAPCD Reg. IV	67.17	Storage of Materials Containing VOC
SDCAPCD Reg. IV	71	Abrasive Blasting
SDCAPCD Reg. VI	102	Open Fires - Western Section
SDCAPCD Reg. VI	105	Burning Permits
SDCAPCD Reg. VI	106	Permit Duration
SDCAPCD Reg. VI	107	Burning Hours
SDCAPCD Reg. VI	108	Burning Conditions
SDCAPCD Reg. VI	111	Prior Notification
SDCAPCD Reg. VI	112	Burning Report
SDCAPCD Reg. X	Subpart A	NSPS - General Provisions
SDCAPCD Reg. XI	Subpart A	NESHAP - General Provisions
40 CFR Part 63	Subpart A	NESHAP - General Provisions
SDCAPCD Reg. XI	Subpart M, 361.145	Standard for Demolition and Renovation

SDCAPCD Reg. XI	Subpart M, 361.150	Standard for Waste Disposal for Manufacturing, Fabricating, Demolition, Renovation, and Spraying Operations
40 CFR Part 82	Subpart A	Production and Consumption Controls
40 CFR Part 82	Subpart B	Servicing of Motor Vehicle Air Conditioners
40 CFR Part 82	Subpart F	Recycling and Emissions Reduction

C. PERMIT SHIELDS

Not applicable for this source.

D. ADDITIONAL TERMS

1. Any emission unit described in this Title V operating permit as being fired on natural gas, shall only use Public Utility Commission (PUC)-quality natural gas, unless the emission unit permit specifies otherwise. [Rule(s) 53, 62]

SECTION III. EMISSION UNIT REQUIREMENTS

A. DISTRICT PERMITTED EMISSION UNITS

The District Permits listed in the following Appendix A, including all terms and conditions of such permits, constitute the emission unit portion of this Title V Operating Permit.

B. REGISTERED AND LEASED EMISSION UNITS

The permittee shall comply with the source specific applicable requirements specified in the Rules and Regulations cited below for all registered emission units, unless specifically exempted by the same Rule or Regulations.

Regulation	Rule Citation	Title
SDCAPCD Reg. IV	52	Particulate Matter
SDCAPCD Reg. IV	53	Specific Contaminants
SDCAPCD Reg. IV	54	Dust and Fumes
SDCAPCD Reg. IV	62	Sulfur Content of Fuels
SDCAPCD Reg. IV	67.6	Solvent Cleaning Operations
SDCAPCD Reg. IV	69.4	Stationary Reciprocating Internal Combustion Engines

C. INSIGNIFICANT EMISSION UNITS AND ACTIVITIES

The permittee shall comply with all applicable requirements of the SDCAPCD Rules and Regulations for all emission units listed as insignificant emissions sources in accordance with Regulation XIV, Appendix A. Insignificant activities include the following:

Appendix A Citation	Source Type/Description

(d)(1)(iii)	I.C. engines with \leq 50 bhp output rating
(d)(4)(i)	Fuel-burning equipment with a maximum gross heat input rate of < 1 million Btu/hr when not part of a process line, line, equipment, article, machine or other contrivance for which a permit to operate is required
(d)(34)	Abrasive blasting equipment with a manufacturer's rated sand capacity of < 100 lbs or < 1 cubic foot
(h)(1)	Liquid surface coating or adhesive application operations (portable or stationary) where not more than 20 gallons per year of material containing organic compounds are applied
(o)(29)(ii)	Aerosol can puncturing/crushing operations which vent all emissions through a properly operated/maintained carbon canister, provided < 500 cans/day are processed

SECTION IV. DISTRICT-ONLY PROVISIONS

VARIANCE PROCEDURES

The permittee may seek relief from District enforcement action in the event of a breakdown in accordance with District Rule 98. Notwithstanding the foregoing, the granting by the District of breakdown relief or the issuance by the Hearing Board of a variance does not provide relief from federal enforcement or citizen's suits. [Rule 98]

SECTION V. APPENDICES

APPENDIX A: EMISSION UNITS – SPECIFIC CONDITIONS

Permit or Application #	Emissions Unit Type
930297	Treatment Plant
940189	Sludge Screen Facility
950315	Anaerobic Sludge Digestion
960190 thru 960193	Boilers
961168, 961169	I.C. Engines
002381, 002649, 002650	Diesel Engines



COUNTY OF SAN DIEGO, AIR POLLUTION CONTROL DISTRICT
 10124 OLD GROVE ROAD, SAN DIEGO, CA 92131
 PHONE (858) 586-2600 FAX (858) 586-2601
 www.sdapcd.org

Sectors: 3, I
Site ID: APCD1976-SITE-02083
App ID: APCD2009-APP-987682

PERMIT ID
 APCD2006-PTO-930297

SD City of Metro Wastewater Dept
 Salvador Coria
 2392 Kincaid Rd
 San Diego CA, 92101

EQUIPMENT ADDRESS
 SD City of Metro Wastewater
 Salvador Coria
 1902 Gatchell Road
 San Diego CA 92106

PERMIT TO OPERATE

This permit is not valid until required fees are received by the District.

The above is hereby granted a Permit To Operate the article, machine, equipment or contrivance described below. This permit is not transferable to a new owner nor is it valid for operation of the equipment at another location except as specified. This Permit To Operate or copy must be posted on or within 25 feet of the equipment, or readily available on the operating premises.

EQUIPMENT OWNER

City of San Diego - Metropolitan Wastewater Dept Owner Manager 2392 Kincaid Rd, San Diego, CA 92101

EQUIPMENT DESCRIPTION

A 240 million gallon per day (MGD) advanced primary treatment plant consisting of: preliminary treatment and grit handling operations (headworks, screening building, six (6) aerated grit tanks, six (6) parshall flumes, effluent weir structure, and grit processing equipment) controlled by Odor Reduction System (ORS) 1; twelve (12) sedimentation basins controlled by ORS's 2,3,4,5,7 and 8, with each ORS controlling no more than three sedimentation basins; chemical addition/storage facilities, associated piping, fans, ducts and electrical equipment. ORS 1 consisting of two identical trains (1 service and 1 standby) with each train consisting of one (1) scrubber fan, one (1) scrubber, two (2) recirculating pumps (1 service, 1 standby) and makeup water system. ORS 2,3,4,5,7 and 8 each consist of one (1) scrubber fan, one (1) wet scrubber, two (2) recirculating pumps (1 service, 1 standby), a makeup water system, one (1) carbon fan, two (2) carbon towers (1 service, 1 standby) each containing approximately 20,000 pounds activated carbon. APP. 977649 (982377/SJR) (08/06) (987682/RKY)

Every person who owns or operates this equipment is required to comply with the conditions listed below and all applicable requirements and District rules, including but not limited to Rules 10, 20, 40, 50, 51.

Fee Schedules: 1 [56A] Sewage Treatment Facility

BEC: APCD2014-CON-000832

FAILURE TO OPERATE IN COMPLIANCE IS A MISDEMEANOR SUBJECT TO CIVIL AND CRIMINAL PENALTIES



Sectors: 3, I
Site ID: APCD1976-SITE-02083
App ID: APCD2009-APP-987682

PERMIT ID
APCD2006-PTO-930297


A. FEDERALLY-ENFORCEABLE AND DISTRICT-ENFORCEABLE CONDITIONS

1. The Odor Reduction System(s) (ORS) and its monitoring equipment shall be maintained in good operating condition and shall be in full operation in accordance with the facility Operations and Maintenance (O&M) manual at all times when the process equipment is in operation except during outages not to exceed 374 hours per calendar year. An outage is any period when any component necessary for full operation of the ORS is shut down or malfunctions. Full operation consists of: For ORS 1, one wet scrubber in operation; for ORS 2-8, one wet scrubber followed by one carbon adsorption unit in operation. The District must be notified of all outages which exceed 24 hours. Notification must be submitted in writing no later than 2 calendar days after any outage. The O&M manual and logs of the date, duration (in minutes), purpose and type of shutdown shall be maintained on-site for five years from date of entry and shall be made available to District personnel upon request. [Rule 51]
2. Odor reduction system 1, 2, 3, 4, 5, 7 and 8 shall be equipped with a volumetric flow measuring device in its liquid recirculation system indicating the instantaneous flow of liquid to the scrubber packing. Scrubber flow shall be greater than 250 gallons per minute when the scrubber is in operation. Scrubber flow rate shall be recorded once daily. The flow meters shall be calibrated in accordance with the manufacturer's specifications. Scrubber flow records and records of calibration including manufacturer's calibration specifications indicating the flow meter's accuracy and dates of calibration shall be kept on site for three years and made available to the District upon request. (Rule 51)
3. Odor reduction system 1, 2, 3, 4, 5, 7 and 8 shall be equipped with a pH control and visual display indicating the instantaneous ph value. pH of the scrubbing solution shall be 9.0 or greater when the scrubber is in operation except during equipment start-up, the duration of which shall not exceed 24 hours. Ph values shall be recorded once daily. All instruments and probes associated with pH control shall be calibrated in accordance with the manufacturer's specifications. Daily pH records and records of calibration including manufacturer's calibration specifications and dates of calibration shall be kept on site for three years and made available to the District upon request. (Rule 51)
4. Odor reduction systems 1, 2, 3, 4, 5, 7 and 8 shall be equipped with an oxidation reduction potential (ORP) controller and a visual display indicating the instantaneous ORP value. ORP shall be 575 mv or greater when the scrubber is in operation except during equipment start-up, the duration of which shall not exceed 24 hours. ORP values shall be recorded once daily. All instruments and probes associated with ORP control shall be calibrated in accordance with the manufacturer's specifications. Daily ORP records and records of calibration including the manufacturer's calibration specifications and dates of calibration shall be kept on site for three years and made available to the District upon request. (Rule 51)
5. Sulfur content sampling shall be conducted at least every 180 days on the carbon in each activated carbon system using ASTM-D1619-03 Method B, ASTM-D1619-83 Method B, or Calgon method TM-30 (or any other equivalent method approved in writing and prior to testing by the District). The sampling shall be done at the middle sampling port of each carbon bed. Records of the dates of carbon sampling, sampling ports used and results shall be maintained on site for at least three years and made available to District personnel upon request. (Rule 51)
6. The carbon shall be replaced within 180 days after any sample is taken which indicates the carbon sulfur capacity as indicated below has been reached.

Carbon type	sulfur capacity (%wt)
Centaur HSV	16
NaOH impregnated	25
Granular Activated Carbon (GAC)	4

(Rule 51)
7. The activated carbon material used for replacement of the spent active carbon in either bed of an odor control system shall, at least, have the same contaminant removal capacity as the material specified to the District by the applicant. The submitted specifications indicate an average contaminant removal capacity of (0.14 gram H₂S/cc carbon) for NaOH impregnated carbon, (0.09 gram H₂S/cc carbon) for 'Centaur HSV' activated carbon, and(0.01 gram H₂S/cc carbon) for Granular Activated Carbon (GAC). (Rule 51)



COUNTY OF SAN DIEGO, AIR POLLUTION CONTROL DISTRICT
10124 OLD GROVE ROAD, SAN DIEGO, CA 92131
PHONE (858) 586-2600 FAX (858) 586-2601
www.sdapcd.org

Sectors: 3, I
Site ID: APCD1976-SITE-02083
App ID: APCD2009-APP-987682

PERMIT ID
APCD2006-PTO-930297


8. Records of the carbon manufacturer's hydrogen sulfide removal capacity, the carbon bed sample date, the carbon bed analyses laboratory results, the date(s) of the activated carbon replacement and/or regeneration and the manufacturer specification indicating the type of carbon (NaOH,, 'Centaur HSV', or Granular Activated Carbon) shall be maintained for each carbon bed. These records shall be maintained on site for three years and made readily available to the District personnel upon request. (Rule 51)
9. Spent carbon shall be stored in closed containers pending removal from site. (Rule 51)
10. At no time shall the subject equipment cause or contribute to a public nuisance as specified in District Rule 51. If compliance with Rule 51 cannot be demonstrated to the satisfaction of the District, the permittee will take whatever corrective action necessary to meet applicable requirements. If corrective action requires any physical change or modification to the subject equipment the permittee shall apply for and obtain an Authority to Construct for all such modifications prior to making any physical change. (Rule 51)
11. Where equipped, process covers or enclosures shall be used at all times except during periods of equipment maintenance. (Rule 51)
12. Access, facilities, utilities and any necessary safety equipment for source testing and inspection shall be provided upon request of the Air Pollution Control District. [Rule 19]

B. DISTRICT-ONLY ENFORCEABLE CONDITIONS

13. This Air Pollution Control District Permit does not relieve the holder from obtaining permits or authorizations required by other governmental agencies.
14. The permittee shall, upon determination of applicability and written notification by the District, comply with all applicable requirements of the Air Toxics "Hot Spots" Information and Assessment Act (California Health and Safety Code Section 44300 et seq.) (Air Toxics Hot Spots)



Sectors: 3, I
Site ID: APCD1976-SITE-02083
App ID: APCD2009-APP-987682

PERMIT ID
APCD2006-PTO-940189


SD City of Metro Wastewater Dept
Salvador Coria
2392 Kincaid Rd
San Diego CA, 92101

EQUIPMENT ADDRESS
SD City of Metro Wastewater
Salvador Coria
1902 Gatchell Road
San Diego CA 92106

PERMIT TO OPERATE

This permit is not valid until required fees are received by the District.

The above is hereby granted a Permit To Operate the article, machine, equipment or contrivance described below. This permit is not transferable to a new owner nor is it valid for operation of the equipment at another location except as specified. This Permit To Operate or copy must be posted on or within 25 feet of the equipment, or readily available on the operating premises.

EQUIPMENT OWNER

City of San Diego - Metropolitan Wastewater Dept Owner Manager 2392 Kincaid Rd, San Diego, CA 92101

EQUIPMENT DESCRIPTION

One (1) raw sludge screening facility consisting of: screens, screw conveyors, hoppers, truck loading area, monitoring equipment and all associated pumps, blowers, piping, ducting and valves. The above operations are controlled by two odor reduction systems. Each odor reduction system consists of: one polishing carbon adsorption vessel (7' diameter). Note: there are two (2) wet scrubbers (32" x 96" x 85") upstream of the carbon adsorption vessels which are by passed and not in use. One (1) raw sludge blending tank (80,000 gallon capacity) which is controlled by a carbon canister (3' diameter). The monitoring equipment consists of: probes, flow meters, visual displays for meters, transmitters, local controllers and computer data logging system.

Every person who owns or operates this equipment is required to comply with the conditions listed below and all applicable requirements and District rules, including but not limited to Rules 10, 20, 40, 50, 51.

Fee Schedules: 1 [91A] Miscellaneous
3 [94E] Air Quality Inspector II

BEC: APCD2014-CON-000829

FAILURE TO OPERATE IN COMPLIANCE IS A MISDEMEANOR SUBJECT TO CIVIL AND CRIMINAL PENALTIES

A. FEDERALLY-ENFORCEABLE AND DISTRICT-ENFORCEABLE CONDITIONS

1. Sulfur content sampling shall be conducted at least every 180 days on the carbon in each 7 foot diameter activated carbon system using ASTM-D1619-03 Method B, ASTM-D1619-83 Method B, or Calgon method TM-30 (or any other equivalent method approved in writing and prior to testing by the District). The sampling shall be done at the middle sampling port of each carbon bed. Records of the dates of carbon sampling, sampling ports used and results shall be maintained on site for at least three years and made available to District personnel upon request. (Rule 51)



COUNTY OF SAN DIEGO, AIR POLLUTION CONTROL DISTRICT
10124 OLD GROVE ROAD, SAN DIEGO, CA 92131
PHONE (858) 586-2600 FAX (858) 586-2601
www.sdapcd.org

Sectors: 3, I
Site ID: APCD1976-SITE-02083
App ID: APCD2009-APP-987682

PERMIT ID
APCD2006-PTO-940189


2. The carbon shall be replaced within 180 days after any sample is taken which indicates the carbon sulfur capacity as indicated below has been reached.
Carbon type - sulfur capacity (%wt)
Centaur HSV - 16
NaOH impregnated - 25
Granular Activated Carbon (GAC) - 4
[Rule 51]
3. The activated carbon material used for replacement of the spent active carbon of the 7 foot diameter polishing carbon adsorption odor reduction system shall, at least, have the same contaminant removal capacity as the material specified to the district by the applicant. The submitted specifications indicate an average contaminant removal capacity of 0.14 gram H₂S/cc carbon for NaOH-impregnated carbon, 0.09 gram H₂S/cc carbon for 'Centaur HSV' activated carbon, and 0.01 - gram H₂S/cc carbon for Granular Activated Carbon (GAC). (Rule 51)
4. Records of the carbon manufacturer's hydrogen sulfide removal capacity, the carbon bed sample date, the carbon laboratory results, the date(s) of the activated carbon replacement and/or regeneration and the manufacturer specification indicating the type of carbon (NaOH, KOH, 'Centaur HSV' or Granular Activated Carbon) shall be maintained for each carbon bed. These records shall be maintained on site for three years and made readily available to the District personnel upon request.
[Rule 51]
5. The 3 foot diameter carbon canister shall be replaced once every five years. Records of the carbon replacement date and the carbon bed adsorption capacity shall be maintained for seven years and made available to District personnel upon request. (Rule 51)
6. Spent carbon shall be stored in closed containers pending removal from site. (Rule 51)
7. Where equipped, process covers or enclosures shall be used at all times except during periods of equipment maintenance. (Rule 51)
8. At no time shall the subject equipment cause or contribute to a public nuisance as specified in District Rule 51. If compliance with Rule 51 cannot be demonstrated to the satisfaction of the District, the permittee will take whatever corrective action necessary to meet applicable requirements. If corrective action requires any physical change or modification to the subject equipment the permittee shall apply for and obtain an Authority to Construct for all such modifications prior to making any physical change. (Rule 51)
9. The Odor Reduction System(s) (ORS) and its monitoring equipment shall be maintained in good operating condition and shall be in full operation in accordance with the facility Operations and Maintenance (O&M) manual at all times when the process equipment is in operation except during outages not to exceed 374 hours per calendar year. An outage is any period when any component necessary for full operation of the ORS is shut down or malfunctions. Full operation consists of two polishing carbon adsorption vessels in operation. The District must be notified of all outages which exceed 24 hours. Notification must be submitted in writing no later than 2 calendar days after any outage. The O&M manual and logs of the date, duration (in minutes), purpose and type of shutdown shall be maintained on-site for five years from date of entry and shall be made available to District personnel upon request. [Rule 51]
10. Access, facilities, utilities and any necessary safety equipment for source testing and inspection shall be provided upon request of the Air Pollution Control District. (Rule 19)

B. DISTRICT-ONLY ENFORCEABLE CONDITIONS

11. This Air Pollution Control District Permit does not relieve the holder from obtaining permits or authorizations required by other governmental agencies.
12. The permittee shall, upon determination of applicability and written notification by the District, comply with all applicable requirements of the Air Toxics "Hot Spots" Information and Assessment Act (California Health and Safety Code Section 44300 et seq.) (Air Toxic Hot Spots)



Sectors: 3, I
Site ID: APCD1976-SITE-02083
App ID: APCD2009-APP-987682

PERMIT ID
APCD2009-PTO-950315


SD City of Metro Wastewater Dept
Salvador Coria
2392 Kincaid Rd
San Diego CA, 92101

EQUIPMENT ADDRESS
SD City of Metro Wastewater
Salvador Coria
1902 Gatchell Road
San Diego CA 92106

PERMIT TO OPERATE

This permit is not valid until required fees are received by the District.

The above is hereby granted a Permit To Operate the article, machine, equipment or contrivance described below. This permit is not transferable to a new owner nor is it valid for operation of the equipment at another location except as specified. This Permit To Operate or copy must be posted on or within 25 feet of the equipment, or readily available on the operating premises.

EQUIPMENT OWNER

City of San Diego - Metropolitan Wastewater Dept Owner Manager 2392 Kincaid Rd, San Diego, CA 92101

EQUIPMENT DESCRIPTION

Anaerobic sludge digestion consisting of: four (4) digester tanks approx 3.5 million gallons each, two (2) digester tanks approx. 3.3 million gallons each, one (1) digester tank approx. 4.2 million gallons, one (1) secondary digester/holding tank approx. 3.0 million gallons and associated mixing and recirculation pumps, gas mixers, heat exchangers, piping, valves and fittings. A portion of the digester gas from above equipment routs to three (3) digester gas fired, enclosed flares, each flare 32' high, 84" diameter. Each flare is equipped with one (1) electronic ignitor, one (1) purge blower, two (2) air dampers (motor operated louvers), two (2) stack thermocouple, optical flame detectors, sampling ports, flame arrestors, automatic shutoff valves, control panel and other equipment listed in the Flare Ind. Inc. Owners Manual

Every person who owns or operates this equipment is required to comply with the conditions listed below and all applicable requirements and District rules, including but not limited to Rules 10, 20, 40, 50, 51.

Fee Schedules: 1 [56A] Sewage Treatment Facility

BEC: APCD2014-CON-000830

FAILURE TO OPERATE IN COMPLIANCE IS A MISDEMEANOR SUBJECT TO CIVIL AND CRIMINAL PENALTIES

A. FEDERALLY-ENFORCEABLE AND DISTRICT-ENFORCEABLE CONDITIONS

1. The permittee shall comply with Rule 53. (Rule 1421)
2. The total Digester gas consumed at this facility shall not be greater than 1,460 million standard cubic feet per calendar year. This total consumption shall be calculated as the sum of the gas consumed in permits 961168, 961169, 960190, 960191, 960192, and 960193, plus the total digester gas consumed by the flares. Digester gas consumed in the flares shall not exceed 995 million standard cubic feet per calendar year. Records of digester gas consumption shall be maintained on-site for at least three years and made available to District personnel upon request. (NSR)



COUNTY OF SAN DIEGO, AIR POLLUTION CONTROL DISTRICT
10124 OLD GROVE ROAD, SAN DIEGO, CA 92131
PHONE (858) 586-2600 FAX (858) 586-2601
www.sdapcd.org

Sectors: 3, I
Site ID: APCD1976-SITE-02083
App ID: APCD2009-APP-987682

PERMIT ID
APCD2009-PTO-950315



3. Functioning non-resettable totalizing flow meter(s) which display and measure standardized volumetric flow rate with an accuracy of + or -5% shall be installed in the digester gas fuel lines to the flare(s), boilers and engines under permits 961168, 961169, 96190, 960191, 960192 and 960193. The totalizing flow meters shall be calibrated in accordance with the manufacturer's specifications. Records of calibration including manufacturer's calibration specifications indicating the flow meter's accuracy and dates of calibration shall be maintained on-site for at least three years and made available to District personnel upon request. (Rule 51)
4. At no time shall the subject equipment cause or contribute to a public nuisance as specified in District Rule 51. If compliance with Rule 51 cannot be demonstrated to the satisfaction of the District, the permittee will take whatever corrective action necessary to meet applicable requirements. If corrective action requires any physical change or modification to the subject equipment the permittee shall apply for and obtain an Authority to Construct for all such modifications prior to making any physical change. (Rule 51)
5. The maximum daily Hydrogen Sulfide content in the Digester gas shall not exceed 84 ppmv for the months from May through September, and 58 PPMV for the remaining of the months of the year. (Rule 51)
6. The hydrogen sulfide concentration of the digester gas shall be measured twice per week on two non-consecutive days of operation. If any hydrogen sulfide concentration exceeds 40 ppmv, the sampling frequency will be increased to three days per week, with all samples taken more than 24 hours apart. Sampling three times per week shall continue until the average of the last three samples is under 40 PPMV. Records of hydrogen sulfide concentration and sampling dates shall be maintained on-site for three years and made available to District personnel upon request. (Rule 51)
7. The calendar year average Hydrogen Sulfide concentrations in the Digester gas shall not exceed 40 ppmv. The calendar year average shall be determined using the monthly averages of the H₂S concentrations measured according to the Condition above. Records of the calendar year average Hydrogen Sulfide concentrations shall be maintained on-site for at least three years and made available to District personnel upon request. (NSR)
8. Hydrogen sulfide concentrations shall be measured with a properly calibrated Portable Hydrogen Sulfide Analyzer (such as an Industrial Scientific ATX-612 H₂S or a Jerome Meter Model 631-X), an appropriate drager tube (such as drager tube #8101991) or any equivalent method approved prior to use in writing by the District. The above monitoring equipment shall be maintained and calibrated in accordance with manufacturer's specifications. The manufacturer's specifications shall be maintained on-site for three years and made available to District personnel upon request. (Rule 51)
9. The flares shall be equipped with optical flame detectors, Stack temperature transmitter, flame arrestors and automatic shut off valves. The stack temperature transmitter shall be calibrated in accordance with the manufacturer's specifications. The manufacturer's specifications and required calibration shall be maintained on-site for three years and made available to District personnel upon request. (Rule 51)
10. The temperature probe shall be functioning and maintained in good working condition and be accurate to +/-5%. The temperature transmitter shall be calibrated in accordance with the manufacturer's specifications. The Exhaust Stack temperature shall be continuously displayed and recorded during incineration. Records of the exhaust temperature and the manufacturer's calibration and maintenance specifications as well as the calibration indicating the accuracy of the temperature transmitter shall be maintained on-site for at least three years and shall be made available to District personnel upon request. (Rule 51)
11. Air Pollution Control equipment shall be maintained in good operating condition and shall be in operation in accordance with Operation and Maintenance (O&M) manual at all times when the process equipment is in operation except for scheduled full or partial facility electrical power shutdowns and non-Air Pollution Control equipment maintenance. The permittee shall keep a copy of the O&M manual and logs of date, duration, purpose and type of shutdown (i.e. either full or partial facility electrical power shutdown, non-Air Pollution Control equipment maintenance) shall be available on-site and make the manual available to the District upon request. (Rule 51)



COUNTY OF SAN DIEGO, AIR POLLUTION CONTROL DISTRICT
10124 OLD GROVE ROAD, SAN DIEGO, CA 92131
PHONE (858) 586-2600 FAX (858) 586-2601
www.sdapcd.org

Sectors: 3, I
Site ID: APCD1976-SITE-02083
App ID: APCD2009-APP-987682

PERMIT ID
APCD2009-PTO-950315

12. The Digester gases shall be incinerated in the flare system and shall have an operating temperature between 1,400° and 1,800° F measured at the top temperature probe and shall have a residence time of no less than 0.6 seconds except:
 - 1) During flare startup and/or during multiple flare transitions, the duration of which shall not exceed 15 minutes.
 - 2) During maintenance activities when the flare is still in operation, the duration of which shall not exceed 192 hours per calendar year for each flare, and/or
 - 3) During all other operations, the duration of which shall not exceed five minutes per day.Logs of the date, duration (in minutes) and purpose of all maintenance activities that result in flare exhaust temperature deviation shall be maintained on-site for three years and made available to the District personnel upon request. (Rule 51)
13. There shall be no release of uncontrolled emissions of digester gas throughout the Plant, except for releases described by the manufacturer design specifications and that occur during construction, repair and routine preventive maintenance. The "Preventive Maintenance Reference Table for the City of San Diego Point Loma Wastewater Treatment Plant Permit #950315" dated January 1, 2012 may be used as a guideline. (Rule 51)
14. Access, facilities, utilities and any necessary safety equipment for source testing and inspection shall be provided upon request of the Air Pollution Control District. (Rule 19)

B. DISTRICT-ONLY ENFORCEABLE CONDITIONS

15. This Air Pollution Control District Permit does not relieve the holder from obtaining permits or authorizations required by other governmental agencies.
16. The permittee shall, upon determination of applicability and written notification by the District, comply with all applicable requirements of the Air Toxics "Hot Spots" Information and Assessment Act (California Health and Safety Code Section 44300 et seq.) (Air Toxic Hot Spots)



Sectors: 3, I
Site ID: APCD1976-SITE-02083
App ID: APCD2003-APP-979972

PERMIT ID
APCD2002-PTO-960190

SD City of Metro Wastewater Dept
Salvador Coria
2392 Kincaid Rd
San Diego CA, 92101

EQUIPMENT ADDRESS
City of San Dieog Metro
Salvador Coria
1902 Gatchell Rd
San Diego CA 92106

PERMIT TO OPERATE

This permit is not valid until required fees are received by the District.

The above is hereby granted a Permit To Operate the article, machine, equipment or contrivance described below. This permit is not transferable to a new owner nor is it valid for operation of the equipment at another location except as specified. This Permit To Operate or copy must be posted on or within 25 feet of the equipment, or readily available on the operating premises.

EQUIPMENT OWNER

City of San Diego - Metropolitan Wastewater Dept Owner Manager 2392 Kincaid Rd, San Diego, CA 92101

EQUIPMENT DESCRIPTION

BOILER: CLEAVER BROOKS MODEL CB 250 (LE), FORCED DRAFT BURNER, DIGESTER GAS FIRED WITH NATURAL GAS BACKUP, 10.2 MM BTU/HR LOW NOX BURNER AND FLUE GAS RECIRCULATION, S/N OL097310, BOILER # 1. 960190AFS29MAY2002

Every person who owns or operates this equipment is required to comply with the conditions listed below and all applicable requirements and District rules, including but not limited to Rules 10, 20, 40, 50, 51.

Fee Schedules: 1 [13A] Boiler/Heater

BEC: 12135

FAILURE TO OPERATE IN COMPLIANCE IS A MISDEMEANOR SUBJECT TO CIVIL AND CRIMINAL PENALTIES

A. FEDERALLY-ENFORCEABLE AND DISTRICT-ENFORCEABLE CONDITIONS

1. The permittee shall comply with the following applicable requirements, unless a specific shield is provided below: Rule 53, Rule 62, and Rule 69.2.
2. Only digester gas & natural gas shall be used as fuel in this boiler unless another fuel is approved in advance in writing by the District. [Rule 69.2]
3. The Higher Heating Value (HHV) of the fuels and the annual (calendar year) fuel usage shall be determined on a monthly basis. The site shall determine and record the digester gas HHV on a monthly basis. At least once every six months an independent analytical laboratory shall determine the digester gas HHV. The natural gas HHV shall be obtained from the serving utility. All these HHV records shall be maintained on-site and shall be made available to the District upon request. [Rule 69.2]
4. If the HHV determined by an independent analytical laboratory varies by more than 5% (+ or -) from the value determined by the facility, then the independent analytical laboratory results shall be used for that month. [Rule 69.2]



COUNTY OF SAN DIEGO, AIR POLLUTION CONTROL DISTRICT
10124 OLD GROVE ROAD, SAN DIEGO, CA 92131
PHONE (858) 586-2600 FAX (858) 586-2601
www.sdapcd.org

Sectors: 3, I
Site ID: APCD1976-SITE-02083
App ID: APCD2003-APP-979972

PERMIT ID
APCD2002-PTO-960190


5. This boiler shall not vent digester gas for boiler blowdown or to remove residual digester gas from digester gas piping system prior to a preventative maintenance event more than two (2) times a day for this boiler. Digester gas venting shall not exceed 15 seconds per event. [Rule 69.2]
6. Digester gas venting shall be logged in the boiler venting log book on the day of the venting. The log shall include the following: Date, time, estimated duration of the digester gas venting procedure, a running total of the number of digester gas venting events during a calendar year. [Rule 69.2]
7. For each month, therms utilized shall be calculated as follows: $\text{HHV (BTU/SCF for the specified month)} \times \text{digester gas (SCF/month for the specified month)} / 100,000 \text{ BTU/therm} + \text{HHV (BTU/SCF for the specified month)} \times \text{natural gas (SCF/month for the specified month)} / 100,000 \text{ BTU/therm} = \text{therms/month}$. (Rule 69.2)
8. By the end of each calendar month, the permittee shall calculate the total therms used by this equipment during the preceding calendar month and the total therms used by this equipment and the boiler that this equipment replaced during the calendar year. (Rule 69.2)
9. The boiler shall have a non-resettable, totalizing meter in the fuel line to measure the mass flow rate of each fuel. (Rule 69.2)
10. The flue gas recirculation system shall be in operation in accordance with the manufacturer's instructions when the equipment is in operation. The manufacturer's instructions shall be maintained on-site and made available to the District upon request. (Rule 69.2)
11. The permittee shall tune the boiler annually in accordance with the manufacturer's recommended tuning procedure. A copy of the manufacturer's recommended tuning procedure shall be maintained on-site and made available to the District upon request. The tune-up shall be performed prior to annual permit renewal, unless otherwise directed in writing by the District. (Rule 69.2)
12. In accordance with District Rule 69.2 (e), continuous monitors shall allow monitoring of the stack gas oxygen concentration in the flue gas and the percentage of flue gas recirculated. These monitors shall be calibrated and maintained in accordance with all applicable local, state, and federal regulations and procedures as approved by the District. (Rule 69.2)
13. All records required by this permit, including fuel usages and tune-up documentation, shall be maintained on-site for a minimum of three years and made available to District personnel upon request. (Rule 69.2)
14. The exhaust gas concentration of sulfur compounds, calculated as Sulfur Dioxide (SO₂) while burning gaseous fuel shall not exceed 0.05% by volume, on a dry basis. (Rule 53)
15. Particulate emissions shall not exceed 0.10 grains per dry standard cubic foot of gas which is standardized to 12 percent of carbon dioxide by volume. (Rule 53)
16. If requested by the District or EPA particulate emissions shall be measured in accordance with District method 5. (Rule 53)
17. If requested by the District or EPA the sulfur content of fuel shall be measured in accordance with ASTM test method d-3246. (Rule 53)
18. Access, facilities, utilities and any necessary safety equipment for source testing and inspection shall be provided upon request of the Air Pollution Control District. (Rule 19)

B. DISTRICT-ONLY ENFORCEABLE CONDITIONS

19. This Air Pollution Control District Permit does not relieve the holder from obtaining permits or authorizations required by other governmental agencies.
20. The permittee shall, upon determination of applicability and written notification by the District, comply with all applicable requirements of the Air Toxics "Hot Spots" Information and Assessment Act (California Health and Safety Code Section 44300 et seq.) (Air Toxic Hot Spots)



Sectors: 3, I
Site ID: APCD1976-SITE-02083
App ID: APCD2003-APP-979972

PERMIT ID
APCD2002-PTO-960191

SD City of Metro Wastewater Dept
Salvador Coria
2392 Kincaid Rd
San Diego CA, 92101

EQUIPMENT ADDRESS
City of San Diego Metro
Salvador Coria
1902 Gatchell Rd
San Diego CA 92106

PERMIT TO OPERATE

This permit is not valid until required fees are received by the District.

The above is hereby granted a Permit To Operate the article, machine, equipment or contrivance described below. This permit is not transferable to a new owner nor is it valid for operation of the equipment at another location except as specified. This Permit To Operate or copy must be posted on or within 25 feet of the equipment, or readily available on the operating premises.

EQUIPMENT OWNER

City of San Diego - Metropolitan Wastewater Dept Owner Manager 2392 Kincaid Rd, San Diego, CA 92101

EQUIPMENT DESCRIPTION

BOILER: CLEAVER BROOKS MODEL CB 250 (LE), FORCED DRAFT BURNER, DIGESTER GAS FIRED WITH NATURAL GAS BACKUP, 10.2 MM BTU/HR LOW NOX BURNER AND FLUE GAS RECIRCULATION, S/N OL097311, BOILER # 2. 960191AFS29MAY2002

Every person who owns or operates this equipment is required to comply with the conditions listed below and all applicable requirements and District rules, including but not limited to Rules 10, 20, 40, 50, 51.

Fee Schedules: 1 [13A] Boiler/Heater

BEC: 12181

FAILURE TO OPERATE IN COMPLIANCE IS A MISDEMEANOR SUBJECT TO CIVIL AND CRIMINAL PENALTIES

A. FEDERALLY-ENFORCEABLE AND DISTRICT-ENFORCEABLE CONDITIONS

1. The permittee shall comply with the following applicable requirements, unless a specific shield is provided below: Rule 53, Rule 62, and Rule 69.2. (Rule 1421)
2. Only digester gas & natural gas shall be used as fuel in this boiler unless another fuel is approved in advance in writing by the District. (Rule 69.2)
3. The Higher Heating Value (HHV) of the fuels and the annual (calendar year) fuel usage shall be determined on a monthly basis. The site shall determine and record the Digester Gas HHV on a monthly basis. At least once every six months an independent analytical laboratory shall determine the Digester Gas HHV. The Natural Gas HHV shall be obtained from the serving Utility. All these HHV records shall be maintained on-site and shall be made available to the District upon request. (Rule 69.2)
4. If the HHV determined by an independent analytical laboratory varies by more than 5 percent (+ or -) from the value determined by the facility, then the independent analytical laboratory results shall be used for that month. (Rule 69.2)



COUNTY OF SAN DIEGO, AIR POLLUTION CONTROL DISTRICT
10124 OLD GROVE ROAD, SAN DIEGO, CA 92131
PHONE (858) 586-2600 FAX (858) 586-2601
www.sdapcd.org

Sectors: 3, I
Site ID: APCD1976-SITE-02083
App ID: APCD2003-APP-979972

PERMIT ID
APCD2002-PTO-960191


5. This Boiler shall not vent Digester Gas for Boiler blow-down or to remove residual Digester Gas from Digester Gas Piping System prior to a preventative maintenance event more than two (2) times a day for this Boiler. Digester Gas venting shall not exceed 15 seconds per event. (Rule 69.2)
6. Digester Gas venting shall be logged in the Boiler Venting Logbook on the day of the venting. The Log shall include the following:
 - date
 - time
 - estimated duration of the Digester Gas venting procedure
 - a running total of the number of Digester Gas venting events during a calendar year (Rule 69.2)
7. For each month, therms utilized shall be calculated as follows:
$$\text{HHV (BTU/SCF for the specified month)} \times \text{Digester Gas (SCF/month for the specified month)} / 100,000 \text{ BTU/therm} + \text{HHV (BTU/SCF for the specified month)} \times \text{Natural Gas (SCF/month for the specified month)} / 100,000 \text{ BTU/therm} = \text{therms/month. [Rule 69.2]}$$
8. By the end of each calendar month, the Permittee shall calculate the total therms used by this equipment during the preceding calendar month and the total therms used by this equipment and the Boiler that this equipment replaced during the calendar year. (Rule 69.2)
9. The Boiler shall have a non-resettable, totalizing meter in the fuel line to measure the mass flow rate of each fuel. (Rule 69.2)
10. The Flue Gas Recirculation System shall be in operation in accordance with the manufacturer's instructions when the equipment is in operation. The manufacturer's instructions shall be maintained on-site and made available to the District upon request. (Rule 69.2)
11. The Permittee shall tune the Boiler annually in accordance with the manufacturer's recommended tuning procedure. A copy of the manufacturer's recommended tuning procedure shall be maintained on-site and made available to the District upon request. The tune-up shall be performed prior to annual Permit renewal unless otherwise directed in writing by the District. (Rule 69.2)
12. In accordance with District Rule 69.2(E), continuous monitors shall allow monitoring of the Stack Gas Oxygen concentration in the Flue Gas and the percentage of Flue Gas recirculated. These monitors shall be calibrated and maintained in accordance with all applicable Local, State and Federal Regulations and Procedures as approved by the District. (Rule 69.2)
13. All records required by this Permit, including fuel usages and tune-up documentation, shall be maintained on-site for a minimum of three years and made available to District personnel upon request. (Rule 69.2)
14. The exhaust gas concentration of Sulfur compounds calculated as Sulfur Dioxide (SO₂) while burning gaseous fuel shall not exceed 0.05% by volume on a dry basis. (Rule 53)
15. Particulate Emissions shall not exceed 0.10 grains per dry standard cubic foot of gas which is standardized to 12 percent of Carbon Dioxide by volume. (Rule 53)
16. If requested by the District or EPA, Particulate Emissions shall be measured in accordance with District Method 5. (Rule 53)
17. If requested by the District or EPA, the Sulfur content of fuel shall be measured in accordance with ASTM Test Method D-3246. (Rule 53)
18. Access, facilities, utilities and any necessary safety equipment for source testing and inspection shall be provided upon request of the Air Pollution Control District. (Rule 19)

B. DISTRICT-ONLY ENFORCEABLE CONDITIONS

19. This Air Pollution Control District Permit does not relieve the holder from obtaining permits or authorizations required by other governmental agencies.



COUNTY OF SAN DIEGO, AIR POLLUTION CONTROL DISTRICT
10124 OLD GROVE ROAD, SAN DIEGO, CA 92131
PHONE (858) 586-2600 FAX (858) 586-2601
www.sdapcd.org

Sectors: 3, I
Site ID: APCD1976-SITE-02083
App ID: APCD2003-APP-979972

PERMIT ID
APCD2002-PTO-960191


20. The permittee shall, upon determination of applicability and written notification by the District, comply with all applicable requirements of the Air Toxics "Hot Spots" Information and Assessment Act (California Health and Safety Code Section 44300 et seq.)



Sectors: 3, I
Site ID: APCD1976-SITE-02083
App ID: APCD2000-APP-975796

PERMIT ID
APCD2002-PTO-960192

SD City of Metro Wastewater Dept
Salvador Coria
2392 Kincaid Rd
San Diego CA, 92101

EQUIPMENT ADDRESS
City of San Diego Metro
Salvador Coria
1902 Gatchell Rd
San Diego CA 92106

PERMIT TO OPERATE

This permit is not valid until required fees are received by the District.

The above is hereby granted a Permit To Operate the article, machine, equipment or contrivance described below. This permit is not transferable to a new owner nor is it valid for operation of the equipment at another location except as specified. This Permit To Operate or copy must be posted on or within 25 feet of the equipment, or readily available on the operating premises.

EQUIPMENT OWNER

City of San Diego - Metropolitan Wastewater Dept Owner Manager 2392 Kincaid Rd, San Diego, CA 92101

EQUIPMENT DESCRIPTION

BOILER: CLEAVER BROOKS MODEL CB 250 (LE), FORCED DRAFT BURNER, DIGESTER GAS FIRED WITH NATURAL GAS BACKUP, 10.2 MM BTU/HR LOW NOX BURNER AND FLUE GAS RECIRCULATION, S/N OL097312, BOILER # 3. 960192AFS29MAY2002

Every person who owns or operates this equipment is required to comply with the conditions listed below and all applicable requirements and District rules, including but not limited to Rules 10, 20, 40, 50, 51.

Fee Schedules: 1 [13A] Boiler/Heater

BEC: 12182

FAILURE TO OPERATE IN COMPLIANCE IS A MISDEMEANOR SUBJECT TO CIVIL AND CRIMINAL PENALTIES

A. FEDERALLY-ENFORCEABLE AND DISTRICT-ENFORCEABLE CONDITIONS

1. The permittee shall comply with the following applicable requirements, unless a specific shield is provided below: Rule 53, Rule 62, and Rule 69.2. (Rule 1421)
2. Only digester gas & natural gas shall be used as fuel in this boiler unless another fuel is approved in advance in writing by the District. (Rule 69.2)
3. The Higher Heating Value (HHV) of the fuels and the annual (calendar year) fuel usage shall be determined on a monthly basis. The site shall determine and record the digester gas HHV on a monthly basis. At least once every six months an independent analytical laboratory shall determine the digester gas HHV. The natural gas HHV shall be obtained from the serving utility. All these HHV records shall be maintained on-site and shall be made available to the District upon request. (Rule 69.2)
4. If the HHV determined by an independent analytical laboratory varies by more than 5 percent (+ or -) from the value determined by the facility, then the independent analytical laboratory results shall be used for that month. (Rule 69.2)



COUNTY OF SAN DIEGO, AIR POLLUTION CONTROL DISTRICT
10124 OLD GROVE ROAD, SAN DIEGO, CA 92131
PHONE (858) 586-2600 FAX (858) 586-2601
www.sdapcd.org

Sectors: 3, I
Site ID: APCD1976-SITE-02083
App ID: APCD2000-APP-975796

PERMIT ID
APCD2002-PTO-960192



5. This boiler shall not vent digester gas for boiler blowdown or to remove residual digester gas from digester gas piping system prior to a preventative maintenance event more than two (2) times a day for this boiler. Digester gas venting shall not exceed 15 seconds per event. (Rule 69.2)
6. Digester gas venting shall be logged in the boiler venting log book on the day of the venting. The log shall include the following: Date, time, estimated duration of the digester gas venting procedure, a running total of the number of digester gas venting events during a calendar year. (Rule 69.2)
7. For each month, therms utilized shall be calculated as follows: $\text{HHV (BTU/SCF for the specified month)} \times \text{digester gas (SCF/month for the specified month)} / 100,000 \text{ BTU/therm} + \text{HHV (BTU/SCF for the specified month)} \times \text{natural gas (SCF/month for the specified month)} / 100,000 \text{ BTU/therm} = \text{therms/month}$. (Rule 69.2)
8. By the end of each calendar month, the permittee shall calculate the total therms used by this equipment during the preceding calendar month and the total therms used by this equipment and the boiler that this equipment replaced during the calendar year. (Rule 69.2)
9. The boiler shall have a non-resettable, totalizing meter in the fuel line to measure the mass flow rate of each fuel. (Rule 69.2)
10. The Flue Gas Recirculation System shall be in operation in accordance with the manufacturer's instructions when the equipment is in operation. The manufacturer's instructions shall be maintained on-site and made available to the District upon request. (Rule 69.2)
11. The permittee shall tune the boiler annually in accordance with the manufacturer's recommended tuning procedure. A copy of the manufacturer's recommended tuning procedure shall be maintained on-site and made available to the District upon request. The tune-up shall be performed prior to annual permit renewal, unless otherwise directed in writing by the District. (Rule 69.2)
12. In accordance with District Rule 69.2 (e), continuous monitors shall allow monitoring of the stack gas oxygen concentration in the flue gas and the percentage of flue gas recirculated. These monitors shall be calibrated and maintained in accordance with all applicable local, state, and federal regulations and procedures as approved by the District. (Rule 69.2)
13. All records required by this permit, including fuel usages and tune-up documentation, shall be maintained on-site for a minimum of three years and made available to District personnel upon request. (Rule 69.2)
14. The exhaust gas concentration of sulfur compounds, calculated as Sulfur Dioxide (SO₂) while burning gaseous fuel shall not exceed 0.05% by volume, on a dry basis. (Rule 53)
15. Particulate emissions shall not exceed 0.10 grains per dry standard cubic foot of gas which is standardized to 12 percent of carbon dioxide by volume. (Rule 53)
16. If requested by the District or EPA particulate emissions shall be measured in accordance with District method 5. (Rule 53)
17. If requested by the District or EPA the sulfur content of fuel shall be measured in accordance with ASTM test method D-3246. (Rule 53)
18. Access, facilities, utilities and any necessary safety equipment for source testing and inspection shall be provided upon request of the Air Pollution Control District. (Rule 19)

B. DISTRICT-ONLY ENFORCEABLE CONDITIONS

19. This Air Pollution Control District Permit does not relieve the holder from obtaining permits or authorizations required by other governmental agencies.
20. The permittee shall, upon determination of applicability and written notification by the District, comply with all applicable requirements of the Air Toxics "Hot Spots" Information and Assessment Act (California Health and Safety Code Section 44300 et seq.) (Air Toxics Hot Spots)



Sectors: 3, I
Site ID: APCD1976-SITE-02083
App ID: APCD1996-APP-960193

PERMIT ID
APCD2002-PTO-960193

SD City of Metro Wastewater Dept
Salvador Coria
2392 Kincaid Rd
San Diego CA, 92101

EQUIPMENT ADDRESS
City of San Diego Metro
Salvador Coria
1902 Gatchell Rd
San Diego CA 92106

PERMIT TO OPERATE

This permit is not valid until required fees are received by the District.

The above is hereby granted a Permit To Operate the article, machine, equipment or contrivance described below. This permit is not transferable to a new owner nor is it valid for operation of the equipment at another location except as specified. This Permit To Operate or copy must be posted on or within 25 feet of the equipment, or readily available on the operating premises.

EQUIPMENT OWNER

City of San Diego - Metropolitan Wastewater Dept Owner Manager 2392 Kincaid Rd, San Diego, CA 92101

EQUIPMENT DESCRIPTION

BOILER: CLEAVER BROOKS MODEL CB 250 (LE), FORCED DRAFT BURNER, DIGESTER GAS FIRED WITH NATURAL GAS BACKUP, 10.2 MM BTU/HR LOW NOX BURNER AND FLUE GAS RECIRCULATION, S/N OL097313, BOILER # 4. 960193AFS29MAY2002

Every person who owns or operates this equipment is required to comply with the conditions listed below and all applicable requirements and District rules, including but not limited to Rules 10, 20, 40, 50, 51.

Fee Schedules: 1 [13A] Boiler/Heater
BEC: 12183

FAILURE TO OPERATE IN COMPLIANCE IS A MISDEMEANOR SUBJECT TO CIVIL AND CRIMINAL PENALTIES

A. FEDERALLY-ENFORCEABLE AND DISTRICT-ENFORCEABLE CONDITIONS

- 1. The permittee shall comply with the following applicable requirements, unless a specific shield is provided below: Rule 53, Rule 62, and Rule 69.2. (Rule 1421)
2. Only digester gas & natural gas shall be used as fuel in this boiler unless another fuel is approved in advance in writing by the District. (Rule 69.2)
3. The Higher Heating Value (HHV) of the fuels and the annual (calendar year) fuel usage shall be determined on a monthly basis. The site shall determine and record the Digester Gas HHV on a monthly basis. At least once every six months an independent analytical laboratory shall determine the Digester Gas HHV. The Natural Gas HHV shall be obtained from the serving Utility. All these HHV records shall be maintained on-site and shall be made available to the District upon request. (Rule 69.2)
4. If the HHV determined by an independent analytical laboratory varies by more than 5 percent (+ or -) from the value determined by the facility, then the independent analytical laboratory results shall be used for that month. (Rule 69.2)



COUNTY OF SAN DIEGO, AIR POLLUTION CONTROL DISTRICT
10124 OLD GROVE ROAD, SAN DIEGO, CA 92131
PHONE (858) 586-2600 FAX (858) 586-2601
www.sdapcd.org

Sectors: 3, I
Site ID: APCD1976-SITE-02083
App ID: APCD1996-APP-960193

PERMIT ID
APCD2002-PTO-960193



5. This Boiler shall not vent Digester Gas for Boiler blow-down or to remove residual Digester Gas from Digester Gas Piping System prior to a preventative maintenance event more than two (2) times a day for this Boiler. Digester Gas venting shall not exceed 15 seconds per event. (Rule 69.2)
6. Digester Gas venting shall be logged in the Boiler Venting Logbook on the day of the venting. The Log shall include the following:
 - date
 - time
 - estimated duration of the Digester Gas venting procedure
 - a running total of the number of Digester Gas venting events during a calendar year (Rule 69.2)
7. For each month, therms utilized shall be calculated as follows:
$$\text{HHV (BTU/SCF for the specified month)} \times \text{Digester Gas (SCF/month for the specified month)} / 100,000 \text{ BTU/therm} + \text{HHV (BTU/SCF for the specified month)} \times \text{Natural Gas (SCF/month for the specified month)} / 100,000 \text{ BTU/therm} = \text{therms/month. (Rule 69.2)}$$
8. By the end of each calendar month, the Permittee shall calculate the total therms used by this equipment during the preceding calendar month and the total therms used by this equipment and the Boiler that this equipment replaced during the calendar year. (Rule 69.2)
9. The Boiler shall have a non-resettable, totalizing meter in the fuel line to measure the mass flow rate of each fuel. (Rule 69.2)
10. The Flue Gas Recirculation System shall be in operation in accordance with the manufacturer's instructions when the equipment is in operation. The manufacturer's instructions shall be maintained on-site and made available to the District upon request. (Rule 69.2)
11. The Permittee shall tune the Boiler annually in accordance with the manufacturer's recommended tuning procedure. A copy of the manufacturer's recommended tuning procedure shall be maintained on-site and made available to the District upon request. The tune-up shall be performed prior to annual Permit renewal unless otherwise directed in writing by the District. (Rule 69.2)
12. In accordance with District Rule 69.2(E), continuous monitors shall allow monitoring of the Stack Gas Oxygen concentration in the Flue Gas and the percentage of Flue Gas recirculated. These monitors shall be calibrated and maintained in accordance with all applicable Local, State and Federal Regulations and Procedures as approved by the District. (Rule 69.2)
13. All records required by this Permit, including fuel usages and tune-up documentation, shall be maintained on-site for a minimum of three years and made available to District personnel upon request. (Rule 69.2)
14. The exhaust gas concentration of Sulfur compounds calculated as Sulfur Dioxide (SO₂) while burning gaseous fuel shall not exceed 0.05% by volume on a dry basis. (Rule 53)
15. Particulate Emissions shall not exceed 0.10 grains per dry standard cubic foot of gas which is standardized to 12 percent of Carbon Dioxide by volume. (Rule 53)
16. If requested by the District or EPA, Particulate Emissions shall be measured in accordance with District Method 5. (Rule 53)
17. If requested by the District or EPA, the Sulfur content of fuel shall be measured in accordance with ASTM Test Method D-3246. (Rule 53)
18. Access, facilities, utilities and any necessary safety equipment for source testing and inspection shall be provided upon request of the Air Pollution Control District. (Rule 19)

B. DISTRICT-ONLY ENFORCEABLE CONDITIONS

19. This Air Pollution Control District Permit does not relieve the holder from obtaining permits or authorizations required by other governmental agencies.



COUNTY OF SAN DIEGO, AIR POLLUTION CONTROL DISTRICT
10124 OLD GROVE ROAD, SAN DIEGO, CA 92131
PHONE (858) 586-2600 FAX (858) 586-2601
www.sdapcd.org

Sectors: 3, I
Site ID: APCD1976-SITE-02083
App ID: APCD1996-APP-960193

PERMIT ID
APCD2002-PTO-960193


20. The permittee shall, upon determination of applicability and written notification by the District, comply with all applicable requirements of the Air Toxics "Hot Spots" Information and Assessment Act (California Health and Safety Code Section 44300 et seq.) (Air Toxics Hot Spots)



Sectors: 3, I
Site ID: APCD1976-SITE-02083
App ID: APCD1997-APP-961168

PERMIT ID
APCD2004-PTO-961168


SD City of Metro Wastewater Dept
Salvador Coria
2392 Kincaid Rd
San Diego CA, 92101

EQUIPMENT ADDRESS
City of San Diego Metro
Salvador Coria
1902 Gatchell Rd
San Diego CA 92106

PERMIT TO OPERATE

This permit is not valid until required fees are received by the District.

The above is hereby granted a Permit To Operate the article, machine, equipment or contrivance described below. This permit is not transferable to a new owner nor is it valid for operation of the equipment at another location except as specified. This Permit To Operate or copy must be posted on or within 25 feet of the equipment, or readily available on the operating premises.

EQUIPMENT OWNER

City of San Diego - Metropolitan Wastewater Dept Owner Manager 2392 Kincaid Rd, San Diego, CA 92101

EQUIPMENT DESCRIPTION

CATERPILLAR MODEL G-3612TA GAS ENGINE, S/N 1YG00124 (DUAL FUEL), 3200 HP, KATO 2300 KW GENERATOR WITH WASTE HEAT RECOVERY; DIGESTER GAS FUEL WITH NATURAL GAS BACKUP. 961168AFS16AUG2000 976381EAD02DEC2002JFT APP979972CONDCHGJUL0904

Every person who owns or operates this equipment is required to comply with the conditions listed below and all applicable requirements and District rules, including but not limited to Rules 10, 20, 40, 50, 51.

Fee Schedules: 1 [34B] Cogeneration Engine w/ Emission Controls
1 [92F] NOx and CO Source Test

BEC: 11783

FAILURE TO OPERATE IN COMPLIANCE IS A MISDEMEANOR SUBJECT TO CIVIL AND CRIMINAL PENALTIES

A. FEDERALLY-ENFORCEABLE AND DISTRICT-ENFORCEABLE CONDITIONS

1. The Permittee shall comply with the following applicable Requirements unless a specific Shield is provided below: Rule 53, Rule 62 and Rule 69.4. (Rule 1421)
2. When operating on Natural Gas or Digester Gas, emissions of Oxides of Nitrogen (NOx) calculated as Nitrogen Dioxide shall not exceed 42 Parts Per Million by Volume on a Dry basis (PPMVD) corrected to 15% Oxygen. (Rule 69.4)
3. When operating on Natural Gas or Digester Gas, emissions of Carbon Monoxide (CO) shall not exceed 280 Parts Per Million by Volume on a Dry basis (PPMVD) corrected to 15% Oxygen. (NSR)
4. Only digester gas or natural gas shall be used as fuel in these engines. (Rule 69.4)
5. Except for purging digester gas and natural gas from the fuel lines, as a safety precaution during scheduled maintenance period, digester gas and natural gas shall not be released into the atmosphere and shall be consumed in District permitted flares, boilers, or engines. (Rule 69.4)



COUNTY OF SAN DIEGO, AIR POLLUTION CONTROL DISTRICT
10124 OLD GROVE ROAD, SAN DIEGO, CA 92131
PHONE (858) 586-2600 FAX (858) 586-2601
www.sdapcd.org

Sectors: 3, I
Site ID: APCD1976-SITE-02083
App ID: APCD1997-APP-961168

PERMIT ID
APCD2004-PTO-961168



6. Non-resettable totalizing fuel meters with an accuracy of +/- 5% in each gas fuel line of the engine shall measure the volumetric flow rate, temperature and pressure of the fuel. Any correction factors shall be displayed on the meters. (Rule 69.4)
 7. Fuel use records shall be maintained for each fuel and shall be made available to the District on request. (Rule 69.4)
 8. The engine shall be equipped with an engine hour run meter to record the total elapsed operating time of the engine. (Rule 69.4)
 9. Owner or operator shall conduct annual maintenance of the engine as recommended by the manufacturer or as specified by any other maintenance procedure approved by in writing by the Air Pollution Control Officer. (Rule 69.4)
 10. The following information on the engine shall be kept onsite for at least the same period of time as the engine which the records apply are located at the site and made available to the District upon request:
 - (a) Engine manufacturer name, model number, brake horsepower output rating;
 - (b) Combustion methods (lean burn);
 - (c) Fuel type;
 - (d) Manual of recommended maintenance provided by the manufacturer; and
 - (e) Records of annual engine maintenance, including dates of maintenance performance.(Rule 69.4)
 11. This equipment shall be source tested on an annual basis using District approved test methods to ensure compliance with District emission standards for NOx and CO prior to Permit renewal. Permittee shall provide access, facilities, utilities and any necessary safety equipment for source testing and inspection upon request of the Air Pollution Control District. (Rule 69.4)
 12. Concentrations of NOx, CO, and O2 in the Engine exhaust shall be measured in accordance with SDC APCD Test Method 100. The averaging periods for the measurement and Engine brake horsepower output during the measurement shall be in accordance with Rule 69.4(F). (Rule 69.4, NSR)
 13. Emissions Source Testing shall be performed at no less than 80 percent of the brake horsepower rating. If an Owner or Operator of an Engine demonstrates to the satisfaction of the Air Pollution Control Officer that the Engine does not operate at these Conditions, then emissions Source Testing shall be performed at the highest achievable continuous brake horsepower rating or under typical duty cycle or operational mode of the Engine. (Rule 69.4)
 14. The usage of 100 percent natural gas as a fuel for either of the two engines shall be for emergency use only and limited to those periods where the digester gas supply system is undergoing repair, not to exceed a total of thirty (30) days per year per engine unless approved in writing by the District in advance. (NSR)
 15. The exhaust gas concentration of Sulfur compounds calculated as Sulfur Dioxide (SO2) while burning gaseous fuel shall not exceed 0.05% by volume on a dry basis. (Rule 53)
 16. Particulate Emissions shall not exceed 0.10 grains per dry standard cubic foot of gas which is standardized to 12 percent of Carbon Dioxide by volume. (Rule 53)
 17. If requested by the District or EPA, Particulate Emissions shall be measured in accordance with District Method 5. (Rule 53)
 18. If requested by the District or EPA, the Sulfur content of fuel shall be measured in accordance with ASTM Test Method D-3246. (Rule 53)
 19. All records shall be kept on site at least three years unless otherwise indicated by the conditions of this permit. (Rule 69.4)
 20. Access, facilities, utilities and any necessary safety equipment for source testing and inspection shall be provided upon request of the Air Pollution Control District. (Rule 19)
- B. DISTRICT-ONLY ENFORCEABLE CONDITIONS**
21. This Air Pollution Control District Permit does not relieve the holder from obtaining permits or authorizations required by other governmental agencies.



COUNTY OF SAN DIEGO, AIR POLLUTION CONTROL DISTRICT
10124 OLD GROVE ROAD, SAN DIEGO, CA 92131
PHONE (858) 586-2600 FAX (858) 586-2601
www.sdapcd.org

Sectors: 3, I
Site ID: APCD1976-SITE-02083
App ID: APCD1997-APP-961168

PERMIT ID
APCD2004-PTO-961168



22. The permittee shall, upon determination of applicability and written notification by the District, comply with all applicable requirements of the Air Toxics "Hot Spots" Information and Assessment Act (California Health and Safety Code Section 44300 et seq.) (Air Toxics Hot Spots)



Sectors: 3, I
Site ID: APCD1976-SITE-02083
App ID: APCD1997-APP-961169

PERMIT ID
APCD2004-PTO-961169

SD City of Metro Wastewater Dept
Salvador Coria
2392 Kincaid Rd
San Diego CA, 92101

EQUIPMENT ADDRESS
City of San Diego Metro
Salvador Coria
1902 Gatchell Rd
San Diego CA 92106

PERMIT TO OPERATE

This permit is not valid until required fees are received by the District.

The above is hereby granted a Permit To Operate the article, machine, equipment or contrivance described below. This permit is not transferable to a new owner nor is it valid for operation of the equipment at another location except as specified. This Permit To Operate or copy must be posted on or within 25 feet of the equipment, or readily available on the operating premises.

EQUIPMENT OWNER

City of San Diego - Metropolitan Wastewater Dept Owner Manager 2392 Kincaid Rd, San Diego, CA 92101

EQUIPMENT DESCRIPTION

CATERPILLAR MODEL G-312TA GAS ENGINE, S/N 1YG00125 (DUAL FUEL), 3200 HP, KATO 2300 KW GENERATOR WITH WASTE HEAT RECOVERY; DIGESTER GAS FUEL WITH NATURAL GAS BACKUP. 961169AFS16AUG2000 976381EAD04DEC2002JFTAPP979972CONDCHGJUL0904

Every person who owns or operates this equipment is required to comply with the conditions listed below and all applicable requirements and District rules, including but not limited to Rules 10, 20, 40, 50, 51.

Fee Schedules: 1 [34B] Cogeneration Engine w/ Emission Controls
1 [92F] NOx and CO Source Test

BEC: 11783

FAILURE TO OPERATE IN COMPLIANCE IS A MISDEMEANOR SUBJECT TO CIVIL AND CRIMINAL PENALTIES

A. FEDERALLY-ENFORCEABLE AND DISTRICT-ENFORCEABLE CONDITIONS

1. The permittee shall comply with the following applicable requirements, unless a specific shield is provided below: Rule 53, Rule 62 and Rule 69.4. (Rule 1421)
2. When operating on natural gas or digester gas, emissions of Oxides of Nitrogen (NOx), calculated as nitrogen dioxide shall not exceed 42 Parts Per Million Volume on a Dry basis (PPMVD) corrected to 15% oxygen. (Rule 69.4)
3. When operating on natural gas or digester gas, emissions of Carbon Monoxide (CO) shall not exceed 280 Parts Per Million Volume on a Dry basis (PPMVD) corrected to 15% oxygen. (NSR)
4. Only digester gas or natural gas shall be used as fuel in these engines. (Rule 69.4)
5. Except for purging digester gas and natural gas from fuel lines, as a safety precaution during scheduled maintenance periods, digester gas and natural gas shall not be released into the atmosphere and shall be consumed in District permitted flares, boilers, or engines. (Rule 69.4)



COUNTY OF SAN DIEGO, AIR POLLUTION CONTROL DISTRICT
10124 OLD GROVE ROAD, SAN DIEGO, CA 92131
PHONE (858) 586-2600 FAX (858) 586-2601
www.sdapcd.org

Sectors: 3, I
Site ID: APCD1976-SITE-02083
App ID: APCD1997-APP-961169

PERMIT ID
APCD2004-PTO-961169



6. Non resettable totalizing fuel meters with an accuracy of +/- 5% in each gas fuel line of the engine shall measure the volumetric flow rate, temperature and pressure of the fuel. Any correction factors shall be displayed on the meters. (Rule 69.4)
7. Fuel use records shall be maintained for each fuel and shall be made available to the District on request. (Rule 69.4)
8. The engine shall be equipped with an engine hour run meter to record the total elapsed operating time of the engine. (Rule 69.4)
9. Owner or operator shall conduct annual maintenance of the engine as recommended by the manufacturer or as specified by any other maintenance procedure approved by in writing by the Air pollution Control Officer. (Rule 69.4)
10. The following information on the engine shall be kept on-site for at least the same period of time as the engine which the records apply are located at the site and made available to the District upon request:
 - (a) Engine manufacturer name, model number, brake horsepower output rating;
 - (b) Combustion methods (lean burn);
 - (c) Fuel type;
 - (d) Manual of recommended maintenance provided by the manufacturer; and
 - (e) Records of annual engine maintenance, including dates of maintenance performance.(Rule 69.4)
11. This equipment shall be source tested on an annual basis using District-approved test methods to ensure compliance with District emission standards for NOx and CO prior to permit renewal. Permittee shall provide access, facilities, utilities and any necessary safety equipment for source testing and inspection upon request of the Air Pollution Control District. (Rule 69.4)
12. Concentrations of NOx, CO, and O2 in the engine exhaust shall be measured in accordance with SDC APCD test method 100. The averaging periods for the measurement and engine brake horsepower output during the measurement shall be in accordance with Rule 69.4 (f). (Rule 69.4, NSR)
13. Emissions source testing shall be performed at no less than 80 percent of the brake horsepower rating. If an owner or operator of an engine demonstrates to the satisfaction of the Air Pollution Control Officer that the engine does not operate at these conditions, then emissions source testing shall be performed at the highest achievable continuous brake horsepower rating or under typical duty cycle or operational mode of the engine. (Rule 69.4)
14. The usage of 100 percent natural gas as a fuel for either of the two engines shall be for emergency use only and limited to those periods where the digester gas supply system is under going repair, not to exceed a total of thirty (30) days per year per engine unless approved in writinig by the District in advance. (NSR)
15. The exhaust gas concentration of sulfur compounds, calculated as Sulfur Dioxide (SO2) while burning gaseous fuel shall not exceed 0.05% by volume, on a dry basis. (Rule 53)
16. Particulate emissions shall not exceed 0.10 grains per dry standard cubic foot of gas which is standardized to 12 percent of carbon dioxide by volume. (Rule 53)
17. If requested by the District or EPA particulate emissions shall be measured in accordance with District method 5. (Rule 53)
18. If requested by the District or EPA the sulfur content of fuel shall be measured in accordance with ASTM test method D-3246. (Rule 53)
19. All records shall be kept on-site at least three years unless otherwise indicated by the conditions of this permit. (Rule 69.4)
20. Access, facilities, utilities and any necessary safety equipment for source testing and inspection shall be provided upon request of the Air Pollution Control District. (Rule 19)
22. The permittee shall, upon determination of applicability and written notification by the District, comply with all applicable requirements of the Air Toxics "Hot Spots" Information and Assessment Act (California Health and Safety Code Section 44300 et seq.) (Air Toxic Hot Spots)



COUNTY OF SAN DIEGO, AIR POLLUTION CONTROL DISTRICT
10124 OLD GROVE ROAD, SAN DIEGO, CA 92131
PHONE (858) 586-2600 FAX (858) 586-2601
www.sdapcd.org

Sectors: 3, I
Site ID: APCD1976-SITE-02083
App ID: APCD1997-APP-961169

PERMIT ID
APCD2004-PTO-961169


B. DISTRICT-ONLY ENFORCEABLE CONDITIONS

21. This Air Pollution Control District Permit does not relieve the holder from obtaining permits or authorizations required by other governmental agencies.



COUNTY OF SAN DIEGO, AIR POLLUTION CONTROL DISTRICT
10124 OLD GROVE ROAD, SAN DIEGO, CA 92131
PHONE (858) 586-2600 FAX (858) 586-2601
www.sdapcd.org

Sectors: 3, I
Site ID: APCD1976-SITE-02083
App ID: APCD2014-APP-003702

PERMIT ID
APCD2015-PTO-002381

SD City of Metro Wastewater Dept
Salvador Coria
2392 Kincaid Rd
San Diego CA, 92101

EQUIPMENT ADDRESS
City of San Diego-Metropolitan
Salvador Coria
1902 Gatchell Road
San Diego CA 92106

PERMIT TO OPERATE

This permit is not valid until required fees are received by the District.

The above is hereby granted a Permit To Operate the article, machine, equipment or contrivance described below. This permit is not transferable to a new owner nor is it valid for operation of the equipment at another location except as specified. This Permit To Operate or copy must be posted on or within 25 feet of the equipment, or readily available on the operating premises.

EQUIPMENT OWNER

SD City of Metro Wastewater Dept Owner Manager 2392 Kincaid Rd, San Diego, CA 92101

EQUIPMENT DESCRIPTION

Five (5) prime diesel engines (ATCM portable): each engine rated up to 100 bhp, Tier 4 certified.

Every person who owns or operates this equipment is required to comply with the conditions listed below and all applicable requirements and District rules, including but not limited to Rules 10, 20, 40, 50, 51.

Fee Schedules: 5 [34G] Engine for Non-Emergency and Non-Cogeneration Operation

BEC: APCD2015-CON-001079

FAILURE TO OPERATE IN COMPLIANCE IS A MISDEMEANOR SUBJECT TO CIVIL AND CRIMINAL PENALTIES

A. FEDERALLY-ENFORCEABLE AND DISTRICT-ENFORCEABLE CONDITIONS

3. Each engine shall have an original manufacturer label containing the following information: make, model, family number and serial number. [Rule 10]
4. Each engine shall not operate at this location for more than 960 hours per calendar year, as evidenced by operational log records. Engine identifications (Make, Model, Serial Number, PERP Number), hours of operation and hour meter readings shall be recorded on each day of engine usage. [Rule 20.3, Rule 1200]
5. This engine shall use only carb diesel fuel. [Rule 69.4.1, 17 CCR 93116]
6. Visible emissions including crank case smoke shall comply with Air Pollution Control District Rule 50. [Rule 50]



COUNTY OF SAN DIEGO, AIR POLLUTION CONTROL DISTRICT
10124 OLD GROVE ROAD, SAN DIEGO, CA 92131
PHONE (858) 586-2600 FAX (858) 586-2601
www.sdapcd.org

Sectors: 3, I
Site ID: APCD1976-SITE-02083
App ID: APCD2014-APP-003702

PERMIT ID
APCD2015-PTO-002381


7. A non-resettable engine hour meter shall be installed on this engine, maintained in good working order, and used for recording engine operation hours. If a meter is replaced when the emission unit is operating on site, the Air Pollution Control District's Compliance Division shall be notified in writing within 10 calendar days. The written notification shall include the following information:
 - (a) old meter's hour reading
 - (b) replacement meter's manufacturer name, model and serial number if available and current hour reading on replacement meter
 - (c) copy of receipt of new meter or of installation work order. A copy of the meter replacement notification shall be maintained onsite and made available to the Air Pollution Control District upon request.
[Rule 69.4.1; 17CCR 93116]
8. The owner or operator of this engine shall conduct periodic maintenance of the engine and add-on control equipment, if any, as recommended by the engine and control equipment manufacturers or as specified by the engine servicing company's maintenance procedures. The periodic maintenance shall be conducted at least once every 4000 hours of operation, or every six months, whichever occurs first. [Rule 69.4.1]
9. The owner or operator shall maintain documentation identifying all fuel used in this engine as CARB diesel or an alternative fuel meeting the requirements of 17 CCR 93116.3(a) and with a sulfur content not to exceed 15 ppm sulfur by weight. These records shall be kept on site for at least the same period of time as the engine to which the records apply is located at the site. [Rule 69.4 and/or 69.4.1, 17 CCR 93116]
10. The owner or operator of the engine shall maintain a manual of recommended maintenance provided by the manufacturer, or maintenance procedures specified by the engine servicing company on site for at least the same period of time as the engine to which the records apply is located at the site. [Rule 69.4.1]
13. All operational and maintenance logs required by this permit shall be kept a minimum of 3 years unless otherwise indicated by the conditions of this permit, and these records shall be made available to the Air Pollution Control District upon request. [Rules 69.4 and 69.4.1]
14. Access, facilities, utilities and any necessary safety equipment for source testing and inspection shall be provided upon request of the Air Pollution Control District. [Rule 19]

B. DISTRICT-ONLY ENFORCEABLE CONDITIONS

1. This permit authorizes operation only at the stationary source(s) listed on this permit to operate. This engine shall be operated as a portable unit as defined by the Airborne Toxic Control Measure for Diesel Particulate Matter from Portable Engines Rated at 50 Horsepower and Greater. This permit does not preclude off-site operations under a valid registration issued by the California Air Resources Board (CARB) under the Portable Equipment Registration Program (PERP). (17CCR93116).
2. This engine shall be certified to meet the Federal or California tiered emission standard for non-road engines as shown in the equipment description above. (17 CCR 93116)
11. This engine, as part of the fleet that it is included in, shall comply with the fleet averaging standards of 17CCR 93116. A copy of the most recent compliance statement submitted to the California Air Resources Board under 17CCR 93116 shall be provided to District personnel upon request. (17CCR 93116)
12. The responsible official shall submit compliance statements as required by 17CCR 93116. These compliance statements are due to the California Air Resources Board by March 1, 2013, March 1, 2017 and March 1, 2020.
15. This Air Pollution Control District Permit does not relieve the holder from obtaining permits or authorizations required by other governmental agencies.
16. The permittee shall, upon determination of applicability and written notification by the District, comply with all applicable requirements of the Air Toxics "Hot Spots" Information and Assessment Act (California Health and Safety Code Section 44300 et seq.)



Sectors: 3, I
Site ID: APCD1996-SITE-02083
App ID: APCD2014-APP-003811

PERMIT ID
APCD2016-PTO-002649


SD City of Metro Wastewater Dept
Salvador Coria
2392 Kincaid Rd
San Diego CA, 92101

EQUIPMENT ADDRESS
City of San Diego-Metropolitan
Salvador Coria
1902 Gatchell Road
San Diego CA 92106

PERMIT TO OPERATE

This permit is not valid until required fees are received by the District.

The above is hereby granted a Permit To Operate the article, machine, equipment or contrivance described below. This permit is not transferable to a new owner nor is it valid for operation of the equipment at another location except as specified. This Permit To Operate or copy must be posted on or within 25 feet of the equipment, or readily available on the operating premises.

EQUIPMENT OWNER

City of San Diego - Metropolitan Wastewater Dept Owner Manager 2392 Kincaid Rd, San Diego, CA 92101

EQUIPMENT DESCRIPTION

Prime Diesel Engine (Low-Use, ATCM Portable): Isuzu, Model AP-4JJ1T, 69.7 BHP, S/N 4JJ1-183573, Model Year 2014, Tier 4 Certified, Engine Family No. ESZXL03.0PTA, driving a dewatering pump.

Every person who owns or operates this equipment is required to comply with the conditions listed below and all applicable requirements and District rules, including but not limited to Rules 10, 20, 40, 50, 51.

Fee Schedules: 1 [34G] Engine for Non-Emergency and Non-Cogeneration Operation
BEC: APCD2016-CON-001232

FAILURE TO OPERATE IN COMPLIANCE IS A MISDEMEANOR SUBJECT TO CIVIL AND CRIMINAL PENALTIES

A. FEDERALLY-ENFORCEABLE AND DISTRICT-ENFORCEABLE CONDITIONS

3. Each engine shall have an original manufacturer label containing the following information: make, model, family number and serial number. [Rules 69.4, 69.4.1]
5. This engine shall use only carb diesel fuel. (Rule 69.4.1, 17 CCR 93116)
6. Visible emissions including crank case smoke shall comply with Air Pollution Control District Rule 50. (Rule 50)
8. A non-resettable engine hour meter shall be installed on this engine, maintained in good working order, and used for recording engine operation hours. If a meter is replaced when the emission unit is operating on site, the Air Pollution Control District's Compliance Division shall be notified in writing within 10 calendar days. The written notification shall include the following information:
 - (a) old meter's hour reading
 - (b) replacement meter's manufacturer name, model and serial number if available and current hour reading on replacement meter
 - (c) copy of receipt of new meter or of installation work order. A copy of the meter replacement notification shall be maintained onsite and made available to the Air Pollution Control District upon request. (Rule 69.4.1)(17CCR 93116)



COUNTY OF SAN DIEGO, AIR POLLUTION CONTROL DISTRICT
10124 OLD GROVE ROAD, SAN DIEGO, CA 92131
PHONE (858) 586-2600 FAX (858) 586-2601
www.sdapcd.org

Sectors: 3, I
Site ID: APCD1996-SITE-02083
App ID: APCD2014-APP-003811

PERMIT ID
APCD2016-PTO-002649



9. The owner or operator of this engine shall conduct periodic maintenance of the engine and add-on control equipment, if any, as recommended by the engine and control equipment manufacturers or as specified by the engine servicing company's maintenance procedures. The periodic maintenance shall be conducted at least once each calendar year. (Rule 12, Rule 69.4.1)
10. The owner or operator shall maintain documentation identifying all fuel used in this engine as CARB diesel or an alternative fuel meeting the requirements of 17 CCR 93116.3(a) and with a sulfur content not to exceed 15 ppm sulfur by weight. These records shall be kept on site for at least the same period of time as the engine to which the records apply is located at the site. [Rule 69.4 and/or 69.4.1, 17 CCR 93116]
11. The owner or operator of the engine shall maintain a manual of recommended maintenance provided by the manufacturer, or maintenance procedures specified by the engine servicing company on site for at least the same period of time as the engine to which the records apply is located at the site. [Rule 69.4.1]
13. The owner or operator shall maintain an operating log containing, at a minimum, the following:
 - records of periodic engine inspections
 - the dates the inspection was performed
 - records of engine maintenance
 - the dates maintenance was performed
 - the nature of the maintenance[Rules 69.4, 69.4.1]
15. Unless otherwise specified in this permit, records required by this written permit shall be maintained on site for a minimum of five years and made available to the District upon request. (Rule 1421)
16. Access, facilities, utilities and any necessary safety equipment for source testing and inspection shall be provided upon request of the Air Pollution Control District. [Rule 19]

B. DISTRICT-ONLY ENFORCEABLE CONDITIONS

1. This permit authorizes operation only at the stationary sources listed below. This engine shall be operated as a portable unit as defined by the Airborne Toxic Control Measure for Diesel Particulate Matter from Portable Engines Rated at 50 Horsepower and Greater. This permit does not preclude off-site operations under a valid registration issued by the California Air Resources Board (CARB) under the Portable Equipment Registration Program (PERP). (17CCR93116).
 - Point Loma Wastewater Treatment Plant (APCD1976-SITE-02083)
 - Pump Station 1 (APCD2012-SITE-00979)
 - Pump Station 2 (APCD1990-SITE-07804)
 - Pump Station 64 (APCD1993-SITE-08801)
 - Pump Station 65 (APCD2012-SITE-08505)
 - Grove Avenue Pump Station (APCD1998-SITE-10415)
 - Otay River Pump Station (APCD199-SITE-10755)
 - East Mission Gorge Pump Station (APCD1991-SITE-08104)
 - Penasquitos Pump Station (APCD1994-SITE-09038)
 - North City Water Reclamation Plant (APCD1991-SITE-08439)
 - South Bay Water Reclamation Plant (APCD1996-SITE-09652)
 - Metro Biosolids Center (APCD1994-SITE-07517)
2. This engine shall be certified to meet the Federal or California tiered emission standard for non-road engines as shown in the equipment description above. (17 CCR 93116)
4. If designated as an Emergency Engine in the above equipment description, the engine shall be operated exclusively in emergency applications except for up to 50 hours per year for maintenance and testing. If designated as a Low-Use Engine in the above equipment description, the engine shall be operated 80 hours or less each calendar year. (17CCR 93116)
7. This equipment shall not be operated within 1000 feet of any K-12 school unless California Health and Safety Code Section 42301.6 is met.



COUNTY OF SAN DIEGO, AIR POLLUTION CONTROL DISTRICT
10124 OLD GROVE ROAD, SAN DIEGO, CA 92131
PHONE (858) 586-2600 FAX (858) 586-2601
www.sdapcd.org

Sectors: 3, I
Site ID: APCD1996-SITE-02083
App ID: APCD2014-APP-003811

PERMIT ID
APCD2016-PTO-002649


12. The responsible official shall submit compliance statements as required by 17CCR 93116. These compliance statements are due to the California Air Resources Board by March 1, 2013, March 1, 2017 and March 1, 2020.
14. Records of annual engine use shall be maintained at a central place of business for five years. These records shall clearly identify each portable engine subject to the recordkeeping requirement as well as the annual hours of operation. These records are to be made available, upon request for inspection, to local air pollution control district or CARB personnel. These records shall be provided to the appropriate personnel within ten business days of request. (17 CCR 93116)
17. This Air Pollution Control District Permit does not relieve the holder from obtaining permits or authorizations required by other governmental agencies.
18. The permittee shall, upon determination of applicability and written notification by the District, comply with all applicable requirements of the Air Toxics "Hot Spots" Information and Assessment Act (California Health and Safety Code Section 44300 et seq.)



Sectors: 3, I
Site ID: APCD1996-SITE-02083
App ID: APCD2014-APP-003812

PERMIT ID
APCD2016-PTO-002650

SD City of Metro Wastewater Dept
Salvador Coria
2392 Kincaid Rd
San Diego CA, 92101

EQUIPMENT ADDRESS
City of San Diego-Metropolitan
Salvador Coria
1902 Gatchell Road
San Diego CA 92106

PERMIT TO OPERATE

This permit is not valid until required fees are received by the District.

The above is hereby granted a Permit To Operate the article, machine, equipment or contrivance described below. This permit is not transferable to a new owner nor is it valid for operation of the equipment at another location except as specified. This Permit To Operate or copy must be posted on or within 25 feet of the equipment, or readily available on the operating premises.

EQUIPMENT OWNER

City of San Diego - Metropolitan Wastewater Dept Owner Manager 2392 Kincaid Rd, San Diego, CA 92101

EQUIPMENT DESCRIPTION

Prime Diesel Engine (Low-Use, ATCM Portable): Isuzu, Model AP-4JJ1T, 69.7 BHP, S/N 4JJ1-183576, Model Year 2014, Tier 4 Certified, Engine Family No. ESZXL03.0PTA, driving a dewatering pump.

Every person who owns or operates this equipment is required to comply with the conditions listed below and all applicable requirements and District rules, including but not limited to Rules 10, 20, 40, 50, 51.

Fee Schedules: 1 [34G] Engine for Non-Emergency and Non-Cogeneration Operation
BEC: APCD2016-CON-001232

FAILURE TO OPERATE IN COMPLIANCE IS A MISDEMEANOR SUBJECT TO CIVIL AND CRIMINAL PENALTIES

A. FEDERALLY-ENFORCEABLE AND DISTRICT-ENFORCEABLE CONDITIONS

3. Each engine shall have an original manufacturer label containing the following information: make, model, family number and serial number. [Rules 69.4, 69.4.1]
5. This engine shall use only carb diesel fuel. (Rule 69.4.1, 17 CCR 93116)
6. Visible emissions including crank case smoke shall comply with Air Pollution Control District Rule 50. (Rule 50)
8. A non-resettable engine hour meter shall be installed on this engine, maintained in good working order, and used for recording engine operation hours. If a meter is replaced when the emission unit is operating on site, the Air Pollution Control District's Compliance Division shall be notified in writing within 10 calendar days. The written notification shall include the following information:
 - (a) old meter's hour reading
 - (b) replacement meter's manufacturer name, model and serial number if available and current hour reading on replacement meter
 - (c) copy of receipt of new meter or of installation work order. A copy of the meter replacement notification shall be maintained onsite and made available to the Air Pollution Control District upon request.
[Rule 69.4.1; 17CCR 93116]



COUNTY OF SAN DIEGO, AIR POLLUTION CONTROL DISTRICT
10124 OLD GROVE ROAD, SAN DIEGO, CA 92131
PHONE (858) 586-2600 FAX (858) 586-2601
www.sdapcd.org

Sectors: 3, I
Site ID: APCD1996-SITE-02083
App ID: APCD2014-APP-003812

PERMIT ID
APCD2016-PTO-002650



9. The owner or operator of this engine shall conduct periodic maintenance of the engine and add-on control equipment, if any, as recommended by the engine and control equipment manufacturers or as specified by the engine servicing company's maintenance procedures. The periodic maintenance shall be conducted at least once each calendar year. [Rule 12, Rule 69.4.1]
10. The owner or operator shall maintain documentation identifying all fuel used in this engine as CARB diesel or an alternative fuel meeting the requirements of 17 CCR 93116.3(a) and with a sulfur content not to exceed 15 ppm sulfur by weight. These records shall be kept on site for at least the same period of time as the engine to which the records apply is located at the site. [Rule 69.4 and/or 69.4.1, 17 CCR 93116]
11. The owner or operator of the engine shall maintain a manual of recommended maintenance provided by the manufacturer, or maintenance procedures specified by the engine servicing company on site for at least the same period of time as the engine to which the records apply is located at the site. [Rule 69.4.1]
13. The owner or operator shall maintain an operating log containing, at a minimum, the following:
 - records of periodic engine inspections
 - the dates the inspection was performed
 - records of engine maintenance
 - the dates maintenance was performed
 - the nature of the maintenance[Rules 69.4, 69.4.1]
15. Unless otherwise specified in this permit, records required by this written permit shall be maintained on site for a minimum of five years and made available to the District upon request. [Rule 1421]
16. Access, facilities, utilities and any necessary safety equipment for source testing and inspection shall be provided upon request of the Air Pollution Control District. [Rule 19]

B. DISTRICT-ONLY ENFORCEABLE CONDITIONS

1. This permit authorizes operation only at the stationary sources listed below. This engine shall be operated as a portable unit as defined by the Airborne Toxic Control Measure for Diesel Particulate Matter from Portable Engines Rated at 50 Horsepower and Greater. This permit does not preclude off-site operations under a valid registration issued by the California Air Resources Board (CARB) under the Portable Equipment Registration Program (PERP). (17CCR93116).
 - Point Loma Wastewater Treatment Plant (APCD1976-SITE-02083)
 - Pump Station 1 (APCD2012-SITE-00979)
 - Pump Station 2 (APCD1990-SITE-07804)
 - Pump Station 64 (APCD1993-SITE-08801)
 - Pump Station 65 (APCD2012-SITE-08505)
 - Grove Avenue Pump Station (APCD1998-SITE-10415)
 - Otay River Pump Station (APCD199-SITE-10755)
 - East Mission Gorge Pump Station (APCD1991-SITE-08104)
 - Penasquitos Pump Station (APCD1994-SITE-09038)
 - North City Water Reclamation Plant (APCD1991-SITE-08439)
 - South Bay Water Reclamation Plant (APCD1996-SITE-09652)
 - Metro Biosolids Center (APCD1994-SITE-07517)
2. This engine shall be certified to meet the Federal or California tiered emission standard for non-road engines as shown in the equipment description above. (17 CCR 93116)
4. If designated as an Emergency Engine in the above equipment description, the engine shall be operated exclusively in emergency applications except for up to 50 hours per year for maintenance and testing. If designated as a Low-Use Engine in the above equipment description, the engine shall be operated 80 hours or less each calendar year. (17CCR 93116)
7. This equipment shall not be operated within 1000 feet of any K-12 school unless California Health and Safety Code Section 42301.6 is met.



COUNTY OF SAN DIEGO, AIR POLLUTION CONTROL DISTRICT
10124 OLD GROVE ROAD, SAN DIEGO, CA 92131
PHONE (858) 586-2600 FAX (858) 586-2601
www.sdapcd.org

Sectors: 3, I
Site ID: APCD1996-SITE-02083
App ID: APCD2014-APP-003812

PERMIT ID
APCD2016-PTO-002650


12. The responsible official shall submit compliance statements as required by 17CCR 93116. These compliance statements are due to the California Air Resources Board by March 1, 2013, March 1, 2017 and March 1, 2020.
14. Records of annual engine use shall be maintained at a central place of business for five years. These records shall clearly identify each portable engine subject to the recordkeeping requirement as well as the annual hours of operation. These records are to be made available, upon request for inspection, to local air pollution control district or CARB personnel. These records shall be provided to the appropriate personnel within ten business days of request. (17 CCR 93116)
17. This Air Pollution Control District Permit does not relieve the holder from obtaining permits or authorizations required by other governmental agencies.
18. The permittee shall, upon determination of applicability and written notification by the District, comply with all applicable requirements of the Air Toxics "Hot Spots" Information and Assessment Act (California Health and Safety Code Section 44300 et seq.)

APPENDIX B: RULE REFERENCE TABLE

Rule Citation ¹	RULE TITLE	A/R ²	District Adoption Date ³	SIP FR Approval Date
	REGULATION I - GENERAL PROVISIONS			
1	Title	F	04/30/80	09/28/81
2	Definitions	F	11/04/09	09/17/10
4	Review of Rules	F	01/01/70 [†]	09/22/72
5	Authority to Arrest	F	03/24/76 [†]	05/11/77
	REGULATION II - PERMITS			
10	Permits Required	F	07/25/95	03/11/98
10.1 ^{††}	NSPS & NESHAPS Requirements	D	11/8/76	N/A
11	Exemptions from Rule 10 Permit Requirements	D/F	09/20/78	07/06/82
12	Registration of Specified Equipment	D	11/15/00	N/A
12.1	Portable Equipment Registration	D	05/21/97	N/A
14	Applications	F	04/30/80	09/28/81
15	Permit Process - Public Notifications	D/F	09/18/90	Pending
17	Cancellation of Applications	F	04/06/93	03/11/98
18	Action on Applications	F	01/17/72	09/22/72
18	Action on Applications	D/F	09/18/90	Pending
19	Provision of Sampling and Testing Facilities	F	04/06/93	03/11/98
19.1 ^{††}	NSPS & NESHAPS Provision of Sampling and Testing Facilities Requirements	D	11/08/76	N/A
19.2	Continuous Emission Monitoring Requirements	F	01/12/79	09/28/81
19.3	Emission Information	F	5/15/96	03/09/00
20	Standards for Granting Permits	D/F	04/25/89	Pending
20.1	Definitions, Emission Calculations, Emission Offsets and Banking, Exemptions, and Other Requirements	F	07/05/79	04/14/81
20.1	NSR - General Provisions	D/F	12/17/98	Pending
20.2	Standards for Authority to Construct - Best Available Air Pollution Control Technology	F	07/05/79	04/14/81
20.2	NSR - Non-major Stationary Sources	D/F	12/17/98	Pending
20.3	Standards for Authority to Construct - Air Quality Analysis	F	07/05/09	04/14/81
20.3	NSR - Major Stationary Source and PSD Stationary Source	D/F	12/17/98	Pending
20.4	Standards for Authority to Construct - Major Stationary Sources	F	07/05/09	04/14/81
20.4	NSR - Portable Emission Units	D/F	12/17/98	Pending
20.5	Power Plants	F	07/05/79	04/14/81
20.6	Standards for Permit to Operate - Air Quality Analysis	F	07/05/79	04/14/81
20.6	Standards for Permit to Operate Air Quality Analysis	D/F	12/14/87	Pending
20.8	Special Offset Requirement Relating to Banking	D	2/16/83	N/A
21	Permit Conditions	F	11/29/94	03/11/98
22	Denial of Applications	D/F	01/01/69 [†]	N/A

23	Further Information	D/F	01/01/69 [†]	N/A
24	Temporary Permit to Operate	F	03/20/96	10/24/08
25	Appeals	F	01/01/69 [†]	09/22/72
25	Appeals	D/F	06/21/00	Pending
26.0	Banking of Emission Reduction Credits (ERCs) - General Requirements	D/F	10/22/97	Pending
26.1	Standards for Granting Emission Reduction Credits (ERCs)	D/F	10/22/97	Pending
26.2	Use of Emission Reduction Credits (ERCs)	D/F	10/22/97	Pending
26.3	Reclassification of Class B Emission Reduction Credits (ERCs)	D/F	10/22/97	Pending
26.4	Permanency of Banked Emission Reduction Credits (ERCs)	D/F	10/22/97	Pending
26.5	Transfer of Emission Reduction Credits (ERCs)	D/F	10/22/97	Pending
26.6	District Banking of Emission Reduction Credits (ERCs)	D/F	10/22/97	Pending
26.7	Shutdown and Related Emission Unit	D/F	10/22/97	Pending
26.8	Banking of Limited Emission Reductions	D/F	10/22/97	Pending
26.9	Emission Reduction Credit Certificates and The Emission Reduction Credit Register	D/F	10/22/97	Pending
26.10	Banking For BRAC Military Base Closure or Realignment Actions	D/F	10/22/97	Pending
27	Banking of Mobile Source Emission Reduction Credits	D/F	11/29/94	Pending
27.1	Federal Requirements for San Diego County APCD Alternative Mobile Source Emission Reduction Program Approved On 9/8/2000	F	08/06/08	06/03/09
	REGULATIONS III - FEES			
40	Permit Fees	D	01/01/12	N/A
42	Hearing Board Fees	D	07/01/00	N/A
44	Technical Reports, Charges for	D	12/7/83	N/A
	REGULATIONS IV - PROHIBITIONS			
50	Visible Emissions	F	08/13/97	12/7/98
50.1 ^{††}	NSPS & NESHAPS Visible Emissions Requirements	D	11/08/76	N/A
51	Nuisance	F	01/01/69 [†]	09/22/72
52	Particulate Matter	F	01/22/97	12/9/98
52.1 ^{††}	NSPS & NESHAPS Particular Matter Requirements	D	11/08/76	N/A
53	Specific Contaminants	F	01/22/97	12/9/98
53.1	Scavenger Plants	F	01/01/69 [†]	09/22/72
53.2 ^{††}	NSPS & NESHAPS Specific Contaminants Requirements	D	11/08/76	N/A
54	Dusts and Fumes	F	01/22/97	12/9/98
54.1	NSPS & NESHAP Dust and Fumes Requirement	D	11/08/76	N/A
58	Incinerator Burning	F	01/17/73 [†]	05/11/77
59	Control of Waste Disposal - Site Emissions	D	11/03/87	N/A
59.1	Municipal Solid Waste Landfills	D	06/17/98	N/A
60	Circumvention	F	05/17/94	03/09/00
60.2	Limiting Potential to Emit - Synthetic Minor Sources	D	04/04/12	N/A
61.0	Definitions Pertaining to the Storage & Handling of Organic Compounds	F	10/16/90	09/13/93

61.1	Receiving & Storing Volatile Organic Compounds at Bulk Plants & Bulk Terminals	F	01/10/95	08/08/95
61.2	Transfer of Volatile Organic Compounds into Mobile Transport Tanks	F	07/26/00	08/26/03
61.3	Transfer of Volatile Organic Compounds into Stationary Storage Tanks	F	10/16/90	06/30/93
61.3.1	Transfer of Gasoline into Stationary Underground Storage Tanks	D	03/01/06	Pending
61.4	Transfer of Volatile Organic Compounds into Vehicle Fuel Tanks	F	10/16/90	05/13/93
61.4	Transfer of Volatile Organic Compounds into Vehicle Fuel Tanks	D/F	03/26/08	Pending
61.4.1	Transfer of Gasoline from Stationary Underground Storage Tanks into Vehicles Fuel Tanks	D	03/01/06	N/A
61.5	Visible Emission Standards for Vapor Control Systems	F	09/20/78 [†]	04/14/81
61.6	NSPS Requirements for Storage of Volatile Organic Compounds	D	01/13/87	Withdrawn
61.7	Spillage and Leakage of Volatile Organic Compounds	F	01/13/87	03/11/98
61.8	Certification Requirements for Vapor Control Equipment	F	01/13/87	03/11/98
62	Sulfur Content of Fuels	F	10/21/81	07/06/82
62.1 ^{††}	NSPS Requirements for Sulfur Content of Fuels	D	11/08/76	N/A
64	Reduction of Animal Matter	F	08/21/81	07/06/82
66	Organic Solvents	F	07/25/95	Repealed
66.1	Miscellaneous Surface Coating Operations and Other Processes Emitting VOCs	D/F	2/24/10	08/09/12
67.0	Architectural Coatings	F	12/12/01	Withdrawn
67.0.1	Architectural Coatings	D/F	06/24/15	Pending
67.1	Alternative Emission Control Plans	F	05/15/96	03/27/97
67.2	Dry Cleaning Equipment Using Petroleum - Based Solvent	F	05/15/96	03/27/97
67.3	Metal Parts and Products Coating Operations	F	04/09/03	11/14/03
67.4	Metal Container, Metal Closure and Metal Coil Coating Operations	F	11/09/11	09/20/12
67.5	Paper, Film and Fabric Coating Operations	F	05/15/96	03/27/97
67.6.1	Cold Solvent Cleaning and Stripping Operations	F	5/23/07	10/13/09
67.6.2	Vapor Degreasing Operations	F	5/23/07	10/13/09
67.7	Cutback and Emulsified Asphalts	F	05/15/96	03/27/97
67.9	Aerospace Coating Operations	F	04/30/97	08/17/98
67.10	Kelp Processing and Bio-Polymer Manufacturing	F	06/25/97	06/22/98
67.11	Wood Parts and Products Coating Operations	F	06/27/12	04/11/13
67.11.1	Large Coating Operations for Wood Products	F	09/25/02	06/05/03
67.12	Polyester Resin Operations	F	05/15/96	03/27/97
67.15	Pharmaceutical and Cosmetic Manufacturing Operations	F	05/15/96	03/27/97
67.16	Graphic Arts Operations	F	05/09/12	09/20/12
67.17	Storage of Materials Containing Volatile Organic Compounds	F	05/15/96	03/27/97
67.18	Marine Coating Operations	F	05/15/96	03/27/97
67.19	Coating and Printing Inks Manufacturing Operations	F	05/15/96	05/26/00
67.20.1	Motor Vehicle and Mobile Equipment Coating Operations	D	06/30/10	N/A

67.21	Adhesive Material Application Operations	D	11/14/08	N/A
67.22	Expandable Polystyrene Foam Products Manufacturing Operations	D	05/15/96	N/A
67.24	Bakery Ovens	F	05/15/96	03/27/97
68	Fuel-Burning Equipment – Oxides of Nitrogen	F	09/20/94	04/09/96
68.1††	NSPS Requirements for Oxides of Nitrogen from Fuel-Burning Equipment	D	11/08/76	N/A
69	Electrical Generating Steam Boilers, Replacement Units & New Units	D	12/12/95	N/A
69.2	Industrial & Commercial Boilers, Process Heaters & Steam Generators	F	09/27/94	02/09/96
69.2.1	Small Boilers, Process Heaters and Steam Generators	D	03/25/09	N/A
69.3	Stationary Gas Turbine Engines	F	09/27/94	06/17/97
69.3	Stationary Gas Turbine Engines – RACT	D/F	12/16/98	Pending
69.3.1	Stationary Gas Turbine Engines – BARCT	D	02/24/10	N/A
69.4	Stationary Internal Combustion Engines	F	07/30/03	01/04/06
69.4	Stationary Internal Combustion Engines – RACT	D/F	07/30/03	2/25/04
69.4.1	Stationary Internal Combustion Engines - BARCT	D	11/15/00	N/A
69.5	Natural Gas-Fired Water Heaters	D	01/01/99	N/A
69.5.1	Natural Gas-Fired Water Heaters	D	06/24/15	N/A
69.6	Natural Gas-Fired Fan-Type Central Furnaces	D	06/17/98	N/A
70	Orchard Heaters	F	01/17/72	09/22/72
71	Abrasive Blasting	F	03/30/77	08/31/78
	REGULATION V - PROCEDURES BEFORE THE HEARING BOARD			
75	Procedure Before the Hearing Board	D/F	09/17/85	Pending
75.1††	NSPS & NESHAPS Variance Procedures	D	09/17/85	7/30/79
97	Emergency Variance	D/F	07/25/95	Pending
98	Breakdown Conditions: Emergency Variance	D	07/25/95	Withdrawn
	REGULATION VI - BURNING CONTROL			
101	Burning Control	F	09/25/02	04/30/03
	REGULATION VII - VALIDITY AND EFFECTIVE DATE			
140	Validity	F	01/01/69†	09/22/72
141	Effective Date	F	01/01/69†	09/22/72
	REGULATION VIII - SAN DIEGO AIR POLLUTION EMERGENCY PLAN			
126	Applicability	F	05/25/77	08/31/78
127	Episode Criteria Levels	F	09/17/91	03/18/99
128	Episode Declaration	F	09/17/91	03/18/99
129	Episode Termination	F	05/25/77	08/31/78
130	Episode Actions	F	09/17/91	03/18/99
131	Stationary Source Curtailment Plan	F	04/01/81	06/21/82
132	Traffic Abatement Plan	F	04/01/81	06/21/82

132	Traffic Abatement Plan	D/F	12/17/97	Pending
133	Schools	F	05/25/77	08/31/78
134	Source Inspection	F	04/01/81	06/21/82
135	Air Monitoring Stations	F	05/25/77	08/31/78
136	Interdistrict and Interbasin Coordination	F	05/25/77	08/31/78
137	Emergency Action Committee	F	05/25/77	08/31/78
138	Procedures and Plans	F	05/25/77	08/31/78
	APPENDIX A - Persons to be Notified on Episode Declaration	F		
REGULATION IX - PUBLIC RECORDS				
175	General	F	05/22/74†	05/11/77
176	Information Supplied to District	F	05/22/74†	05/11/77
177	Inspection of Public Records	F	03/30/77	08/31/78
177	Inspection of Public Records	D/F	06/20/01	Pending
REGULATION XII - TOXIC AIR CONTAMINANTS				
1200	Toxic Air Contaminants - New Source Review	D	06/12/96	N/A
1202	Hexavalent Chromium - Cooling Towers	D	07/25/95	N/A
1203	Ethylene Oxide Sterilizers and Aerators	D	07/26/00	N/A
1205	Control of Dioxins Emissions from Medical Waste Incinerators	D	01/01/94	N/A
1210	Toxic Air Contaminant Public Health Risks - Public Notification and Risk Reduction	D	06/12/96	N/A

1.

REGULATION XIV - TITLE V OPERATING PERMITS				
1401	General Provisions	F	02/27/04	02/27/04
1410	Permit Required	F	02/27/04	02/27/04
1411	Exemption from Permit to Operate for Insignificant Units	F	03/07/95	11/30/01
1412	Federal Acid Rain Program Requirements	F	01/18/94	11/30/01
1413	Early Reduction of Hazardous Air Pollutants	F	03/07/95	11/30/01
1414	Applications	F	03/07/95	11/30/01
1415	Permit Process-Public Notification	F	02/27/04	02/27/04
1417	Pendency & Cancellation of Applications	F	03/07/95	11/30/01
1418	Action on Applications	F	02/27/04	11/30/01
1419	Provisions of Sampling & Testing Facilities & Emission Information	F	03/07/95	11/30/01
1420	Standards for Granting Permits	F	03/07/95	11/30/01
1421	Permit Conditions	F	02/27/04	02/27/04
1422	Denial or Cancellation Of Applications	F	03/07/95	11/30/01
1423	Further Information	F	01/18/94	11/30/01
1424	Applications Deemed Denied	F	01/18/94	11/30/01
1425	Appeals & Judicial Review	F	02/27/04	02/27/04
	APPENDIX A - Insignificant Units	F	02/27/04	11/30/01
	REGULATION XV - FEDERAL CONFORMITY			
1501	Conformity of General Federal Actions	F	06/22/99	04/23/99

The following NSPS and NESHAP have been adopted locally by the District. EPA has granted the District delegation for each of these rules. Therefore, these rules, as adopted by the District are the federally applicable requirements. For all other NSPS and NESHAP, the versions cited in the CFR are the federally applicable requirements.

Subpart & Citation	RULE TITLE	District Adoption Date	Federal Delegation Date
Part 60 REGULATION X - STANDARDS OF PERFORMANCE FOR NEW STATIONARY SOURCES			
A	General Provisions	Unknown 11/03/92	11/08/76
E	Standards of Performance for Incinerators	Unknown	03/30/77
I	Standards of Performance for Asphalt Concrete Plants	Unknown 01/13/87	11/08/76
L	Standards of Performance for Secondary Lead Smelters	Unknown	11/08/76
M	Standards of Performance for Secondary Brass and Bronze Ingot Production Plants	Unknown 09/17/85*	03/30/77
O	Standards of Performance for Sewage Treatment Plants	01/13/87	09/17/87
DD	Standards of Performance for Grain Elevators	Unknown	05/24/82
EE	Standards of Performance for Surface Coating Metal Furniture	03/04/86 11/03/92	03/19/87
QQ	Standards of Performance for the Graphic Arts Industry: Publication Rotogravure Printing	08/24/83	12/22/83
RR	Standards of Performance for Pressure Sensitive Tape and Label Surface Coating Operations	09/17/86 11/03/92	03/19/87
SS	Standards of Performance for the Industrial Surface Coating Large Appliances	02/22/84 11/03/92*	04/24/84
TT	Standards of Performance for Metal Coil Surface Coating	02/22/84 11/03/92*	04/24/84
BBB	Standards of Performance for the Rubber Tire Manufacturing Industry	03/14/89	07/18/89
FFF	Standards of Performance for Flexible Vinyl and Urethane Coating and Printing	09/17/86	03/19/87
JJJ	Standards of Performance for Petroleum Dry Cleaners	12/15/87	07/18/89
Part 61 REGULATION XI- NATIONAL EMISSION STANDARDS FOR HAZARDOUS AIR POLLUTANTS (NESHAPS)			
A	General Provisions	01/13/87	05/24/82
C	National Emission Standard for Beryllium	Unknown	11/08/76
D	National Emission Standard for Beryllium Rocket Motor Firing	Unknown	11/08/76
E	National Emission Standard for Mercury	03/27/90	05/17/91
F	National Emission Standard for Vinyl Chloride	08/17/77 06/16/78	11/21/77
M	National Emission Standard for Asbestos	06/04/85 02/01/95	07/18/89

The following ATCM and NESHAP have not been adopted by the District, but are being implemented and enforced by the District as ATCM's.

Subpart & Citation	RULE TITLE	A/R	Most Recent Adoption Date
DISTRICT RULES AND REGULATIONS APPENDIX A - CALIFORNIA AIRBORNE TOXIC CONTROL MEASURES (ATCM)			
17 CCR § 93102	Hexavalent Chromium ATCM for Chrome Plating & Chromic Acid Anodizing Operations	D/F	12/7/06
17 CCR § 93109	ATCM For Emissions of Perchloroethylene From Dry Cleaning Operations	F	01/25/07
17 CCR § 93101.5	ATCM to Reduce Emissions of Hexavalent Chromium and Nickel from Thermal Spraying	D	09/30/05
17 CCR § 93105	ATCM for Construction, Grading, Quarrying, and Surface Mining Operations	D	07/26/01
17 CCR § 93106	Asbestos ATCM for Surface Applications	D	07/20/00
17 CCR § 93107	ATCM For Emissions of Toxic Metals From Non-Ferrous Metal Melting	D	01/14/93
17 CCR § 93111	ATCM for Emissions of Chlorinated Toxic Air Contaminants from Automotive Maintenance & Repair Activities	D	04/27/00
17 CCR § 93112	ATCM for Emissions of Hexavalent Chromium and Cadmium from Motor Vehicle and Motor Equipment Coatings	D	09/20/01
17 CCR § 93113	ATCM to Reduce Emissions of Toxic Air Contaminants from Outdoor Residential Waste Burning	D	02/03/03
17 CCR § 93115	ATCM for Stationary Compression Ignition Engines	D	05/19/11
17 CCR § 93116	ATCM for Portable Diesel-Fueled Engines	D	02/19/11
DISTRICT RULES AND REGULATIONS APPENDIX B - NATIONAL EMISSION STANDARDS FOR HAZARDOUS AIR POLLUTANTS (NESHAP) FOR SOURCE CATEGORIES			
Part 63			
A	General Provisions	F	05/16/07
N	Hard and Decorative Chromium Electroplating and Chromium Anodizing Tanks	F	04/20/06
O	Ethylene Oxide Sterilization Facilities	F	12/28/07
R	Gasoline Distribution	F	01/24/11
T	Halogenated Solvent Cleaning	F	09/08/00
DD	Off-site Waste & Recovery Operations	F	07/20/99
GG	Aerospace Manufacturing and Rework Facilities	F	12/08/00
II	Shipbuilding and Ship Repair (Surface Coating)	F	12/15/95
JJ	Wood Furniture Manufacturing Operations	F	12/28/98
VVV	Publicly Owned Treatment Works	F	10/21/02
AAAA	Municipal Solid Waste Landfills	F	01/16/03
EEEE	Organic Liquids Distribution (non-gasoline)	F	07/17/08
MMMM	Surface Coating of Miscellaneous Metal Parts and Products	F	04/26/04
PPPP	Plastic Parts (surface coating)	F	04/24/07
SSSS	Surface Coating of Metal Coil	F	03/17/03
VVVV	Boat Manufacturing	F	08/22/01
WWWW	Reinforced Plastic Composites Production	F	8/25/05

YYYY	Stationary Combustion Turbines	F	08/18/04
ZZZZ	Stationary Reciprocating Internal Combustion Engines	F	03/09/11
DDDDD	Industrial, Commercial, and Institutional Boilers and Process Heaters	F	05/18/11
GGGGG	Site Remediation	F	11/29/06
HHHHH	Miscellaneous Coating Manufacturing	F	10/04/06
PPPPP	Engine Test Cells/Stand	F	08/28/03
WWWWW	Hospital Ethylene Oxide Sterilizers Area Sources	F	12/28/07
BBBBBB	Gasoline Distribution Bulk Terminals, Bulk Plants, and Pipeline Facilities	F	01/24/11
CCCCCC	Gasoline Dispensing Facilities	F	01/24/11
HHHHHH	Paint Stripping and Miscellaneous Surface Coating Operations at Area Sources	F	01/09/08
JJJJJ	Area Sources: Industrial, Commercial, and Institutional Boilers	F	3/21/11
QQQQQ	Wood Preserving Area Sources	F	07/16/07
VVVVV	Chemical Manufacturing Area Sources	F	11/29/09
WWWWW	Plating and Polishing Operations Area Sources	F	07/01/08
XXXXXX	Metal Fabrication and Finishing Area Sources	F	7/23/08
AAAAAAA	Asphalt Processing and Asphalt Roofing Manufacturing Area Sources	F	12/02/09
CCCCCCC	Paint and Allied Products Manufacture Area Sources	F	12/03/09

2.

The following NSPS have been adopted by the District by reference. The rules listed below are the CFR versions of these rules which are federally applicable requirements.

Subpart & Citation	RULE TITLE	Latest EPA Promulgation Date	District Adoption Date	Delegation Date
Part 60	DISTRICT RULES AND REGULATIONS APPENDIX C - STANDARDS OF PERFORMANCE FOR NEW STATIONARY SOURCES (NSPS)			
D	Standards of Performance for Fossil-Fuel-Fired Steam Generators for Which Construction is Commenced After August 17, 1971	10/17/00 01/28/09	10/17/01 06/24/09	01/03/08 Pending
Da	Standards of Performance for Electric Utility Steam Generating Units for Which Construction is Commenced After September 18, 1978	06/11/01 01/28/09	10/17/01 06/24/09	01/03/08 Pending
Db	Standards of Performance for Industrial-Commercial - Institutional Steam Generating Units	10/01/01 01/28/09	04/25/01 06/24/09	01/03/08 Pending
Dc	Standards of Performance for Small Industrial-Commercial -Institutional Steam Generating Units	05/08/96 01/28/09	08/13/97 06/24/09	06/24/98 Pending
GG	Standards of Performance for Stationary Gas Turbines	06/27/89 02/24/06	10/17/01 02/25/09	01/03/08 Pending
K	Standards of Performance for Storage Vessels for Petroleum Liquids Construct After June 11, 1973 and Prior to May 19, 1978	10/17/00	06/20/07	01/03/08
Ka	Standards of Performance for Storage Vessels for Petroleum Liquids Construction after May 18, 1978	12/14/00	06/20/07	01/03/08
Kb	Standards of Performance for Volatile Organic Liquid Storage Vessels (Including Petroleum Liquid Storage Vessels) for Which Construction, Reconstruction, or Modification Commenced after July 23, 1984	10/15/03	06/20/07	01/03/08
AAA	Standards of Performance for New Residential Wood Heaters	06/12/99 10/17/00	04/12/00 N/A	01/03/08 N/A
OOO	Standards of Performance for Nonmetallic Mineral Processing Plants	06/09/97 10/17/00	04/28/99 N/A	05/28/02 N/A
UUU	Standards of Performance for Calciners and Dryers in Mineral Industries	07/29/93 10/17/00	11/17/99 N/A	05/28/02 N/A
VVV	Standards for Polymeric Coating of Supporting Substrates Facilities	09/11/89	05/23/07	01/03/08
WWW	Standards of Performance for Municipal Solid Waste Landfills	04/10/00	08/13/97	06/24/98
AAAA	Standards of Performance for Small Municipal Waste Combustion Units	12/06/00	06/20/07	01/03/08
CCCC	Standards of Performance for Commercial and Industrial Solid Waste Incineration Units	12/01/00	06/20/07	01/03/08
EEEE	Standards of Performance for Other Solid Waste Incineration Units	12/16/05	06/20/07	01/03/08
KKKK	Standards of Performance for Stationary Combustion Turbines	07/06/06	02/25/09	06/01/09

The following NSPS have not been adopted by the District and are not delegated to the District. However, the District has the authority to enforce the NSPS through the Title V program. The rules listed below are the CFR versions of these rules, which are federally applicable requirements.

Subpart & Citation	RULE TITLE	Latest EPA Promulgation Date	District Adoption Date	Delegation Date
Part 60				
III	Standards of Performance for Stationary Compression Ignition Internal Combustion Engines	07/11/06	N/A	N/A
JJJ	Standards of Performance for Stationary Spark Ignition Internal Combustion Engines	01/18/08	N/A	N/A

1. Rule Citations marked with an “††” contain no substantive requirements and are listed for informational purposes only.
2. ‘A/R’ Denotes enforceability of the listed applicable requirement as follows:
 - ‘F’ Denotes a Federal applicable requirement that is federally enforceable and District enforceable.
 - ‘D/F’ Denotes a District applicable requirement which is pending SIP approval. When such a rule receives SIP approval, it supersedes the existing SIP rule and becomes the Federal applicable requirement.
 - ‘D’ Denotes a District only applicable requirement. This may include some state requirements that are enforceable by the District.
3. District adoption dates marked with an “†” are the effective date of the rule, the actual adoption date is uncertain.
4. On September 17, 2010, EPA approved the District’s November, 4, 2009, revision to the table of exempt compounds in Rule 2, which can be administratively amended without Board action to amend the rule.

APPENDIX C: ABBREVIATIONS THAT MAY APPEAR IN THIS PERMIT

APCO	Air Pollution Control Officer
ASTM	American Society for Testing and Methods
BACT	Best Available Control Technology
CAA	federal Clean Air Act
CFR	Code of Federal Regulations
CO	Carbon Monoxide
CO ₂	Carbon Dioxide
District	San Diego County Air Pollution Control District
EF	Emission Factor
EPA	US Environmental Protection Agency
HAP	Hazardous Air Pollutant
I&M	Inspection and Maintenance
NESHAP	National Emission Standard for Hazardous Air Pollutants
NSPS	New Source Performance Standards
NSR	New Source Review
[NSR]	New Source Review based condition
NO _x	Oxides of nitrogen
O ₂	Oxygen
OES	Office of Environmental Services
O&M	Operation and maintenance
Pb	Lead
PM	Total Particulate Matter
PM ₁₀	Particulate matter with aerodynamic equivalent diameter of ≤ 10 microns
PSD	Prevention of Significant Deterioration
RMP	Risk Management Plan
SDCAPCD	San Diego County Air Pollution Control District
SIP	State Implementation Plan
SO _x	Oxides of sulfur
Title IV	Title IV of the federal Clean Air Act
Title V	Title V of the federal Clean Air Act
VOC	Volatile organic compound

Units of Measure:

dscf	=	Dry standard cubic foot
g	=	grams
gal	=	gallon
gr/dscf	=	Grains per dry standard cubic foot
hr	=	hour
lb	=	pound
in	=	inches
max	=	maximum
min	=	minute
MM Btu	=	Million British thermal units
psia	=	pounds per square inch, absolute
scf	=	Standard cubic foot
scfm	=	standard cubic feet per minute
yr	=	year