



THOMAS J. PASTUSZKA,
CMC, CCB
EXECUTIVE OFFICER/CLERK

County of San Diego
AIR POLLUTION CONTROL DISTRICT HEARING BOARD
1600 PACIFIC HIGHWAY, ROOM 402, SAN DIEGO, CALIFORNIA 92101-2471

TELEPHONE (619) 531-5600
FAX (619) 595-4616

STATEMENT OF PROCEEDINGS
SAN DIEGO COUNTY
AIR POLLUTION CONTROL DISTRICT HEARING BOARD
Regular Meeting, Thursday, August 27, 2009

ADMINISTRATIVE ITEM:

A. Approval of Minute Orders for August 13, 2009

ACTION: APPROVED AS AMENDED

Petition No.

4299 MARINE CORPS BASE CAMP PENDLETON: Requests a Regular 1-Year Variance (filed July 20, 2009) from District Rule 10 (b), pertaining to District Application Nos. 988049 and 987700, involving a diesel generator being used for mission critical training located at Camp Pendleton's Kilo-Two MOUT/Iraqi Village training site without a permit.
ACTION: ITEM CONTINUED TO SEPTEMBER 10, 2009 AND ADDITION OF EXHIBIT

4300 AIR POLLUTION CONTROL DISTRICT, COUNTY OF SAN DIEGO: Requests Order for Abatement (filed August 6, 2009) against M.I.T. Engineering & Construction Inc., Pacific Compliance & Engineering Testing, Inc., SWP Engineering & Construction, Inc., and Jesse Willard Kirk, Jr. The requested Order for Abatement is not intended to act as a Variance. The District in this Petition seeks an Order for Abatement requesting Respondents to cease violating permit conditions and Health and Safety Code Section 41954 (f) and District Rules 21, 61.3.1 and 61.4.1.
ACTION: APPROVED

4303 CALPINE-OTAY MESA ENERGY CENTER, LLC: Requests the Interim portion of an Interim / Regular Variance (filed August 13, 2009) from District Rule 69.3 and Rule 69.3.1(NOx concentration) during cold startups, pertaining to District Permit No. 986419, involving two GE 7FA gas turbines with a corresponding steam turbine generator located at 647 Alta Road, San Diego, CA 92154.
The Regular Portion of the Variance will be heard on September 24, 2009
ACTION: GRANTED WITH CONDITIONS AND ADDITION OF EXHIBIT

4304 HAMILTON SUNDSTRAND POWER SYSTEMS: Requests a 90-Day Variance (filed August 13, 2009) from District Rule 21, Condition Nos. 1 and 2, pertaining to Permit No.984955, regarding engine performance evaluation using military grade F76 diesel fuel with a higher sulfur content than allowed in an engine test cell located at 4400 Ruffin Road, San Diego, CA 92123.

ACTION: GRANTED

LAST MATTER OF BUSINESS:

Opportunity for members of the Public to speak to the Board on any subject matter within the Board's jurisdiction but not on an item on today's Agenda.

ACTION: NO SPEAKERS