



County of San Diego

Planning and Development Services
Land Development Division

April 22, 2013

TO: Ashley Gungle, Project Processing
Susan Hoang, Land Development

FROM: Everett Hauser, Active Transportation Planner

TIERRA DEL SOL

PDS2012-3600-12-005

The MUP reflects planned and proposed trails of the [County's Trails Master Plan](#) for Boulevard:

- Tierra Del Sol Trail

The trail should not be placed immediately adjacent to the perimeter fence. There should be a 2-3' buffer from the overhanging barb-wire fence then the 10' graded trail. Typical sections should reflect this condition. See Sheet C-104.

The Fuel Treatment exhibit describes a 15' wide trail easement. The plans should reflect the same conditions (10' with buffer) as shown on the plot plan.

A separate trail exhibit for the entire perimeter trail should be prepared for review. The Trail will be dedicated to the County and precise determination of its alignment will be necessary to complete this recordation.