



County of San Diego

HERMAN REDDICK
PROGRAM MANAGER
(858) 974-5813
FAX (858) 974-5928

PUBLIC SAFETY GROUP
SAN DIEGO COUNTY FIRE AUTHORITY

KEN MILLER & RALPH STEINHOFF
FIRE SERVICES COORDINATOR
(858) 974-5920
FAX (858) 974-5928

8525 Gibbs Drive, Suite 201, San Diego, CA 92123

May 17, 2013

County of San Diego
Planning & Development Services
5510 Overland Ave., Suite 321
San Diego, CA 92123

Attn: Ashley Gungle, Project Planner

Ref: **P12-010 –Rugged Solar Farm LLC**
Multiple APNs
San Diego County Fire Authority
Fire Protection Plan—Not Accepted without Revision

We have reviewed the revised Fire Protection Plan prepared by DUDEK, dated April, 2013, and the Plot Plans prepared by Aecom Technical Services, Inc., dated April 29, 2013. Please accept the following comments:

PLOT PLAN

- Sheets C-102-6 are not to scale.
- There is inadequate access to the trackers in many areas throughout the project. Please revise to be consistent with the FPP.
- There is no water storage in the Center Top portion of the project.
- There appears to be no access to the water storage in the Center Bottom portion of the project.

FIRE PROTECTION PLAN

- Pages 22 & 23: When discussing the Project will enter into a Fire Service Agreement with the SDCFA, stipulate that the agreement will be per the Project Design Feature PS-1 of the Soitec Solar Development Program EIR.
- Page 22: When discussing adequate emergency access, please also include the 20 foot wide perimeter access roads.
- Page 31, paragraph 3: The new co-location of the Boulevard and CAL FIRE fire stations will be near the existing *Boulevard* fire station.

- The plot plans in Appendix A are inconsistent with the plot plans by Aecom Technical Services, Inc.

Please call or email me if you have any questions or need clarification – (858) 495-5434 or James.Pine@sdcounty.ca.gov.

Best Regards,

A handwritten signature in blue ink, appearing to read "James Pine".

James Pine, Fire Marshal
San Diego County Fire Authority
Public Safety Group