



**County of San Diego
Planning & Development Services
BUILDING DIVISION**

ACCESSIBILITY CORRECTION LIST Public Accommodations & Commercial Buildings	14B³
Educational Uses	

RECORD ID:	OWNER ON APPLICATION:
------------	-----------------------

LIBRARIES AND STUDY AREAS

1. The following areas shall be accessible:
 - Library card files
 - Book stacks
 - Periodicals
 - Reading and study areas
 - Reference areas
 - Information desks
 - Circulation counters

CBC 11B-206.2.4

2. Dimension aisles complying with the following at open book stacks:
 - Main aisles minimum 44-inches wide
 - Side, range, and end aisles minimum 36-inches wide

CBC 11B-403.5.1

3. Specify book stacks maximum 54 inches above finished floor.
Exception: Where attendant available to assist persons with disabilities
Exception: Book stacks restricted to employee use

CBC 11B-225.2.3

4. Identify on floor plan at least 5% of total seating spaces complying with wheelchair space requirements of items 5 through 9.

CBC 11B-226

5. Dimension accessible routes and aisles serving seating per the following:
 - Minimum 36-inch-wide accessible route to each wheelchair space
 - Minimum 36-inch-wide aisles serving tables or seats on only one side
 - Minimum 44-inch-wide aisles serving tables or seats on both sides

CBC 11B-403.5.1

6. Dimension minimum 30-inch-by-48-inch clear floor space positioned for forward approach to each wheelchair space.

CBC 11B-902.2

7. Detail and dimension knee clearance complying with the following at each wheelchair space:
 - Minimum 27-inches high
 - Minimum 30-inches wide
 - Minimum 11-inches deep

CBC 11B-306.3

8. Detail and dimension toe clearance complying with the following at each wheelchair space:
 - Minimum 9-inches high
 - Minimum 30-inches wide
 - Minimum 19-inches deep

CBC 11B-306.2

9. Specify table tops minimum 28 inches and maximum 34 inches above finished floor at each wheelchair space.

CBC 11B-902.3

**THIS DOCUMENT IS FOR PLAN REVIEW ONLY.
CORRECTION LIST ITEMS AND FIGURES MAY NOT BE REPRODUCED OR COPIED ON PLANS.
IF CONFLICTS EXIST BETWEEN CODE TEXT AND FIGURES, THE CODE TEXT SHALL GOVERN.**

5510 OVERLAND AVE, SUITE 110, SAN DIEGO, CA 92123 • (858) 565-5920 • (888) 336-7553

HTTP://WWW.SDCPDS.ORG