

**REVIEW FOR APPLICABILITY OF/COMPLIANCE WITH
ORDINANCES/POLICIES**

**FOR PURPOSES OF CONSIDERATION OF
WILLIAMS RESIDENCE; P03-134, ER 03-01-009**

November 8, 2007

I. HABITAT LOSS PERMIT ORDINANCE – Does the proposed project conform to the Habitat Loss Permit/Coastal Sage Scrub Ordinance findings?

YES

NO

NOT APPLICABLE/EXEMPT

Discussion:

While the proposed project and off-site improvements are located outside of the boundaries of the Multiple Species Conservation Program, the project site and locations of any off-site improvements do not contain habitats subject to the Habitat Loss Permit/Coastal Sage Scrub Ordinance. Therefore, conformance to the Habitat Loss Permit/Coastal Sage Scrub Ordinance findings is not required.

II. MSCP/BMO - Does the proposed project conform to the Multiple Species Conservation Program and Biological Mitigation Ordinance?

YES

NO

NOT APPLICABLE/EXEMPT

Discussion:

The proposed project and any off-site improvements related to the proposed project are located outside of the boundaries of the Multiple Species Conservation Program. Therefore, conformance with the Multiple Species Conservation Program and the Biological Mitigation Ordinance is not required.

III. GROUNDWATER ORDINANCE - Does the project comply with the requirements of the San Diego County Groundwater Ordinance?

YES

NO

NOT APPLICABLE/EXEMPT

Discussion:

The project does not require groundwater. The project will not use any groundwater for any purpose; including irrigation or domestic supply therefore it is not subject to the groundwater ordinance.

IV. RESOURCE PROTECTION ORDINANCE - Does the project comply with:

The wetland and wetland buffer regulations (Sections 86.604(a) and (b)) of the Resource Protection Ordinance?	YES <input checked="" type="checkbox"/>	NO <input type="checkbox"/>	NOT APPLICABLE/EXEMPT <input type="checkbox"/>
The Floodways and Floodplain Fringe section (Sections 86.604(c) and (d)) of the Resource Protection Ordinance?	YES <input checked="" type="checkbox"/>	NO <input type="checkbox"/>	NOT APPLICABLE/EXEMPT <input type="checkbox"/>
The Steep Slope section (Section 86.604(e))?	YES <input checked="" type="checkbox"/>	NO <input type="checkbox"/>	NOT APPLICABLE/EXEMPT <input type="checkbox"/>
The Sensitive Habitat Lands section (Section 86.604(f)) of the Resource Protection Ordinance?	YES <input checked="" type="checkbox"/>	NO <input type="checkbox"/>	NOT APPLICABLE/EXEMPT <input type="checkbox"/>
The Significant Prehistoric and Historic Sites section (Section 86.604(g)) of the Resource Protection Ordinance?	YES <input checked="" type="checkbox"/>	NO <input type="checkbox"/>	NOT APPLICABLE/EXEMPT <input type="checkbox"/>

Discussion:

Wetland and Wetland Buffers: The site contains no wetland habitats as defined by the San Diego County Resource Protection Ordinance. The site does not have a substratum of predominately undrained hydric soils, the land does not support, even periodically, hydric plants, nor does the site have a substratum that is non-soil and is saturated with water or covered by water at some time during the growing season of each year.

Floodways and Floodplain Fringe: The project is not located near any floodway/floodplain fringe area as defined in the resource protection ordinance, nor is it located near any watercourse which is plotted on any official County floodway/floodplain map.

Steep Slopes: The project site is located in an area of mixed residential and agricultural use on a minor peak at approximately 800 feet elevation. The average slope for the property is 25 percent gradient. Slopes with a gradient of 25 percent or greater and 50 feet or higher in vertical height are required to be placed in open space easements by the San Diego County Resource Protection Ordinance (RPO). The unmanned telecommunications facility will be located however, at a plateau at the top the peak where there are no steep slopes greater than 25 percent. There are no steep slopes on the property. Therefore the project is in conformance with the RPO.

Sensitive Habitats: No sensitive habitat lands were identified on the site as determined on a site visit conducted by Katie Hughes on August 9, 2007. Therefore, it has been found that the proposed project complies with Section 86.604(f) of the Resource Protection Ordinance.

Significant Prehistoric and Historic Sites: The County of San Diego staff archaeologist/historian has inspected the property, analyzed records, and determined there are no archaeological/ historical sites.

V. STORMWATER ORDINANCE (WPO) - Does the project comply with the County of San Diego Watershed Protection, Stormwater Management and Discharge Control Ordinance (WPO)?

YES

NO

NOT APPLICABLE

Discussion:

The project Storm Water Management Plan for this project, received July 12, 2004, was reviewed by the Department of Public Works and is determined to be complete and in compliance with the WPO.

VI. NOISE ORDINANCE – Does the project comply with the County of San Diego Noise Element of the General Plan and the County of San Diego Noise Ordinance?

YES

NO

NOT APPLICABLE

Discussion:

The proposal would not expose people to nor generate potentially significant noise levels which exceed the allowable limits of the County of San Diego Noise Element of the General Plan, County of San Diego Noise Ordinance, and other applicable local, State, and Federal noise control regulations.

Based on staff’s independent noise review, the current plot plans are considered acceptable and Staff has final recommendations to ensure that the proposed T-Mobile facility will comply with County Noise Ordinance standards. The project proposes a T-Mobile concrete block equipment shelter enclosing four equipment cabinets, all located approximately 30 feet from the nearest property line. Any proposed mechanical equipment located within the concrete enclosure is considered insignificant. Anticipated noise levels to the projects property line is considered less than significant; therefore, the proposed T-Mobile facility will comply with County Noise Ordinance property line sound level limits (Section 36.404).