

**REVIEW FOR APPLICABILITY OF/COMPLIANCE WITH
ORDINANCES/POLICIES**

**FOR PURPOSES OF CONSIDERATION OF
STARCO GAS STATION & FOOD MART
S06-026; LOG NO. 06-19-021**

October 23, 2008

I. HABITAT LOSS PERMIT ORDINANCE – Does the proposed project conform to the Habitat Loss Permit/Coastal Sage Scrub Ordinance findings?

YES

NO

NOT APPLICABLE/EXEMPT

Discussion:

The proposed project and any off-site improvements are located within the boundaries of the Multiple Species Conservation Program. Therefore, conformance to the Habitat Loss Permit/Coastal Sage Scrub Ordinance findings is not required.

II. MSCP/BMO - Does the proposed project conform to the Multiple Species Conservation Program and Biological Mitigation Ordinance?

YES

NO

NOT APPLICABLE/EXEMPT

Discussion:

The proposed project and any off-site improvements related to the proposed project are within the boundaries of the Multiple Species Conservation Program. The project conforms with the Multiple Species Conservation Program and the Biological Mitigation Ordinance as discussed in the MSCP Findings dated October 23, 2008.

III. GROUNDWATER ORDINANCE - Does the project comply with the requirements of the San Diego County Groundwater Ordinance?

YES

NO

NOT APPLICABLE/EXEMPT

Discussion:

The project will obtain its water supply from the Otay Water District which obtains water from surface reservoirs and/or imported sources. The project will not use any groundwater for any purpose, including irrigation or domestic supply.

IV. RESOURCE PROTECTION ORDINANCE - Does the project comply with:

The wetland and wetland buffer regulations (Sections 86.604(a) and (b)) of the Resource Protection Ordinance?	YES <input checked="" type="checkbox"/>	NO <input type="checkbox"/>	NOT APPLICABLE/EXEMPT <input type="checkbox"/>
The Floodways and Floodplain Fringe section (Sections 86.604(c) and (d)) of the Resource Protection Ordinance?	YES <input checked="" type="checkbox"/>	NO <input type="checkbox"/>	NOT APPLICABLE/EXEMPT <input type="checkbox"/>
The Steep Slope section (Section 86.604(e))?	YES <input checked="" type="checkbox"/>	NO <input type="checkbox"/>	NOT APPLICABLE/EXEMPT <input type="checkbox"/>
The Sensitive Habitat Lands section (Section 86.604(f)) of the Resource Protection Ordinance?	YES <input checked="" type="checkbox"/>	NO <input type="checkbox"/>	NOT APPLICABLE/EXEMPT <input type="checkbox"/>
The Significant Prehistoric and Historic Sites section (Section 86.604(g)) of the Resource Protection Ordinance?	YES <input checked="" type="checkbox"/>	NO <input type="checkbox"/>	NOT APPLICABLE/EXEMPT <input type="checkbox"/>

Discussion:

Wetland and Wetland Buffers:

The site contains no wetland habitats as defined by the San Diego County Resource Protection Ordinance. The site does not have a substratum of predominately undrained hydric soils, the land does not support, even periodically, hydric plants, nor does the site have a substratum that is non-soil and is saturated with water or covered by water at some time during the growing season of each year.

Floodways and Floodplain Fringe:

The project is not located adjacent to any floodway or floodplain fringe area as defined in the resource protection ordinance, nor is it adjacent to a watercourse plotted on any official County floodway or floodplain map.

Steep Slopes:

Slopes with a gradient of 25 percent or greater and 50 feet or higher in vertical height are required to be placed in open space easements by the San Diego County Resource Protection Ordinance (RPO). There are no steep slopes on the property. The project is in conformance with the RPO.

Sensitive Habitats:

No sensitive habitat lands were identified on the site as determined on a site visit conducted by Amber J. Griffith on March 12, 2008. Therefore, it has been found that the proposed project complies with Section 86.604(f) of the Resource Protection Ordinance.

Significant Prehistoric and Historic Sites:

Based on an analysis of County of San Diego archaeology resource files, archaeological records, maps, and aerial photographs by County of San Diego staff

archaeologist, Diane Shalom on June 18, 2008, it has been determined that the project site does not contain any archaeological/historic resources. The project will not impact historical resources or archaeological resources, because prior grading of the project site has eliminated any potential for impacts to either resource. In addition, the project must comply with the San Diego County Grading, Clearing, and Watercourse Ordinance (§87.101-87.804), CEQA §15064.5(d), and §7050.5 of the Health & Safety Code. Section 87.429 of the Grading, Clearance, and Watercourse Ordinance requires the suspension of grading operations when human remains or Native American artifacts are encountered.

V. STORMWATER ORDINANCE (WPO) - Does the project comply with the County of San Diego Watershed Protection, Stormwater Management and Discharge Control Ordinance (WPO)?

YES

NO

NOT APPLICABLE

Discussion:

The project Storm Water Management Plan dated January 22, 2007, was reviewed for this project. The document is substantially complete and complies with the San Diego County Standard Urban Stormwater Mitigation Plan (SUSMP) and Watershed Protection Ordinance (WPO) requirements for a Stormwater Management Plan.

VI. NOISE ORDINANCE – Does the project comply with the County of San Diego Noise Element of the General Plan and the County of San Diego Noise Ordinance?

YES

NO

NOT APPLICABLE

Discussion:

The proposal would not expose people to nor generate potentially significant noise levels which exceed the allowable limits of the County of San Diego Noise Element of the General Plan, County of San Diego Noise Ordinance, and other applicable local, State, and Federal noise control regulations.

Transportation (traffic, railroad, aircraft) noise levels at the project site are not expected to exceed Community Noise Equivalent Level (CNEL)=60 decibels (dB) limit because review of the project indicates that the project is not in close proximity to a railroad and/or airport. Additionally, the County of San Diego GIS noise model does not indicate that the project would be subject to potential excessive noise levels from circulation element roads either now or at General Plan buildout.

Noise impacts to the proposed project from adjacent land uses are not expected to exceed the property line sound level limits of the County of San Diego Noise Ordinance.

According to the noise report, commercial HVAC unit and gas pump islands are considered the two primary noise sources associated with the project. The noise model within the noise report identifies noise levels to be as high as 47.7 dBA at the northern property line. The project site is zoned C36 and is subject to a one-hour average nighttime sound level limit of 55 dBA at the boundary line. Adjacent properties to the north are zoned RS7 and are subject to a one-hour average nighttime sound level limit of 45 dBA. The sound level limit at a location on a boundary between two (2) zoning districts is the arithmetic mean of the respective limits for the two districts. Potential noise levels generated by the HVAC unit and pump island stations will result in noise levels below 50 dBA at the project property line meeting the County Noise Ordinance sound level requirement. For property line noise levels, please refer to Table 4: Receptor Sound Level Prediction Chart.