



April 24, 2015

COMPLIANCE ADVISORY

Low Permeation Hoses to be Required for Assist Phase II EVR Systems

On March 18, 2015, the California Air Resources Board issued Advisory #343 regarding the replacement of gasoline hoses at gas stations equipped with vacuum assist (Healy) Phase II EVR Systems. The advisory requires low permeation hoses to be used when replacing gasoline hoses. **Starting July 1, 2015, low permeation hoses will be the only allowable replacement hoses for Assist Phase II EVR Systems certified under Executive Orders VR-201, VR-202 and VR-210.**

By September 24, 2018, all gasoline dispensing facilities with an Assist Phase II EVR System listed above must be equipped with certified low permeation hoses exclusively.

Should you have any questions regarding the replacement of hoses or any other vapor recovery related matters, please contact Tim Wolff at (858) 586-2677 or via e-mail at tim.wolff@sdcounty.ca.gov.

TW:jlm

Attachment