



**SAN DIEGO AIR POLLUTION CONTROL DISTRICT**  
**COMPLIANCE DIVISION**  
**10124 OLD GROVE ROAD**  
**SAN DIEGO CA 92131**  
 PHONE (858) 586-2650      FAX (858) 586-2651

| APCD USE ONLY |
|---------------|
| SECTOR _____  |
| ID# _____     |
| NOV# _____    |

## **Exhibit 13 of VR-203/4 and Exhibit 8 of VR-208** **Hirt VCS 100 Processor Operability Test**

**Facility Name:** \_\_\_\_\_      **A/C or PO Number:** \_\_\_\_\_      **Date/Time of Test\*:** \_\_\_\_\_

**For ISD Alarm Response Purposes only:** Processor is on and processing vapors:    **Yes**     **No**

Was TP-201.3 (Including Exhibit 4) conducted in the last 24 hours?     **Yes** or  **No**

Was TP-201.4 (Including Exhibit 6) conducted in the last 24 hours?     **Yes** or  **No**

Was Exhibit 5 conducted in the last 24 hours?     **Yes** or  **No**

Was there a fuel delivery within the last 3 hours?     **Yes** or  **No**

Is the total ullage 70% or less of the total capacity of the GDF storage tank(s):     **Yes** or  **No**

|           |  |
|-----------|--|
| STEP 5.1  | Is POWER switch lit? <input type="checkbox"/> <b>Yes</b> or <input type="checkbox"/> <b>No</b>   |
| STEP 5.2  | Is PROCESSING lamp ON? <input type="checkbox"/> <b>Yes</b> or <input type="checkbox"/> <b>No</b><br>If "YES", test cannot be performed until lamp goes off.                                |
| STEP 5.9  | Time for PROCESSING Lamp to Light? _____ minutes<br>Did PROCESSING Lamp light within three (3) minutes? <input type="checkbox"/> <b>Yes</b> or <input type="checkbox"/> <b>No</b>          |
| STEP 5.10 | Time for OVERPRESSURE Lamp to Light? _____ minutes<br>Did OVERPRESSURE Lamp light within sixty two (62) minutes? <input type="checkbox"/> <b>Yes</b> or <input type="checkbox"/> <b>No</b> |

\*Record exact time of test to demonstrate proper test sequencing as required in Attachment A.