

**FOR YOUR INFORMATION**

**The Following Notice was Published by the District**

**NOTICE OF PRELIMINARY DECISION  
TO APPROVE A SOURCE OF AIR POLLUTION BY THE  
SAN DIEGO AIR POLLUTION CONTROL DISTRICT**

The San Diego Air Pollution Control District has made a preliminary decision to approve an Authority to Construct for two, 2 MW Emergency Engine Generators, each powered by a 2,933 bhp rated diesel engine, Application Nos. APCD2017-APP-004995 and APCD2017-APP-004996, to be operated at Naval Base Coronado in Coronado, CA.

An evaluation of the air pollution impacts of this proposal was performed by the District and it was determined that all applicable District Rules and Regulations will be met when the equipment complies with conditions prescribed by the District. An Air Quality Impact Analysis was conducted for Oxides of Nitrogen (NOx). Results indicate that the operation of this equipment will not result in the violation of any State or Federal ambient air quality standard or interfere with the attainment or maintenance of any State or Federal ambient air quality standard. The combined potential to emit for this equipment is 60.5 lbs/hr, and 1.51 tons/yr of NOx.

The Air Quality Impact Analysis is available for review at the Air Pollution Control District, 10124 Old Grove Road, San Diego, CA 92131. Please refer to Application No. APCD2017-APP-004995 on all correspondence regarding this project.

Written comments concerning the District's proposed action may be submitted for a period of 30 days commencing July 5, 2017 and ending on August 4, 2017.

Questions regarding this notice may be directed to Nicholas Horres at (858) 586-2728 or Nick.Horres@sdcounty.ca.gov.

.....

Published: July 5, 2017 NH:cm –  
6/30/2017