



County of San Diego

DEPARTMENT OF ENVIRONMENTAL HEALTH

5500 Overland Drive #201, San Diego 92123
P.O. BOX 129261, SAN DIEGO, CA 92112-9261
(858 505-6659) FAX (858) 505-6824 www.sdcdeh.org

CHECKLIST FOR PUBLIC POOL ANCILLARY FACILITIES

The following items are needed on plans to be acceptable for plan review approval. If all occupied units are less than 300 feet walking distance from pool, provide a scaled detail indicating such. To determine the number of fixtures, one pool user is considered for every 15 square feet of pool water surface area (divided by two for each gender):

- 1. Show separate toilet rooms for each gender. One toilet for every 60 women and one toilet for every 75 men.
- 2. Show urinal(s) in men's room, and lavatories in toilet rooms. One urinal for every 75 men. One lavatory for every 80 pool users.
- 3. State "hot water maximum 110°F to shower and lavatories, not controlled by the bather". When a common hot water heater is used for lavatories, showers and laundry or other use, indicate the device that will be used to limit hot water to 110°F. Soap in dispensers to be at showers and lavatories.
- 4. State that walls and ceilings are washable and moisture resistant in toilet rooms and showers, and give an acceptable finish schedule. Suggested walls for shower and behind urinals, lavatories and toilets are ceramic tile, FRP, etc.
- 5. State and show on plans and finish schedules, the floors for toilets, showers and walkways to and from the pool area. Indicate the following items:
 - A. State or show non-slip and non-absorbent, unglazed, ceramic tile (2 X 2" max size), or broom finish concrete etc. Submit samples if other than broom finish concrete or unglazed 1x1" or 2 X 2" ceramic tile. It is advisable to include tests for slip coefficient as an aide to determine slip resistance.
 - B. State or show continuous coving, 5", with a 3/8" minimum radius cove up walls. If broom finish concrete, then show 5" min. curb or stem wall with the radius. A 'slimfoot' ceramic base may be acceptable on sealed concrete. Provide a sample.
- 6. Show floor drains and indicate floors are sloped 1/4" per foot to drains (for both restrooms and pool equipment room).
- 7. Dressing Room: Not required if adjacent to living quarters, regardless of the distance from the pool to the farthest unit.
- 8. Bather Shower: Not required if adjacent to living quarters. If installed, provide shower floor and wall schedules. Show shower floor sloped to sewer drain sufficient distance out from showerhead to intercept and confine shower water. One shower to be provided for every 50 pool users per gender. NOTE: A rinse shower does not substitute for a bather shower if required.
- 9. Show drinking fountain. (Required if toilet facilities present. If no toilet facilities are present, then no drinking fountain is required). One drinking fountain for the first 250 pool users and an additional one for every 200 pool users or fraction thereof.
- 10. A diaper change station to be made available. If placed in restrooms, ensure in both men and women restrooms.
- 11. Potable water hose bibb(s) protected with backflow device to be located so that all portions of the pool deck may be reached with a 75 foot length of hose.
- 12. Submit architectural landscape plans. Include fencing, walls and deck (material and drainage). Also identify any structures or features within the pool enclosure area. See also the "Public Pool Fencing Requirements" document.