

### Sample Monthly Aboveground Tank or Container Inspection Form

Month/Year																			
Inspection Date																			
Inspector Name																			
Area	OK	No*	Correction Date	OK	No*	Correction Date	OK	No*	Correction Date	OK	No*	Correction Date	OK	No*	Correction Date	OK	No*	Correction Date	

- Inspection Procedure:
- Check / Inspect for:
1. Tanks, fittings, nozzles, and valves free of signs of leakage (if tank surfaces or containment is oily, cleaning may be required prior to reinspection)
  2. Tank shell (sides bottom and visible top), tank legs/supports, fittings and closures, and valves free of signs of corrosion, blistered paint, damage, distortion or deterioration
  3. Tank level gauges or sight tubes operating properly and leak free
  4. Drums free of dents, rusting or other damage
  5. No evidence of tank or drum overfills
  6. Containment drainage valve securely closed
  7. Secondary containment free of liquid accumulation or significant oil staining; containment floor, curbing/sides curbing free of cracking or damage
  8. Oil piping, hoses and piping mounts/supports free of signs of leaks, damage, settling/distortion, corrosion, peeling paint
  9. Loading areas in front of tanks and in drum drop off areas clean and free of signs of leaks or spills
  10. Spill response supplies well stocked and immediately available

\*Comments/Corrective action needed:

---



---



---



---