



NOTES:

1. FITTINGS SHALL BE PVC SCH 40.
2. NIPPLES AND RISERS SHALL BE PVC SCH 80.
3. TEFLON TAPE SHALL BE USED ON THREADED CONNECTIONS.
4. CLOSE NIPPLES SHALL NOT BE USED.
5. ANTI-DRAIN VALVES SHALL BE INSTALLED UNDER OR IN ALL HEADS.
6. LATERAL DEPTH SHALL BE 18" WHEN 12" POP-UP BODIES ARE USED.

LEGEND ON PLANS

SHOW A NUMBER TO INDICATE TYPE HEAD

Revision	By	Approved	Date	SAN DIEGO REGIONAL STANDARD DRAWING	RECOMMENDED BY THE SAN DIEGO REGIONAL STANDARDS COMMITTEE
ORIGINAL		Kercheval	12/75		
Reviewed	EW	T. Stanton	10/18	ROTOR, SPRAY, OR BUBBLER POP-UP HEAD	 03/24/2022 Chairperson R.C.E. 52241 Date
Reviewed	RP	S. Engeda	03/22		
					DRAWING NUMBER I-03