



VALLEY CENTER FIRE PROTECTION DISTRICT

Administrative Office & Fire Prevention Bureau

28234 Lilac Road

Valley Center, CA 92082

Tel: 760-751-7600

Fax: 760-749-3892

Thursday, August 27, 2015

County of San Diego
Planning and Development Services
5510 Overland Avenue, Suite 110
San Diego, CA 92123

Subject: Approved Fire Protection Plan (08-24-2015)
Valley Center Photovoltaic Solar System (commercial)
PDS2013-MUP-13-019; PDS2013-ER-02-002
Cole Grade Road – 188-120-09&10-00
Valley Center Fire Protection District (VCFPD)

Gentlemen:

We have reviewed the revised Fire Protection Plan – Letter Report, Plot Plan, and Preliminary Grading Plans prepared by Michael Backer International.
We approved the FPP with the requested waivers.

Yours in Safety,


George E. Lucia Sr.
Battalion Chief / Fire Marshal
Valley Center Fire Protection District

Fire Station # 1
28234 Lilac Road
Valley Center, CA 92082

Fire Station # 2
28205 N. Lake Wohlford Road
Valley Center, CA 92082



VALLEY CENTER FIRE PROTECTION DISTRICT

Administrative Office & Fire Prevention Bureau

28234 Lilac Road

Valley Center, CA 92082

Tel: 760-751-7600

Fax: 760-749-3892

Thursday, August 27, 2015

County of San Diego
Planning & Development Services
5510 Overland Avenue
Suite 110
San Diego, CA 92123

Subject: Request for Agency Recommendations
NLP Valley Center Solar LLC, Photovoltaic Solar System (commercial)
PDS2013-MUP-13-019
29471 Cole Grade Road / 188-120-09-00 & 188-120-10-00
Valley Center Fire Protection District (VCFPD)

Gentlemen:

The following are the Valley Center Fire Protection District Fire Marshal's comments regarding the subject project, based on the current information available to us at this preliminary project stage. Fire conditions may change and be clarified as more detailed plans are received.

PROJECT DESCRIPTION

This proposed photovoltaic solar system project is ground mounted within 25 acres of the 66 acre site.

The system will be PV solar panels mounted on a single-axis tracking system.

The project is located in designated Wildland Urban Interface, State Responsibility Area, and "Very High" Fire Severity Zone (the highest category.)

Note: setbacks are 30 feet in the very high zone.

The County Consolidated Fire Code and Valley Center Fire Protection District Fire Code apply. The State Board of Forestry and Fire Protection certified the current San Diego County Consolidated Fire and Building Codes as a package as meeting the CCR Title 14 requirements, and authorizing its use in lieu of Title 14. The County, as land planning authority, is obligated to enforce it. Because the project is in State Responsibility Area, minimum County Consolidated Fire Code requirements must be applied in addition to Valley Center Fire Protection District Fire Code.

Fire Station # 1
28234 Lilac Road
Valley Center, CA 92082

Fire Station # 2
28205 N. Lake Wohlford Road
Valley Center, CA 92082

GENERAL PLAN CONFORMANCE

PDS2013-MUP-13-0-19; PDS2013-ER-02-002

FIRE JURISDICTION

The subject property is within the Valley Center Fire Protection District, which provides structural, wildland fire protection, and emergency medical services on a year around basis. Wildland fire protection is provided by the California Department of Forestry and Fire Protection (CAL FIRE).

TRAVEL TIME. *(VCFPD Ordinance No: 2014-44 Fire Code section 202)*

The estimated time it would take for a responding agency to travel from the fire station to the furthest structure in this proposed development project, determined by measuring the safest, most direct, appropriate and reliable route with consideration given to safe operating speeds for heavy fire apparatus.

The most remote portions of this project are located approximately 2.7 miles from Valley Center Fire Protection District's Station #1 located at 28234 Lilac Road, with an emergency travel time of about 6 minutes when calculated by Table C.1.11 (b) NFPA 1142.

IMPACT *(VCFPD Ordinance: CFD-2008-01)*

This and other projects will have a cumulative impact on the availability of fire services. The level of fire service availability will, if not mitigated, decline. Mitigation is required in the form of participation in a Community Facility District or similar approved mechanism to generate adequate funding for emergency and prevention services in perpetuity. See CFD-2008-01 Valley Center Fire Protection District Requirements. Additional impacts, such as access, fuel (vegetation) modification and water supply, are identified below.

Note, Project Facility Availability status is "fire protection facilities are not expected to be adequate to serve the proposed development within the next five years" until the CFD-2008-01 is perfected.

FIRE ACCESS ROADWAYS - Road design

(County Consolidated Fire Code / VCFPD Ordinance No: 2014-44)

On-site fire access roadways are required around and from arrays and components to a public way. The fire access roadway shall be extended to within 225 feet of acceptable fire fighter hose line access to all ground level exterior portions of any arrays and components. Fire apparatus access roadways in residential and commercial areas shall have an unobstructed, improved width of not less than 24 feet all-weather paved, designed and maintained to support the imposed load of fire apparatus (not less than 75,000 lbs. GVW.). Fire apparatus access roads shall be provided and maintained for purposes of rapid and reliable fire apparatus access and for unobstructed traffic circulation for evacuation or relocation of civilians during an emergency event. Ground-mounted photovoltaic arrays 10 acres or larger in size shall provide a fire apparatus access roadway around the perimeter of the project. The perimeter fire apparatus access roadway shall comply with section 503.

EMERGENCY KEY ACCESS

All central station-monitored fire detection systems and fire sprinkler systems shall have an approved emergency key access box on site in an approved location. The owner or occupant shall provide and maintain current keys for any structure for fire department placement in the box and shall notify the fire department in writing when the building is re-keyed. (Sec. 506.1.3).

IDENTIFICATION

Ground-mounted photovoltaic arrays with multiple equipment structures shall include a means of readily identifying each equipment structure. The fire code official may require a lighted directory map of the project to be installed on-site near the entrance to the facility for projects of 10 or more acres in size.

TRAFFIC CALMING DEVICES

Traffic calming devices (including, but not limited to, speed bumps, speed humps, speed control dips, etc.) shall be prohibited unless approved by the fire code official. (Sec. 503.4.1)

MARKINGS

When required by the fire code official, approved signs or other approved notices shall be provided for fire apparatus access roads to identify such roads or prohibit the obstruction thereof. Signs or notices shall be maintained in a clean and legible condition at all times and will be replaced or repaired when necessary to provide adequate visibility. All new public roads, all private roads within major subdivisions and all private road easements serving four or more parcels shall be named. Road name signs shall comply with County of San Diego Department of Public Works Design Standard #DS-13. (Sec. 503.3).

FIRE PROTECTION PLAN

(County Consolidated Fire Code / VCFPD Ordinance No: 2014-44

FIRE CODE SECTION 4903 / FIRE PROTECTION PLAN

When required. Planning and Development Services or the FAHJ may require an applicant for a parcel map, subdivision map, specific plan or major use permit for any property located in a wildland-urban interface fire area to submit a Fire Protection Plan (FPP) as part of the approval process. (Sec. 4903.1).

Content. The FPP shall consider location, topography, geology, aspect, combustible vegetation (fuel types), climatic conditions and fire history. The plan shall address the following in terms of compliance with applicable codes and regulations including but not limited to: water supply, vehicular and emergency apparatus access, travel time to nearest serving fire station, structural ignitability, structure set back, ignition-resistive building features, fire protection systems and equipment, impacts to existing emergency services, defensible space and vegetation management.

The FPP shall be prepared as prescribed in the County of San Diego Land Use and Environment Group "Guidelines for Determining Significance and Report Format and Content Requirements for Wildland Fire and Fire Protection" document. (Sec. 4903.2).

A Fire Protection Plan (FPP), (Long Format) submitted to and approved by the VCFPD Fire Marshal, is required. It must meet VCFPD Guidelines for Determining Significance and Report Format and Content

SECURITY GATES

No person shall install a security gate or security device across a fire access roadway without the fire code official's approval.

- An automatic gate across a fire access roadway or driveway shall be equipped with an approved emergency key-operated switch overriding all command functions and opening the gate.
- A gate accessing hazardous institutional, educational or assembly occupancy group structure, shall also be equipped with an approved emergency traffic control-activating strobe light sensor or other device approved by the fire code official, which will activate the gate on the approach of emergency apparatus.
- An automatic gate shall be provided with a battery back-up or manual mechanical disconnect in case of power failure.
- An automatic gate shall meet fire department policies deemed necessary by the fire code official for rapid, reliable access.
- When required by the fire code official, an automatic gate in existence at the time of adoption of this chapter is required to install an approved emergency key-operated switch or other mechanism approved by the fire code official, at an approved location, which overrides all command functions and opens the gate. A property owner shall comply with this requirement within 90 days of receiving written notice to comply.
- Where this section requires an approved key-operated switch, it may be dual-keyed or equipped with dual switches provided to facilitate access by law enforcement personnel.
- All gates providing access from a road to a driveway shall be located a minimum of 30 feet from the nearest edge of the roadway and shall be at least two feet wider than the width of the traffic lane(s) serving the gate.
- Electric gate openers, where provided, shall be listed in accordance with UL 325. Gates intended for automatic operation shall be designed, constructed and installed to comply with the requirements of ASTM F2200. (Sec. 503.6).

BRIDGES AND ELEVATED SURFACES

(County Consolidated Fire Code / VCFPD Ordinance No: 2014-44)

Where a bridge or an elevated surface is part of a fire apparatus access road, the bridge shall be constructed and maintained in accordance with AASHTO HB-17. Bridges and elevated surfaces shall be designed for a live load sufficient to carry the imposed loads of fire apparatus. Vehicle load limits and clearance limitations shall be posted at both entrances to bridges when required by the fire code official. Where elevated surfaces designed for emergency vehicle use are adjacent to surfaces which are not designed for such use, approved barriers, approved signs or both shall be installed and maintained when required by the fire code official

RESPONSE MAP UPDATES

Any new development which necessitates updating emergency response maps due to new structures, hydrants, roadways or similar features shall be required to provide map updates in a format compatible with current department mapping services and shall be charged a reasonable fee for updating all response maps. At a minimum, the map updates shall be provided in PDF or a CAD format approved by the FAHJ. (Sec. 505.5)

FIRE FLOW – water supply

(County Consolidated Fire Code / VCFPD Ordinance No: 2014-44)

Provide on-site fire hydrants every 300 feet. Locations shall be approved by the Valley Center FPD Fire Marshal. In hazardous fire areas the required fire flow in the water mains is 2,500 gallons per minute. Fire Hydrants shall meet County standards identified in the Consolidated Fire Code. Waterline extension will be required for purposes of hydrant installation.

(Required if the property is within a water district and a water main is 1500 feet or less from the property line.) Waterlines must be installed, and hydrants accepted by the water district and capable of full required fire flow prior to combustible materials being brought to the construction site. Water lines, fire hydrants, durable all weather fire access must be in place prior to combustible materials being on site.

FUEL MODIFICATION

(County Consolidated Fire Code / VCFPD Ordinance No: 2014-44)

Any person doing construction of any kind which requires a permit under this code or the County Building Code shall install a fuel modification zone prior to allowing any combustible material to arrive on the site and shall maintain the zone during the duration of the project. Combustible vegetation within the array and to a distance of 30 feet from the array and associated equipment shall be reduced to a height of no more than 6 inches. The fuel modification zone may be increased when required by the fire code official or as recommended by a fire protection plan.

FIRE SAFETY PRECAUTIONS BEFORE AND DURING CONSTRUCTION

During the ownership transition and permit process, this property may fall into an unsafe condition from lack of maintenance. The VCFPD Fire Code and Vegetation Compliance program has proven effective in mitigating the spread of fires and has played a part in keeping the destruction from these fires to a minimum. Please ensure this property meets all fire safety requirements at all times prior to grading and during construction. Doing so will reduce the loss of life and property from fire. VCFPD requires the property owner to monitor and reduce the combustible fuel load on this property and at all property line areas as specified by Valley Center Fire Protection District Ordinance 2008-35 also known as the California Urban-Wildland Interface Code regulating and governing the mitigation of hazards to life and property from the intrusion of fire from wildland exposures, fire from adjacent structures, and prevention of structure fires spreading to wild land fuels in the Valley Center Fire Protection District.

August 27, 2015

WAIVERS

The following waivers requested in the revised FPP dated 08-24-2015, have been accepted by the VCFPD.

1. Increased maximum hose line access to 225 feet.
2. Current existing fire hydrants to be credited to the project.
3. Utilize the 30' fuel modification zone that runs along the perimeter of the site as a perimeter roadway.




Yours in Safety,

**George E. Lucia Sr.
Battalion Chief / Fire Marshal
Valley Center Fire Protection District**

FIRE MARSHAL

Valley Center Fire Protection District
25234 Lila Road
Valley Center, California 92082
Phone: 760-760-7600

APPROVED



Fire Marshal

The Attached Conditions
are approved

August 24, 2015

County of San Diego
Department of Planning and Development Services
5510 Overland Avenue, Suite 310
San Diego, CA 92123

San Diego County Fire Authority – Public Safety Group
c/o James Pine, County Fire Marshal
5510 Overland Avenue, Ste. 250
San Diego, CA 92123

SUBJECT: FIRE PROTECTION PLAN - LETTER REPORT WITH FIRE BEHAVIOR
MODELING
VALLEY CENTER SOLAR PROJECT
PDS2013-MUP-13-019; PDS2013-ER-02-002
APN'S: 188-120-09 AND -10 (PORTION OF)

Dear Mr. Pine:

This Fire Protection Plan (FPP) – Letter Report is being submitted pursuant to Chapter 49 of the County Fire Code as an evaluation of the adverse environmental effects that a proposed project may have from wildland fire and as mitigation of those impacts to ensure that the above-referenced Project does not unnecessarily expose people or structures to a significant risk of loss, injury, or death involving wildland fires.

PROJECT DESCRIPTION

The Project proponent is preparing an application for development and operation of a photovoltaic (PV) solar facility to be located on privately-held lands near Valley Center, California. The subject site is located at 29471 Cole Grade Road and is bordered by Cole Grade Road to the west. The Project would require approval from the County of San Diego for a Major Use Permit (MUP) to allow for the construction, operation, and maintenance of such facilities for the long-term generation of clean renewable power from solar energy.

The County Assessor Parcel Numbers (APNs) that comprise the Project area for the main facilities are 188-120-09 and -10, totaling approximately 66 acres (gross). The proposed MUP area for the Project includes approximately 26 acres of the 66 acres. The remainder of the two affected

JN: 145596

FIRE MARSHAL

Valley Center Fire Protection District
28234 Lilac Road
Valley Center, California 92082
(760) 751-7600

APPROVED

Date 8-30-2015

By [Signature]

Fire Marshal

parcels would largely remain in its natural state. Refer to Figure 1, Regional Location Map; Figure 2A, Local Vicinity Map; and, Figure 2B, USGS Quad Map.

The proposed PV solar facilities would be located within an approximately 26-acre land area (“MUP area”) on the affected parcels, allowing the remaining acreage onsite to remain in its present state as undeveloped land. Project development would require a balanced cut and fill grading quantity of 6,000 cubic yards.

The Project design will consist of PV solar panels mounted on a collection of single-axis tracking (SAT) systems supported by machine-driven metal “H” piles or round pipe columns. The solar panels would face to the east in the morning and to the west in the evening hours, thereby tracking the sun along the vertical axis to maximize solar absorption during the hours of daylight. The panels would be mounted on a rack system, measuring approximately 7-12 feet in height as measured from the ground surface to the top of panel. As such, the solar panels would not represent elements of large scale or height within the existing landscape. The length of each row of panels would measure approximately 278 feet along the north/south axis. The ultimate arrangement/number of PV solar panels, racking, inverter pads and structures, and internal access are shown on the MUP Plot Plan to illustrate the general configuration of the proposed solar collection system; however, this layout is subject to modification at final engineering design. Refer to Figures 3A to 3B, which show the MUP Plot Plan and associated Elevations/Details; Figure 3C, Landscape Concept Plan; and, Figure 3D, Preliminary Grading Plan.

An estimated two small-scale, aboveground equipment pads would be constructed within the solar panel field. These structures would be constructed on a concrete building platform approximately 10 feet by 32 feet, and components would be approximately 10 feet in height, as measured from the ground surface. The switchgear pad would be approximately 7.5 feet by 8.4 feet, with components reaching approximately 6 feet in height, as measured from the ground surface; refer to Figure 3B, Major Use Permit Plot Plan – Elevations/Details. The inverter/transformer/switchgear structures would be constructed of non-flammable materials (i.e., metal, concrete block, or similar).

Energy generated by the Project would be delivered to an existing 12 kV distribution line. The point of interconnection (POI) would occur at an existing utility pole located within the Cole Grade Road right-of-way (ROW) adjacent to the Project boundary. No offsite gen-tie improvements are required. The line would extend underground from the onsite switchgear pad to the existing utility pole, then connect to the 12kV line via overhead connection.

No offsite roadway improvements are required, other than the addition of a driveway taper off of Cole Grade Road; refer to Figure 3A, Major Use Permit Plot Plan. Primary access to the site would occur from Cole Grade Road.

Per VCFPD standards, ground-mounted photovoltaic arrays 10 acres or larger in size are required to provide a fire apparatus access roadway around the perimeter of the project, in compliance with Section 503. Onsite circulation would be facilitated via 24-foot wide onsite service/fire

access roads that would run along the perimeter of the majority of the proposed development area. Additionally, a looped road system of 24-foot wide roads are proposed within the interior of the development areas to allow for maintenance of the facilities; however, such roads would also be designed to be capable of accommodating emergency vehicles, as needed.

All fire access roads would be designed and maintained to support the imposed loads of fire service apparatus (not less than 75,000 lbs) and would have an approved surface so as to provide all-weather driving capabilities. The purpose of the interior fire access roads is to allow for access of fire service apparatus throughout the Project site and in order to reach the inverter/transformer units. The interior fire access roads would be constructed to facilitate a maximum fire hose pull of approximately 225 feet. Approval of a waiver would be required to exceed the maximum fire hose pull of 150 feet.

In order to control dust during the life of the Project, a non-toxic, biodegradable, permeable soil-binding agent or permeable rock material would be applied to all disturbed or exposed surface areas as follows: a) A permeable soil-binding agent suitable for both traffic and non-traffic areas shall be used. These agents shall be biodegradable, eco-safe, with liquid copolymers that stabilize and solidify soils or aggregates and facilitate dust suppression; or, b) Alternatively, a permeable rock material consisting of either river stone decomposed granite or gravel could be placed in a thin cover over all exposed surface area in-lieu of the binding agent referenced above. The binding agent would be reapplied approximately every two years for maintenance purposes.

It is anticipated that overall construction of the Project would take approximately four months to complete. Crews would work five days per week, eight hours per day.

The Project would be served by the Valley Center Fire Protection District (VCFPD) from Fire Station No. 1 located at 28234 Lilac Road, just southeast of the Project site. As the Project would have the potential to result in additional demands on the VCFPD and/or other area emergency service providers, the Project would be conditioned to participate in the existing Community Facilities District (CFD) created by the VCFPD or similar approved mechanism to generate adequate funding for emergency and prevention services in perpetuity; refer also to CFD-2008-01 VCFPD Requirements. The Project applicant shall comply with all requirements of the CFD, as applicable, and once such specific requirements have been identified. Joining the CFD for fire protection services and payment of the required fees will ensure that fire protection services would be adequate to serve the Project, and that no significant cumulative effects occur as the result of Project implementation.

ENVIRONMENTAL SETTING

1. Location: The proposed Project site for the NLP Valley Center Solar Project is located within the community of Valley Center, California, within north-central San Diego County. The Project site is located approximately eight miles east of Interstate 15 (I-15) and immediately east of Cole Grade Road. The affected County Assessor Parcel Numbers (APNs) are 188-120-09 and -10, totaling approximately 66 acres (gross); however, only a 26-acre portion of the subject parcels

would be developed as part of the Project; refer to Figure 1A, Regional Location Map, and Figure 2A, Local Vicinity Map.

2. Topography: The Project site is located in north-central San Diego County. The Project site is located along the valley floor, and onsite topography is generally flat. The site is generally flat, and onsite elevations range from approximately 1,532 feet above mean sea level (amsl) in the northeastern portion of the site to approximately 1,465 feet amsl in the southwestern portion. Of the 26-acre MUP area, approximately 98.8 percent of lands have a slope of zero to 15 percent; only 1.2 percent (or 0.3 acres) have slopes of greater than 25 percent. No areas prone to landslide or subsidence occur onsite or on adjacent lands.

3. Geology: The Project area and the surrounding community of Valley Center are generally underlain by Quaternary alluvium. The site does not contain geological features that would pose any increased danger of wildfire potential or human safety issues.

4. Flammable Vegetation - The subject property currently supports fallowed agricultural lands (citrus grove). Many of the citrus trees have been removed from the property, and the land is generally devoid of vegetation or has minor cover of ruderal species. Several rows of trees are present along the western and northern boundaries of the site that would remain with implementation of the Project as designed to provide screening of the proposed development from adjacent roadways (e.g. Cole Grade Road and Via Valencia). Disturbed areas are also present onsite in the form of dirt roads. Two intermittent drainages traverse the central portion of the larger 66-acre property, generally flowing from northeast to the southwest. The drainages support sparse riparian vegetation, including a number of mature coast live oak and California sycamore trees, as well as several palm trees. Other non-native plant species are also present along the drainages.

The subject site is identified by the California Department of Forestry and Fire Protection (CalFire) as being located in a Fire Hazard Severity Zone designated as "Very High" within a State Responsibility Area (SRA), and in the County of San Diego General Plan Safety Element as being in an area with a potential fire threat of "High" to "Very High."

5. Climate: The climate in Valley Center is typically warm during summer when temperatures tend to be in the 70's and cool during winter when temperatures tend to be in the 50's. The warmest month of the year is August with an average maximum temperature of 89 degrees Fahrenheit, while the coldest month of the year is December with an average minimum temperature of 42 degrees Fahrenheit. Temperature variations between night and day tend to be moderate during summer with a difference that can reach 27 degrees Fahrenheit, and moderate during winter with an average difference of 25 degrees Fahrenheit. The annual average precipitation at Valley Center is 15.1 inches. Rainfall is fairly evenly distributed throughout the year. The wettest month of the year is January with an average rainfall of 3.37 inches.

PROJECT EXPOSURE TO WILDLAND FIRES

1. Water Supply: Water for construction would be provided by the VCMWD via the existing onsite water meters (one adjacent to Cole Grade Road). To allow for ongoing maintenance of the solar panels, potable water from the existing onsite water meter would be used for the panel washing. A commercial vendor would arrive onsite and load water from the existing meter. The vendor would de-ionize the water prior to high-pressure washing the panels for maintenance. The use of groundwater is not proposed for construction or operation of the Project.

An existing fire hydrant is located within the right-of-way of Cole Grade Road. The VCFPD personnel would connect to the fire hydrant for the provision of water fire suppression in the event of an emergency. The installation of new fire hydrants is not proposed or required with the Project.

2. Fire Access Roads:

Construction Access

All materials for Project construction would be delivered to the site by truck. The majority of truck traffic would occur on designated truck routes and/or major streets. Access to the site during construction would be provided from Cole Grade Road.

Traffic resulting from Project construction activities would be temporary and may occur along area roadways as workers and materials are transported to and from the Project area. If directed by the County, the Project applicant would prepare a Traffic Construction Mitigation Plan to ensure that circulation on roadways utilized during construction is not adversely affected and that public safety is maintained.

Long-Term Access and Onsite Circulation

Permanent access to the site would occur from Cole Grade Road. No offsite roadway improvements are required, other than a hammerhead turnaround at the entrance on Cole Grade Road to accommodate emergency vehicles; refer to Figure 3A, Major Use Permit Plot Plan. Onsite circulation would be facilitated via 24-foot wide onsite service/fire access roads that would run within the proposed development areas consistent with County of San Diego Fire Standards. These roads would also be designed to be capable of accommodating emergency vehicles, as needed.

The fire access roads would be designed and maintained to support the imposed loads of fire service apparatus (not less than 75,000 lbs) and would have an approved surface so as to provide all-weather driving capabilities. The interior fire access roads would be constructed to facilitate a maximum fire hose pull of a maximum of approximately 225 feet. Approval of a waiver would be required to exceed the maximum fire hose pull of 150 feet. The purpose of the interior fire access roads is to allow for access of fire service apparatus throughout the Project site and in order to reach the inverter/transformer units.

In order to control dust during the life of the Project, a non-toxic, biodegradable, permeable soil-binding agent or permeable rock material would be applied to all disturbed or exposed surface areas as follows: a) A permeable soil-binding agent suitable for both traffic and non-traffic areas shall be used. These agents shall be biodegradable, eco-safe, with liquid copolymers that stabilize and solidify soils or aggregates and facilitate dust suppression; or, b) Alternatively, a permeable rock material consisting of either river stone decomposed granite or gravel could be placed in a thin cover over all exposed surface area in-lieu of the binding agent referenced above. The binding agent would be reapplied approximately every two years for maintenance purposes.

To facilitate circulation onsite, illuminated signage would be installed at the Project entrance off of Cole Grade Road and at each onsite inverter station that notes the location and identification number of each electrical grid disconnect and circuit breaker. The directory would readily identify each equipment structure to assist with emergency response.

Access to Multiple Evacuation Routes: Interior emergency access would be provided by fire access roads that would remain unsurfaced (covered with a binding agent) and would serve as a fire buffer. In addition, a system of internal roadways would be provided between the running rows of solar panels to allow for routine maintenance (surfaced with decomposed granite (d.g.)).

No traffic calming devices (i.e. speed bumps, speed control dips, etc.) are required or proposed. Such measures are prohibited, unless approved by the Fire Code official (Sec.503.4.1).

Dead Ends: No dead-end roads are proposed or required; refer to Figure 3A, Major Use Permit Plan. An approved fire department turnaround would be provided at the terminus of any fire apparatus access road that exceeds 150 feet in length.

Width: The improved width of the interior fire access would be 24 feet in width with a base designed and maintained to support the imposed loads of fire apparatus of not less than 75,000 lbs. In addition, a number of internal roadways of 24-foot width would be provided between the running rows of solar panels to allow for routine maintenance. A series of smaller 10-foot wide roads within the development footprint would be provided for purposes of circulation for maintenance vehicles.

Grade: A maximum 10% grade would be maintained along all Project roadways used for purposes of emergency access.

Surface: Surface improvements for onsite roadways shall consist of an all-weather material with binding agent design, and shall be constructed to VCFPD standards. All roadway surfacing material for Project roads to be used for emergency access purposes shall be compacted per County standards and suitable for travel by 75,000-lb. fire protection service apparatus (bearing load).

Gates: The perimeter of the property would be fenced with an (up to) 8-foot high chain link fence. A gate is proposed at the entrance off of Cole Gate Road to provide secured access to the Project site. All gates providing access from a road to a driveway shall be located a minimum of 30 feet from the nearest edge of the roadway. A gate is also proposed at the easterly end of the MUP boundary to allow the fire department access to the existing residential structures in the eastern

portion of the property. The gate would meet the requirements of San Diego County Fire Code Section 96.1.503.6 for automatic operation with battery back-up. The gates would open immediately upon emergency vehicle strobe light activation from either direction of approach and would include a Knox box key-operation switch.

Emergency Response Time: Emergency response time is the estimated time it would take for a responding agency to travel from the fire station serving a site to the furthest structure within the proposed development boundary. The emergency response time is determined by measuring the safest, most direct, and reliable route, with consideration for safe speeds at which heavy fire apparatus can operate.

The most remote portions of the Project are located approximately 2.7 miles from VCFPD's Station #1 located at 28234 Lilac Road. Emergency response time to the site is estimated to be approximately six minutes when calculated by Table C.1.11 (b) NFPA 1142.

3. Setback from Property Lines: The minimum setbacks as regulated by the County of San Diego Zoning Ordinance Section 4800 will be maintained. A schedule summarizing the specific zoning designation for each affected parcel is as follows:

Zone		
APN:	188-120-09 and-10 (Portion of)	
Use Regulations	RR	
Neighborhood Regulations	V	
Development Regulations	Density	--
	Lot Size	2 AC
	Building Type	C
	Maximum Floor Area	--
	Floor Area Ratio	--
	Height	G
	Lot Coverage	--
	Setback	B
	Open Space	--
Special Area Regulations		--

4. Building Construction: Building construction for onsite structures would be limited to non-combustible construction primarily of concrete block or steel. Project structures would consist of a varied number of inverters/transformers constructed on equipment building pads, and distributed within the MUP development footprint. Fire access roads would serve all equipment pads.

5. Fire Protection Systems: An existing fire hydrant is located within the right-of-way of Cole Grade Road. The VCFPD personnel would connect to the fire hydrant for the provision of water fire suppression in the event of an emergency. The installation of new fire hydrants is not proposed or required with the Project. Water lines, fire hydrants, and/or durable all-weather fire access must be in place, prior to combustible materials being onsite.

6. Defensible Space: A 30-foot wide fuel management zone (FMZ) (measured outward from the boundary of the proposed development area) would be provided around the proposed development area. Additionally, 24-foot wide fire access roads would be constructed within the interior of the site to provide a fire buffer and to ensure adequate onsite circulation of fire/emergency vehicles, as needed.

7. Vegetation Management: The VCFPD requires the property owner to monitor and reduce the combustible fuel load on the property and at all property line areas as specified by VCFPD Ordinance 2008-35 also known as the California Urban-Wildland Interface Code. The Code regulates and governs the mitigation of hazards to life and property from the intrusion of fire from wildland exposures, fire from adjacent structures, and prevention of structure fires spreading to wild land fuels in the VCFPD.

All onsite vegetation will be maintained/weed-whipped on an annual basis to a maximum of six inches, unless otherwise requested by the VCFPD. A minimum 30-foot wide FMZ shall be maintained around the perimeter of all onsite areas proposed for development to reduce the potential for the spread of wildfire. Areas under the panels would be dirt with an erosion control binding agent. The brush clearing zone shall be maintained year-round by the Project proponent as required by this FPP Letter Report and VCFPD fire regulations. The Project site shall be annually maintained to remain free of dead vegetative material.

8. Fire Behavior Computer Modeling: Per the request of the VCFPD, Computer Fire Behavior Modeling was prepared for the Project to determine the potential for the Project to increase the risk for wildfire to occur as proposed by Dudek in July 2015; refer to Appendix B of this report.

The Computer Fire Behavior Modeling completed by Dudek using BehavePlus modeling software was conducted to document the type and intensity of fire that would be expected on the site given various site-specific factors: topography, vegetation, and weather. The modeling provided a conservative (near worst-case) estimate of fire behavior, including estimates of flame length (feet), fire intensity (BTU/feet/second), and spread rate (mph), among others.

The completed modeling consists of four scenarios which vary in location and weather conditions. Two of the modeling scenarios analyzed potential fire behavior along the western and southern edges (Scenarios 3 and 4) during summer weather conditions. The other two modeling scenarios (Scenarios 1 and 2) analyzed potential fire behavior along the eastern and northern edges of the development during Peak weather conditions.

The modeling conducted for the Project site concluded that, as designed, and with consideration of conditions onsite and on surrounding lands, the Project would not result in a substantial

increase in the risk for occurrence or spread of wildfire. No additional mitigation or design measures are required to reduce such potential effects.

The Project design includes a number of measures that would help to reduce the potential for wildfire. The Project components would be constructed of non-combustible materials (i.e. metal, glass, concrete). Additionally, existing vegetation within the MUP area would be largely removed to allow for Project construction, and as a condition of approval, vegetation within the interior of the solar field (under the panels) would be routinely maintained to not exceed a height of 6 inches. Therefore, substantial vegetation would not be present within the MUP area to support a significant wildfire event. Due to the non-combustible nature of the Project components, the solar panel field would assist in reducing the spread of fire from properties abutting the Project site to other adjacent lands. Additionally, an existing hydrant located within the Cole Grade Road right-of-way is available and adequate to provide water for fire suppression services, and no new such infrastructure improvements are required or proposed with the Project. The onsite looped roadway system (24-foot wide roadways) would provide adequate circulation for emergency vehicles. The required 30-foot wide FMZ would further reduce the potential for wildfire to occur onsite or to spread to adjacent properties.

9. Signage: An illuminated directory sign (activated via motion sensor) would be located at the entrance of the facility and at each inverter station. The signage would depict the overall site plan and the locations of each numbered inverter structure and electrical grid disconnect and circuit breaker. Each inverter structure shall be numbered and signed to be plainly visible to the satisfaction of the VCFPD.

10. Disconnects: Switchgear for the Project will be housed onsite on an approximately 8.4-foot by 7.5-foot platform; refer to Figures 3A and 3B which show location and details of the switchgear platform. An override (or cut-off) switch will be provided that will be used to disconnect and disrupt all AC power leaving the inverter structures spaced throughout the site.




11. Waivers: In accordance with the attached Request for Agency Recommendations Letter from the Valley Center Fire Protection District (dated July 1, 2015) the following waivers are requested:

- In accordance with County Consolidated Fire Code/VCFPD Ordinance No: 2014-44, a waiver to increase maximum hose line access from interior fire access roadways and perimeter access road to 225 feet as the panels are fire resistant and there is a looped road system.
- In accordance with County Consolidated Fire Code/VCFPD Ordinance No: 2014-44, a waiver to satisfy the requirement of on-site fire hydrants every 300 feet. There is a fire hydrant on site, located along the western boundary of the site on Cole Grade road, therefore the need for hydrants at 300 foot spacing throughout the site is unnecessary.
- In accordance with County Consolidated Fire Code/VCFPD Ordinance No: 2014-44, a waiver to utilize the 30' fuel modification zone that runs along the perimeter of the site as a perimeter roadway if needed to defend areas that the interior roadways (which

comply with Section 503) do not surround. The utilization of the 30' fuel modification zone is acceptable as the panels are flame resistant, there is a looped road system, and the interior roads provide hose line access to the non-surrounded panel rows.

12. Training: Formal training will be provided to the VCFPD. Fire service training and an educational program shall be provided to VCFPD personnel for all shifts of the fire emergency responders.

SIGNATURES:

 _____ Prepared by (Signature)	8-24-2015 _____ Date	Nicole Marotz, Senior Envn. Planner _____ Printed Name, Title
 _____ Property Owner or Agent (Signature)	8-24-2015 _____ Date	NLP Valley Center Solar Steve Wragg, Vice President Michael Baker International, Agent _____ Printed Name, Title
 _____ Captain (Signature) b/c	8. 27. 2015 _____ Date	George Lucia, Battalion Chief/ Fire Marshall _____ Printed Name, Title

Attachments: Figures 1, 2A-2B, 3A-3D, 4; Fire Service Availability Form; Request for Agency
Recommendations
Appendix A: Wildfire Technical Report
Appendix B: Fire Behavior Computer Modeling

FIRE MARSHAL


Valley Center Fire Protection District
28234 Lilac Road
Valley Center, California 92082
(760) 751-7600

APPROVED

Date 8. 27. 2015

By 

Fire Marshal



Michael Baker
INTERNATIONAL



Source: ESRI


0 2.5 5 10 Miles



NLP Valley Center Solar


REGIONAL LOCATION MAP

Figure 1



NLP Valley Center Solar
LOCAL VICINITY MAP
Figure 2A





Michael Baker
INTERNATIONAL




Scale 1:24,000

Source: National Geographic Society, I-cubed
145596figures.indd


USGS QUAD MAP: VALLEY CENTER QUADRANGLE

NLP Valley Center Solar


Figure 2B



ZONING		
ZONE	USE REGULATIONS	RR
ANIMAL REGULATIONS	V	
DENSITY	---	
LOT SIZE	2 AC	
BUILDING TYPE	---	
MAXIMUM FLOOR AREA	---	
FLOOR AREA RATIO	---	
HEIGHT	6	
LOT COVERAGE	---	
SETBACK	B	
OPEN SPACE	---	
SPECIAL AREA REGULATIONS	---	



MUP BOUNDARY
SCALE: 1"=400'



AGRICULTURAL MITIGATION
SCALE: 1"=400'

NOTES

- GROSS AREA: 66.7 ACRES
- NET AREA: 65.6 ACRES
(COLE GRADE ROAD EASEMENT & 47' ULTIMATE R/W = 1.1 AC)
- MUP BOUNDARY AREA: 25.8 AC
- GENERAL PLAN SEMI-RURAL RESIDENTIAL (SR-2)
- REGIONAL CATEGORY: SEMI-RURAL LANDS
- TOPOGRAPHIC SOURCE: AEROTECH MAPPING INC, FLOWN 6/18/2013
- ASSOCIATED REQUESTS: NONE
- WATER DISTRICT: VALLEY CENTER MUNICIPAL WATER DISTRICT
- FIRE DISTRICT: VALLEY CENTER FIRE PROTECTION DISTRICT
- EXISTING STRUCTURES ARE TO REMAIN UNLESS NOTED.
- EXISTING SOGDE EASEMENTS (A7) AND POWER POLES ARE TO BE RELOCATED, TO NOT CONFLICT WITH PROPOSED PROJECT.
- THE APPROVAL OF THIS MAJOR USE PERMIT (MUP) AUTHORIZES THE FOLLOWING CONSTRUCTION, OPERATION, AND MAINTENANCE OF A PHOTOVOLTAIC SOLAR FARM PURSUANT TO SECTION 6552 OF THE SAN DIEGO COUNTY ZONING ORDINANCE.
- THIS PLAN IS PROVIDED TO ALLOW FOR FULL AND ADEQUATE DISCRETIONARY REVIEW OF A PROPOSED DEVELOPMENT PROJECT. THE PROPERTY OWNER ACKNOWLEDGES THAT ACCEPTANCE OR APPROVAL OF THIS PLAN DOES NOT CONSTITUTE AN APPROVAL TO PERFORM ANY GRADING SHOWN HEREON, AND AGREES TO OBTAIN VALID GRADING PERMITS BEFORE COMMENCING SUCH ACTIVITY.
- ALL SOLAR EQUIPMENT STRUCTURES TO BE CONSTRUCTED OF NON-COMBUSTIBLE MATERIALS (CONCRETE, BLOCK, METAL) OR SIMILAR.
- LIGHTING FOR MAINTENANCE AND SECURITY PROPOSES ONLY. SHIELDED LIGHTING LOCATED AT ENTRANCE GATES AND INVERTER/TRANSFORMER PADS & SHALL CONFORM TO COUNTY OF SAN DIEGO OUTDOOR LIGHTING REQUIREMENTS. SEE DETAIL ON SHEET 2.
- PHASING - PROJECT MAY BE IMPLEMENTED IN SEVERAL PHASES WITHOUT REGARD TO SEQUENCE.
- ALL DISTURBED AREAS WOULD BE COVERED WITH GRAVEL OR A BINDING AGENT TO REDUCE DUST.
- SEE PRELIMINARY GRADING PLAN FOR PROPOSED GRADING.
- NO DEVELOPMENT WILL OCCUR IN THE AREAS IDENTIFIED ON THE PLOT PLAN AS "AGRICULTURAL EASEMENT".
- SITE ACCESS GATE(S) TO BE EQUIPPED WITH FIRE DEPARTMENT APPROVED STROBE LIGHT ACTIVATION AND KNOX KEY-OPERATED SWITCH.
- SOLAR RELATED FACILITIES (PANELS, RACKING, ELECTRICAL CONNECTIONS, INVERTER/TRANSFORMER PADS, SWITCHGEAR, MET STATION, FENCING, AND INTERNAL ACCESS, ETC.) SHOWN ON THE PLOT PLAN MAY BE RELOCATED, RECONFIGURED, AND/OR RESIZED WITHIN THE SOLAR FACILITY DEVELOPMENT AREA WITH THE ADMINISTRATIVE APPROVAL OF THE DIRECTOR OF POS WHEN FOUND IN CONFORMANCE WITH THE INTENT AND CONDITIONS OF PERMIT'S APPROVAL. INVERTER/TRANSFORMER LOCATIONS CAN BE RELOCATED/RECONFIGURED WITHOUT REQUIREMENT OF MINOR DEVIATION. THE INVERTER/TRANSFORMER MUST COMPLY WITH THE NOISE ORDINANCE AND MUST BE ELEVATED 1' ABOVE FLOOD ELEVATION. THE 24" FIRE ACCESS ROAD WIDTHS MAY BE REDUCED ADMINISTRATIVELY WITH THE APPROVAL OF THE COUNTY AND FIRE AUTHORITY HAVING JURISDICTION OVER THE PROJECT.
- THE 5.6 ACRES OF ON-SITE AGRICULTURAL MITIGATION LAND WILL BE PRESERVED FOR AGRICULTURAL AND RELATED USES ONLY FOR THE LIFE OF THE PERMIT/OR APPLICANT WILL ENTER THE PACE PROGRAM AND MITIGATE AGRICULTURAL IMPACTS BY PURCHASE OF AGRICULTURAL CREDITS.
- A SYSTEM IDENTIFICATION SIGN SHALL BE LOCATED AT THE GATE ENTRANCE. SIGN SHALL BE 12X18. SIGN SHALL LIST NAME OF SITE AND CONTACT INFORMATION AS PROVIDED BY SOGDE.
- PRIVATE PROPERTY/NO TRESPASSING AND HIGH VOLTAGE SIGNS SHALL BE LOCATED AT THE GATE ENTRANCE AND EVERY 100' MINIMUM ON FENCE. THE SIGN SHALL BE 10X14. MISCELLANEOUS INTERIOR DIRECTIONAL AND SAFETY SIGNAGE ARE PERMITTED.
- OUTDOOR LIGHTING CIRCUITS SHALL INCORPORATE DUSK-TO-DAWN PHOTOCELL CONTROLLERS, OCCUPANCY SENSORS, AND/OR SWITCHES AS APPROPRIATE.
- A METEOROLOGICAL (MET) STATION SHALL BE LOCATED ADJACENT TO THE INVERTER/EQUIPMENT PAD.
- EXISTING WELL WITHIN MAJOR USE AREA SHALL BE DESTROYED IN ACCORDANCE WITH THE COUNTY REGULATORY CODE SECTION 67.431.

ASSESSOR PARCEL NUMBER

188-120-09 & 10

LEGAL DESCRIPTION

ALL THOSE PORTIONS OF THE EAST HALF OF SECTION 6, TOWNSHIP 11 SOUTH, RANGE 1 WEST, SAN BERNARDINO BASE AND MERIDIAN, IN THE COUNTY OF SAN DIEGO, STATE OF CALIFORNIA, ACCORDING TO THE OFFICIAL PLAT THEREOF, AS DESCRIBED IN DEEDS RECORDED APRIL 1, 1985 AS INSTRUMENT NO. 85-124118, AND SEPTEMBER 24, 1990 AS INSTRUMENT NO. 90-521370, JANUARY 4, 1991 AS INSTRUMENT NO. 91-0004366, ALL OF OFFICIAL RECORDS.

BASIS OF BEARINGS

THE BASIS OF BEARINGS FOR THIS SURVEY IS THE CALIFORNIA COORDINATE SYSTEM OF 1983 (CCS83, EPOCH 2011.00), ZONE 6, BASED LOCALLY UPON CONTROL STATIONS P478 & PM08, PUBLISHED BY THE CALIFORNIA SPATIAL REFERENCE CENTER (CSRC) WITH A BEARING OF N78°55'32"W.

BENCHMARK

BM 50300: 3.5" DISC USGS 5300, 30' +/- SOUTH OF INTERSECTION OF SUNSET ROAD AND VALLEY CENTER ROAD.

ELEVATION = 1500.99 DATUM: NAVD83

SITE ADDRESS:

29471 COLE GRADE ROAD
VALLEY CENTER, CA 92082

EXISTING EASEMENTS*

DESCRIPTION	DISPOSITION
(1) PUBLIC ROAD	TO REMAIN
(2) PUBLIC ROAD	TO REMAIN
(3) SOME PUBLIC UTILITIES	TO REMAIN
(4) SOME PUBLIC UTILITIES	TO REMAIN
(5) WATER PIPE	TO REMAIN
(6) SOME PUBLIC UTILITIES	TO BE RELOCATED
(7) SOME PUBLIC UTILITIES	TO REMAIN
(8) SOME PUBLIC UTILITIES	TO REMAIN

*INDICATES EXCEPTION NUMBER IN LAWYERS TITLE COMPANY PRELIMINARY REPORT ORDER NUMBERS 7607703 & 613672391, DATED OCTOBER 22, 2012 AND JUNE 25, 2013, RESPECTIVELY, WHICH WAS USED IN THE PREPARATION OF THIS SURVEY. ITEMS LISTED AS "A#" ARE TIED TO 7607703. ITEMS LISTED AS "B#" ARE TIED TO 613672391.

PROPOSED EASEMENT

DESCRIPTION
(1) AGRICULTURAL EASEMENT

LEGEND:


PROPERTY BOUNDARY	---
EXISTING EASEMENT	---
100' RIGHT-OF-WAY	---
MUP BOUNDARY (25.0 AC)	---
SETBACK LINE	---
PROPOSED 7' CHAINLINK FENCE W/ SLATS (8" MAX.)	---
PROPOSED ACCESS GATE	---
EXISTING PAVEMENT	---
PROPOSED PAVEMENT	---
PROPOSED FIRE ACCESS ROAD-ALL WEATHER (WIDTH PER PLAN)	---
EXISTING OVERHEAD POWERLINE	---
EXISTING POWER POLE	---
PROPOSED UNDERGROUND INTERCONNECTION	---
PROPOSED PV PANEL	---
PROPOSED INVERTER/TRANSFORMER PAD (2)	---
30' FUEL MODIFICATION ZONE UNLESS OTHERWISE NOTED	---
RELINQUISHMENT OF ACCESS RIGHTS	---
AGRICULTURAL MITIGATION (5.6 AC)	---
FIRE DEPARTMENT TURN AROUND (SEE SHEET 2) ALL WEATHER PAVING	---
VIDEO CAMERA ON 10' POLE (6)	---
PRIVATE DRIVEWAY ACCESS-ALL WEATHER	---
100-YEAR INUNDATION LIMITS	---

SHEET INDEX

SHEET 1 - TITLE SHEET/PLOT PLAN
SHEET 2 - ELEVATIONS/DETAILS
SHEET 3 - LANDSCAPE PLAN


OWNER/APPLICANT:

NLP VALLEY CENTER SOLAR, LLC
17601 VON KARMAN AVENUE, SUITE 1050
IRVINE, CA 92614
CONTACT: PATRICK BROWN
PHONE: (619) 733-2649



NOTES

- 1. GROSS AREA: 66.7 ACRES
- 2. NET AREA: 65.6 ACRES (COLE GRADE ROAD EASEMENT & 47' ULTIMATE R/W = 1.1 AC)
- 3. MAP BOUNDARY AREA: 25.3 ACRES
- 4. TOPOGRAPHIC SOURCE: AEROTECH MAPPING INC, 6/18/2013
- 5. THIS PLAN IS PROVIDED TO ALLOW FOR FULL AND ADEQUATE DISCRETIONARY REVIEW OF A PROPOSED DEVELOPMENT PROJECT. THE PROPERTY OWNER ACKNOWLEDGES THAT ACCEPTANCE OR APPROVAL OF THIS PLAN DOES NOT CONSTITUTE AN APPROVAL TO PERFORM ANY GRADING SHOWN HEREON, AND AGREES TO OBTAIN VALID GRADING PERMITS BEFORE COMMENCING SUCH ACTIVITY.
- 6. ALL DISTURBED AREAS WILL BE SURFACED WITH GRAVEL OR A BINDING AGENT TO REDUCE DUST.
- 7. PILE DRIVING OPERATIONS: IN ORDER TO LIMIT TEMPORARY CONSTRUCTION NOISE, ALL PILE DRIVING OPERATIONS SHALL BE LOCATED A MINIMUM SETBACK OF 215 FEET FROM ANY OCCUPIED RESIDENTIAL PROPERTY LINE. IF PILE DRIVING OPERATIONS ARE TO OCCUR WITHIN 215 FEET, THEN THESE OPERATIONS SHALL LIMITED TO OPERATE 25% OF THE HOURLY OR DAILY DURATION.



POSTS (PV & FENCE): 0.03 AC PRIME
EQUIPMENT PADS: 0.07 AC
FIRE ACCESS ROAD: 2.30 AC
GRADED AREAS: 3.44 AC
TOTAL: 5.84 AC
AGRICULTURAL LANDS IMPACTS
SCALE: 1"=400'

TOPOGRAPHY AND GRADING

VOLUME OF CUT/FILL: 6,000 CY
EXPORT/IMPORT: 0 CY
MAXIMUM SITE RETAINING WALL HEIGHT: N/A
TOTAL DISTURBED AREA BEFORE PROJECT: 2.2 AC
TOTAL DISTURBED AREA AFTER PROJECT: 19.6 AC
TOTAL IMPERVIOUS AREA BEFORE PROJECT: 0.10 AC
TOTAL IMPERVIOUS AREA AFTER PROJECT: 0.30 AC

IMPERVIOUS SURFACES TABLE

ITEM DESCRIPTION	TOTAL AREA	UNIT
INVERTER / TRANSFORMER PAD	0.04	AC
FOOTING FOUNDATION	0.16	AC
TOTAL	0.20	AC


EXISTING EASEMENTS*

DESCRIPTION	DISPOSITION
1. PUBLIC ROAD	TO REMAIN
2. PUBLIC ROAD	TO REMAIN
3. SDG&E PUBLIC UTILITIES	TO REMAIN
4. SDG&E PUBLIC UTILITIES	TO REMAIN
5. WATER PIPE	TO REMAIN
6. SDG&E PUBLIC UTILITIES	TO BE RELOCATED
7. SDG&E PUBLIC UTILITIES	TO REMAIN
8. SDG&E PUBLIC UTILITIES	TO REMAIN

*INDICATES EXCEPTION NUMBER IN LAWYERS TITLE COMPANY PRELIMINARY REPORT ORDER NUMBERS 7607703 & 613672391, DATED OCTOBER 22, 2012 AND JUNE 25, 2013, RESPECTIVELY, WHICH WAS USED IN THE PREPARATION OF THIS SURVEY. ITEMS LISTED AS "A#" ARE TIED TO 7607703. ITEMS LISTED AS "B#" ARE TIED TO 613672391.

PROPOSED EASEMENT

DESCRIPTION
1. AGRICULTURAL EASEMENT



- LEGEND:
- PROPERTY BOUNDARY
 - EXISTING EASEMENT
 - 100' RIGHT-OF-WAY
 - MAP BOUNDARY (26.0 AC)
 - EXISTING CONTOUR
 - PROPOSED GRADING
 - PROPOSED DAYLIGHT LINE
 - PROPOSED SPOT GRADE
 - PROPOSED PAD ELEVATION
 - PROPOSED 7" CHAINLINK FENCE W/ SLATS (8' MAX.)
 - PROPOSED ACCESS GATE
 - DIRECTION OF FLOW / SLOPE
 - EXISTING DIRT ROAD
 - EXISTING PAVEMENT
 - PROPOSED PAVEMENT
 - PROPOSED FIRE ACCESS ROAD-ALL WEATHER (WIDTH PER PLAN)
 - EXISTING BUILDING
 - EXISTING POWER POLE
 - EXISTING WATER WELL
 - PROPOSED PV PANEL
 - PROPOSED INVERTER/TRANSFORMER PAD (2)
 - 100-YEAR INUNDATION LIMITS
 - EXISTING CULVERT
 - RELINQUISHMENT OF ACCESS RIGHTS
 - EXISTING TREES
 - PRIVATE DRIVEWAY ACCESS-ALL WEATHER
 - BMP (SEE MINOR SWP)

ASSESSOR PARCEL NUMBER

188-120-09 & 10

LEGAL DESCRIPTION

ALL THOSE PORTIONS OF THE EAST HALF OF SECTION 6, TOWNSHIP 11 SOUTH, RANGE 1 WEST, SAN BERNARDINO BASE AND MERIDIAN, IN THE COUNTY OF SAN DIEGO, STATE OF CALIFORNIA, ACCORDING TO THE OFFICIAL PLAT THEREOF, AS DESCRIBED IN DEEDS RECORDED APRIL 1, 1985 AS INSTRUMENT NO. 85-124116, AND SEPTEMBER 24, 1990 AS INSTRUMENT NO. 90-521370, JANUARY 4, 1991 AS INSTRUMENT NO. 91-0004366, ALL OF OFFICIAL RECORDS.

BASIS OF BEARINGS

THE BASIS OF BEARINGS FOR THIS SURVEY IS THE CALIFORNIA COORDINATE SYSTEM OF 1983 (CCS83, EPOCH 2011.00), ZONE 6, BASED LOCALLY UPON CONTROL STATIONS P478 & P480, PUBLISHED BY THE CALIFORNIA SPATIAL REFERENCE CENTER (CSRC) WITH A BEARING OF N78°55'32"W.

BENCHMARK


BM 50300, 3.5" DISC USGS S300, 30' +/- SOUTH OF INTERSECTION OF SUNSET ROAD AND VALLEY CENTER ROAD.
ELEVATION = 1500.99 DATUM: NAVD29

SITE ADDRESS:

29471 COLE GRADE ROAD
VALLEY CENTER, CA 92082

OWNER/APPLICANT:

NLP VALLEY CENTER SOLAR, LLC
17901 VON KARMAN AVENUE, SUITE 1050
IRVINE, CA 92614
CONTACT: PATRICK BROWN
PHONE: (619) 733-2649



NOTES



- 1. ALL LANDSCAPE IMPROVEMENTS SHALL BE DESIGNED IN ACCORDANCE WITH COUNTY OF SAN DIEGO LANDSCAPE STANDARDS, VALLEY CENTER DESIGN GUIDELINES AND IN ACCORDANCE WITH AS 10M - STATE WATER CONSERVATION REQUIREMENTS.
- 2. NATIVE AND DROUGHT TOLERANT PLANTS THAT MINIMIZE WATER USE AND MAINTENANCE WILL BE UTILIZED. ALL PLANT MATERIALS WILL BE APPROPRIATE FOR THE SAN DIEGO CLIMATE AND FIT IN WITH THE ADJACENT NEIGHBORHOOD.
- 3. ALL LANDSCAPED AREAS SHALL BE IRRIGATED WITH AUTOMATIC DRIP IRRIGATION SYSTEM. IRRIGATION WATER TO BE PROVIDED VIA EXISTING DOMESTIC WATER METER.
- 4. WITHIN THE MAJOR USED PERMIT AREA, OWNER SHALL BE RESPONSIBLE FOR MAINTAINING THE LANDSCAPE SCREENING, FOR THE LIFE OF THE PERMIT, INCLUDING EXISTING VEGETATION AT THE CORNER OF VIA VALENCIA AND COLE GRADE ROAD, ALONG COLE GRADE ROAD FROM THE INTERSECTION OF MILCO LANE SOUTH TO THE UNNAMED ROAD AND THE INTERSECTION OF COLE GRADE ROAD AND THE UNNAMED ROAD PARALLELING MILCO LANE DURING THE LIFE OF THE PERMIT. ALL DEAD, DYING, OR DISEASED PLANTS WILL BE REPLACED IN KIND.
- 5. WITHIN THE MAJOR USED PERMIT AREA, EXISTING CITRUS TREES TO BE REMOVED UNLESS OTHERWISE NOTED.
- 6. WITHIN THE MAJOR USED PERMIT AREA, EXISTING CITRUS TREES WILL BE WATERED VIA ON SITE DOMESTIC WATER SUPPLY AND MAINTAINED BY THE PROJECT OWNER.
- 7. PLASTIC SLATS SHALL BE REPLACED IF DAMAGED DURING THE LIFE OF THE PERMIT.

LANDSCAPE ZONES


- PROTECT IN PLACE AND MAINTAIN EXISTING CITRUS TREES / GROVE
- LANDSCAPE IMPROVEMENTS - SEE SECTIONS AT LEFT

PLANT LEGEND

TREES	BOTANICAL NAME / COMMON NAME	SIZE	SPACING	WATER USE
	CERODENDRUM FLORIDUM / BLUE PALM VERDE	24" BOX	25' AVERAGE	L
	CUPRESSUS FORBESII / TECATE CYPRESS	24" BOX	25' AVERAGE	L
	OLEA EUROPAEA / OLIVE	24" BOX	25' AVERAGE	M
	PLATANUS RACEMOSA / CALIFORNIA SYCAMORE	24" BOX	25' AVERAGE	M
	QUERCUS AGRIFOLIA / COAST LIVE OAK	36" BOX	25' AVERAGE	L
	QUERCUS CHRYSOLEPS / CANYON LIVE OAK	36" BOX	25' AVERAGE	L
	QUERCUS ENGELMANNI / ENGELMAN OAK	36" BOX	25' AVERAGE	L
	UMBELLULARIA CALIFORNICA / CALIFORNIA BAY LAUREL	24" BOX	25' AVERAGE	M
SHRUBS	BOTANICAL NAME / COMMON NAME	SIZE	SPACING	WATER USE
	ATRIPLEX LENTIFORMIS SPP. BREWERI / QUAIL BUSH	1 & 5 GALLON	VARIES 6'-8"	L
	GALVEZIA SPECIOSA / ISLAND BUSH SNAPDRAGON	1 & 5 GALLON	VARIES 4'-10"	L
	HETEROMELES ARBUTIFOLIA / TOYON	5 & 15 GALLON	VARIES 6'-10"	L
	RHUS OVATA / SUGAR BUSH	5 & 15 GALLON	VARIES 6'-10"	L
	RHAMNUS CALIFORNICA / COFFEE BERRY	1 & 5 GALLON	VARIES 6'-10"	L
	RHUS LAURINA / LAUREL SUMAC	1 & 5 GALLON	VARIES 6'-10"	L
	ROMNEYA COULTERI / MATILDA POPPY	1 & 5 GALLON	VARIES 6'-10"	L
	SALVIA CLEVELANDII / CLEVELAND SAGE	1 & 5 GALLON	VARIES 4'-8"	L
GROUND COVERS	BOTANICAL NAME / COMMON NAME	SIZE	SPACING	WATER USE
	BACCHARIS PILULARIS - COYOTE BRUSH	1 GALLON	6'	L
	CEANOETHUS GRISEUS HORIZONTALIS - CARMEL CREEPER	1 GALLON	8'	L
	IVA HAYESIANA - POVERTY WEED	1 GALLON	6'	L
	MUELENBERGIA RIGENS - DEER GRASS	1 GALLON	6'	M



SCHEMATIC LANDSCAPE PLAN



PROJECT FACILITY AVAILABILITY FORM

FIRE

Please type or use pen

NLP Valley Center Solar LLC; c/o 949-300-4365
Stephen Joslin
Owner's Name Phone
83 S. King Street, Suite #200
Owner's Mailing Address Street
Seattle WA 98104
City State Zip

ORG _____
ACCT _____
ACT _____
TASK _____
DATE _____ AMT \$ _____

DISTRICT CASHIER'S USE ONLY

SECTION 1. PROJECT DESCRIPTION

TO BE COMPLETED BY APPLICANT

- A. ☐ Major Subdivision (TM) ☐ Specific Plan or Specific Plan Amendment
☐ Minor Subdivision (TPM) ☐ Certificate of Compliance: _____
☐ Boundary Adjustment
☐ Rezone (reclassification) from _____ to _____ zone
☒ Major Use Permit (MUP), purpose: PV Solar Farm
☐ Time Extension ... Case No. _____
☐ Expired Map ... Case No. _____
☐ Other _____
- B. ☐ Residential Total number of dwelling units _____
☐ Commercial Gross floor area _____
☐ Industrial Gross floor area _____
☒ Other Gross floor area n/a
- C. Total Project acreage 78.6 (gross) Total lots n/a
Smallest proposed lot. n/a

Assessor's Parcel Number(s)
(Add extra if necessary)

1	8	8	1	2	0	0	9
1	8	8	1	2	0	1	0
1	8	8	1	2	0	1	2

Thomas Bros. Page 1070 Grid F6, G6

Project address 29471 Cole Grade Road

Valley Center 92082
Community Planning Area/Subregion Zip

OWNER/APPLICANT AGREES TO COMPLETE ALL CONDITIONS REQUIRED BY THE DISTRICT.

Applicant's Signature: _____ Date: 9/26/2013

Address: RBF Consulting, 9755 Clairemont Mesa Blvd, Suite 100 San Diego, CA 92124 Phone: 858-614-5000
(On completion of above, present to the district that provides fire protection to complete Sections 2 and 3 below.)

SECTION 2. FACILITY AVAILABILITY

TO BE COMPLETED BY DISTRICT

District name: VALLEY CENTER Fire Protection District
Indicate the location and distance of the primary fire station that will serve the proposed project: STATION 72 at 28234 LILAC Road

- A. ☒ Project is in the District and eligible for service.
☐ Project is not in the district but is within its Sphere of Influence boundary, owner must apply for annexation.
☐ Project is not in the district and is not within its Sphere of Influence boundary.
☐ Project is not located entirely within the district and a potential boundary issue exists with the _____ District.
- B. ☐ Based on the capacity and capability of the District's existing and planned facilities, fire protection facilities are currently adequate or will be adequate to serve the proposed project. The expected emergency travel time to the proposed project is _____ minutes.
- C. ☒ Fire protection facilities are not expected to be adequate to serve the proposed development within the next five years.
☐ District conditions are attached. Number of sheets attached: MUST= _____
☒ District will submit conditions at a later date.

SECTION 3. FUELBREAK REQUIREMENTS

CFD 2008-01 prior to approval of the Final Map

Note: The fuelbreak requirements prescribed by the fire district for the proposed project do not authorize any clearing prior to project approval by the Department of Planning and Land Use.

- ☐ Within the proposed project _____ feet of clearing will be required around all structures.
☐ The proposed project is located in a hazardous wildland fire area, and additional fuelbreak requirements may apply. Environmental mitigation requirements should be coordinated with the fire district to ensure that these requirements will not pose fire hazards.

This Project Facility Availability Form is valid until final discretionary action is taken pursuant to the application for the proposed project or until it is withdrawn, unless a shorter expiration date is otherwise noted.

Authorized Signature: _____ Print name and title: George E. Lucia Phone: 760-644-9933 Date: 10-4-13

On completion of Sections 2 and 3 by the District, applicant is to submit this form with application to:
Zoning Counter, Department of Planning and Land Use, 5201 Ruffin Road, Suite B, San Diego, CA 92123



COUNTY OF SAN DIEGO, PLANNING & DEVELOPMENT SERVICES
REQUEST FOR AGENCY RECOMMENDATIONS
ZONING DIVISION

Date: 06-25-15

Assessor's
Parcel Number: 188-120-09 & 188-120-10

RECORD ID(s): PDS2013-MUP-13-019

Requested
Response Date: 07-17-15

Project
Location: 29471 Cole Grade Rd. Valley Center CA, 92082

Attached to this transmittal is a project that was recently submitted to Planning & Development Services (PDS). PDS is requesting an agency review and comment on the development application (RECORD ID) entered above. Please return this form and any written comments to PDS Project Processing Support Services (address below) within 20 days as indicated by the response date entered above. If there are any questions regarding this application or in completing this form, please contact PDS Project Processing Support Services at (858) 694-3292.

*Please include the **RECORD ID(s)** on all correspondence*

FOR SPECIAL DISTRICTS

FIRE DISTRICT
WATER AGENCY
SEWER AGENCY
SCHOOL DISTRICT

FIRE MARSHAL
Valley Center Fire Protection District
28234 Lilac Road
Valley Center, California 92082
(760) 754-7600

Please review the proposal and provide this department with any additional information or conditions to be considered in project review.

ACCEPTED
JULY 01, 2015 *Wec*

FOR COUNTY TAX COLLECTOR

Is the parcel delinquent?: Yes No (circle one)
Signature & date:

FOR COUNTY DEPARTMENTS

ANIMAL SERVICES
AGRICULTURE
DEH

LIBRARY
PARKS & RECREATION
SHERIFF

Please review the project proposal and provide written comment of departmental concerns to be considered during discretionary review.

FOR OTHER GOVERNMENTAL AGENCIES

INCORPORATED CITY
DEPT. OF FISH AND GAME
STATE AND FEDERAL FORESTRY
STATE DEPT. OF HEALTH
AND EDUCATION

APCD
CALTRANS
LAFCO
SANDAG
RWQCB

This project may be in or adjacent to an area of concern to your jurisdiction. Please review the enclosed information and provide written comment as appropriate.

FOR PRIVATE UTILITY AND ENVIRONMENTAL GROUPS

Please review the enclosed information and provide written comment of concerns to be considered during discretionary review.

Please email all agency recommendations to: CommunityGroups.LUEG@sdcounty.ca.gov



PDS-521A Rev. 09/21/2012



VALLEY CENTER FIRE PROTECTION DISTRICT

Administrative Office & Fire Prevention Bureau

28234 Lilac Road

Valley Center, CA 92082

Tel: 760-751-7600

Fax: 760-749-3892

Wednesday, July 01, 2015

County of San Diego
Planning & Development Services
5510 Overland Avenue
Suite 110
San Diego, CA 92123

Subject: Request for Agency Recommendations
NLP Valley Center Solar LLC, Photovoltaic Solar System (commercial)
PDS2013-MUP-13-019
29471 Cole Grade Road / 188-120-09-00 & 188-120-10-00
Valley Center Fire Protection District (VCFPD)

Gentlemen:

The following are the Valley Center Fire Protection District Fire Marshal's comments regarding the subject project, based on the current information available to us at this preliminary project stage. Fire conditions may change and be clarified as more detailed plans are received.

PROJECT DESCRIPTION

This proposed photovoltaic solar system project is ground mounted within 25 acres of the 66 acre site.

The system will be PV solar panels mounted on a single-axis tracking system.

The project is located in designated Wildland Urban Interface, State Responsibility Area, and "Very High" Fire Severity Zone (the highest category.)

Note: setbacks are 30 feet in the very high zone.

The County Consolidated Fire Code and Valley Center Fire Protection District Fire Code apply. The State Board of Forestry and Fire Protection certified the current San Diego County Consolidated Fire and Building Codes as a package as meeting the CCR Title 14 requirements, and authorizing its use in lieu of Title 14. The County, as land planning authority, is obligated to enforce it. Because the project is in State Responsibility Area, minimum County Consolidated Fire Code requirements must be applied in addition to Valley Center Fire Protection District Fire Code.

GENERAL PLAN CONFORMANCE

PDS2013-MUP-13-0-19; PDS2013-ER-02-002

Fire Station # 1
28234 Lilac Road
Valley Center, CA 92082

Fire Station # 2
28205 N. Lake Wohlford Road
Valley Center, CA 92082

FIRE JURISDICTION

The subject property is within the Valley Center Fire Protection District, which provides structural, wildland fire protection, and emergency medical services on a year around basis. Wildland fire protection is provided by the California Department of Forestry and Fire Protection (CAL FIRE).

TRAVEL TIME. (VCFPD Ordinance No: 2014-44 Fire Code section 202)

The estimated time it would take for a responding agency to travel from the fire station to the furthest structure in this proposed development project, determined by measuring the safest, most direct, appropriate and reliable route with consideration given to safe operating speeds for heavy fire apparatus.

The most remote portions of this project are located approximately 2.7 miles from Valley Center Fire Protection District's Station #1 located at 28234 Lilac Road, with an emergency travel time of about 6 minutes when calculated by Table C.1.11 (b) NFPA 1142.

IMPACT (VCFPD Ordinance: CFD-2008-01)

This and other projects will have a cumulative impact on the availability of fire services. The level of fire service availability will, if not mitigated, decline. Mitigation is required in the form of participation in a Community Facility District or similar approved mechanism to generate adequate funding for emergency and prevention services in perpetuity. See CFD-2008-01 Valley Center Fire Protection District Requirements. Additional impacts, such as access, fuel (vegetation) modification and water supply, are identified below.

Note, Project Facility Availability status is "fire protection facilities are not expected to be adequate to serve the proposed development within the next five years" until the CFD-2008-01 is perfected.

FIRE ACCESS ROADWAYS - Road design

(County Consolidated Fire Code / VCFPD Ordinance No: 2014-44)

On-site fire access roadways are required around and from arrays and components to a public way. The fire access roadway shall be extended to within 150 feet of acceptable fire fighter hose line access to all ground level exterior portions of any arrays and components. Fire apparatus access roadways in residential and commercial areas shall have an unobstructed, improved width of not less than 24 feet all-weather paved, designed and maintained to support the imposed load of fire apparatus (not less than 75,000 lbs. GVW.). Fire apparatus access roads shall be provided and maintained for purposes of rapid and reliable fire apparatus access and for unobstructed traffic circulation for evacuation or relocation of civilians during an emergency event. Ground-mounted photovoltaic arrays 10 acres or larger in size shall provide a fire apparatus access roadway around the perimeter of the project. The perimeter fire apparatus access roadway shall comply with section 503.

EMERGENCY KEY ACCESS

All central station-monitored fire detection systems and fire sprinkler systems shall have an approved emergency key access box on site in an approved location. The owner or occupant shall provide and maintain current keys for any structure for fire department placement in the box and shall notify the fire department in writing when the building is re-keyed. (Sec. 506.1.3).

IDENTIFICATION

Ground-mounted photovoltaic arrays with multiple equipment structures shall include a means of readily identifying each equipment structure. The fire code official may require a lighted directory map of the project to be installed on-site near the entrance to the facility for projects of 10 or more acres in size.

TRAFFIC CALMING DEVICES

Traffic calming devices (including, but not limited to, speed bumps, speed humps, speed control dips, etc.) shall be prohibited unless approved by the fire code official. (Sec. 503.4.1)

MARKINGS

When required by the fire code official, approved signs or other approved notices shall be provided for fire apparatus access roads to identify such roads or prohibit the obstruction thereof. Signs or notices shall be maintained in a clean and legible condition at all times and will be replaced or repaired when necessary to provide adequate visibility. All new public roads, all private roads within major subdivisions and all private road easements serving four or more parcels shall be named. Road name signs shall comply with County of San Diego Department of Public Works Design Standard #DS-13. (Sec. 503.3).

FIRE PROTECTION PLAN

(County Consolidated Fire Code / VCFPD Ordinance No: 2014-44

FIRE CODE SECTION 4903 / FIRE PROTECTION PLAN

When required. Planning and Development Services or the FAHJ may require an applicant for a parcel map, subdivision map, specific plan or major use permit for any property located in a wildland-urban interface fire area to submit a Fire Protection Plan (FPP) as part of the approval process. (Sec. 4903.1).

Content. The FPP shall consider location, topography, geology, aspect, combustible vegetation (fuel types), climatic conditions and fire history. The plan shall address the following in terms of compliance with applicable codes and regulations including but not limited to: water supply, vehicular and emergency apparatus access, travel time to nearest serving fire station, structural ignitability, structure set back, ignition-resistive building features, fire protection systems and equipment, impacts to existing emergency services, defensible space and vegetation management.

The FPP shall be prepared as prescribed in the County of San Diego Land Use and Environment Group "Guidelines for Determining Significance and Report Format and Content Requirements for Wildland Fire and Fire Protection" document. (Sec. 4903.2).

A Fire Protection Plan (FPP), (Long Format) submitted to and approved by the VCFPD Fire Marshal, is required. It must meet VCFPD Guidelines for Determining Significance and Report Format and Content

SECURITY GATES

No person shall install a security gate or security device across a fire access roadway without the fire code official's approval.

- An automatic gate across a fire access roadway or driveway shall be equipped with an approved emergency key-operated switch overriding all command functions and opening the gate.
- A gate accessing hazardous institutional, educational or assembly occupancy group structure, shall also be equipped with an approved emergency traffic control-activating strobe light sensor or other device approved by the fire code official, which will activate the gate on the approach of emergency apparatus.
- An automatic gate shall be provided with a battery back-up or manual mechanical disconnect in case of power failure.
- An automatic gate shall meet fire department policies deemed necessary by the fire code official for rapid, reliable access.
- When required by the fire code official, an automatic gate in existence at the time of adoption of this chapter is required to install an approved emergency key-operated switch or other mechanism approved by the fire code official, at an approved location, which overrides all command functions and opens the gate. A property owner shall comply with this requirement within 90 days of receiving written notice to comply.
- Where this section requires an approved key-operated switch, it may be dual-keyed or equipped with dual switches provided to facilitate access by law enforcement personnel.
- All gates providing access from a road to a driveway shall be located a minimum of 30 feet from the nearest edge of the roadway and shall be at least two feet wider than the width of the traffic lane(s) serving the gate.
- Electric gate openers, where provided, shall be listed in accordance with UL 325. Gates intended for automatic operation shall be designed, constructed and installed to comply with the requirements of ASTM F2200. (Sec. 503.6).

BRIDGES AND ELEVATED SURFACES

(County Consolidated Fire Code / VCFPD Ordinance No: 2014-44)

Where a bridge or an elevated surface is part of a fire apparatus access road, the bridge shall be constructed and maintained in accordance with AASHTO HB-17. Bridges and elevated surfaces shall be designed for a live load sufficient to carry the imposed loads of fire apparatus. Vehicle load limits and clearance limitations shall be posted at both entrances to bridges when required by the fire code official. Where elevated surfaces designed for emergency vehicle use are adjacent to surfaces which are not designed for such use, approved barriers, approved signs or both shall be installed and maintained when required by the fire code official

RESPONSE MAP UPDATES

Any new development which necessitates updating emergency response maps due to new structures, hydrants, roadways or similar features shall be required to provide map updates in a format compatible with current department mapping services and shall be charged a reasonable fee for updating all response maps. At a minimum, the map updates shall be provided in PDF or a CAD format approved by the FAHJ. (Sec. 505.5)

FIRE FLOW – water supply

(County Consolidated Fire Code / VCFPD Ordinance No: 2014-44)

Provide on-site fire hydrants every 300 feet. Locations shall be approved by the Valley Center FPD Fire Marshal. In hazardous fire areas the required fire flow in the water mains is 2,500 gallons per minute. Fire Hydrants shall meet County standards identified in the Consolidated Fire Code. Waterline extension will be required for purposes of hydrant installation.

(Required if the property is within a water district and a water main is 1500 feet or less from the property line.) Waterlines must be installed, and hydrants accepted by the water district and capable of full required fire flow prior to combustible materials being brought to the construction site. Water lines, fire hydrants, durable all weather fire access must be in place prior to combustible materials being on site.

FUEL MODIFICATION


(County Consolidated Fire Code / VCFPD Ordinance No: 2014-44)

Any person doing construction of any kind which requires a permit under this code or the County Building Code shall install a fuel modification zone prior to allowing any combustible material to arrive on the site and shall maintain the zone during the duration of the project. Combustible vegetation within the array and to a distance of 30 feet from the array and associated equipment shall be reduced to a height of no more than 6 inches. The fuel modification zone may be increased when required by the fire code official or as recommend by a fire protection plan.

FIRE SAFETY PRECAUTIONS BEFORE AND DURING CONSTRUCTION

During the ownership transition and permit process, this property may fall into an unsafe condition from lack of maintenance. The VCFPD Fire Code and Vegetation Compliance program has proven effective in mitigating the spread of fires and has played a part in keeping the destruction from these fires to a minimum. Please ensure this property meets all fire safety requirements at all times prior to grading and during construction. Doing so will reduce the loss of life and property from fire. VCFPD requires the property owner to monitor and reduce the combustible fuel load on this property and at all property line areas as specified by Valley Center Fire Protection District Ordinance 2008-35 also known as the California Urban-Wildland Interface Code regulating and governing the mitigation of hazards to life and property from the intrusion of fire from wildland exposures, fire from adjacent structures, and prevention of structure fires spreading to wild land fuels in the Valley Center Fire Protection District.

Yours in Safety,



George E. Lucia Sr.
Battalion Chief / Fire Marshal
Valley Center Fire Protection District

FIRE MARSHAL

Valley Center Fire Protection District
28234 Lilac Road
Valley Center, California 92082
(760) 754-7000

Appendix A

Wildfire Technical Report

APPENDIX A:

WILDFIRE TECHNICAL REPORT

Table of Contents

- 1 Introduction1
 - A. Project Effects on Potential Fire Risk1
 - B. Hazards to Emergency Responders2
 - C. Protection of the Project Site from OffSite Wildland Fire Exposure2
- 2. FIRE OPERATIONS AND TACTICS FOR SOLAR SYSTEMS3
 - A. Strategy.....3
 - B. Tactics4
 - Firefighter Electrical Safety – Incident Plan4
 - Trip, Slip or Fall Hazards8
 - Firefighter Inhalation Hazards8
 - Battery Hazards8
- 3. SUMMARY.....9
- REFERENCES.....10

1 INTRODUCTION

This Fire Protection Plan (FPP) identifies and prioritizes the measures necessary to adequately mitigate potential fire hazards associated with photovoltaic (PV) solar energy generating facilities. It considers the property location, topography, geology, flammable vegetation (fuel types), and climatic conditions. It also considers the water supply, fire access roads, setbacks from the property lines, structure ignitability and fire resistive building materials, fire protection systems, defensible space, and vegetation management.

The NorthLight Power (NLP) Valley Center, LLC Solar Project proposes the use of photovoltaic (PV) technology for the production of solar energy. The FPP – Wildfire Technical Report has been prepared to identify pre-suppression actions that would reduce risk directly associated with the proposed PV solar facilities, actions that would protect and enhance fire suppression resources, and actions that could protect the development from ignition caused by other sources.

In addition to the historical challenges that firefighters are faced with when arriving at a fire event, solar energy systems introduce new hazards including electrical shock both during and post fire incident, as well as concerns associated with the inhalation of unusual materials. These new hazards require that firefighters are able to adapt to new firefighting procedures, strategies, and tactics.

This report outlines the potential hazards associated with the proposed systems, strategies, and tactics, and provides an overall incident plan for use by emergency responders. In addition, as recommended by the California Department of Forestry and Fire Protection (CAL FIRE), this report provides a basic framework advancing the knowledge and understanding for the emergency responders of the hazards and related implementation measures to reduce the potential for fire events to occur.

A. PROJECT EFFECTS ON POTENTIAL FIRE RISK

The installation, operation, and maintenance of a PV solar facility would include activities that could elevate the probability of ignition. Typical fire risk associated with electricity-generating projects, such as solar facilities, include the following:

1. Transmission lines directly contacting vegetation that could cause an ignition.
2. Maintenance equipment and activities associated with the solar energy system or vegetation clearing along the transmission lines that could result in an ignition.
3. Vehicles used for operation of the solar energy system that could result in an ignition (catalytic converter, faulty brakes, etc.).

4. Malfunction of components of the solar energy system, resulting in an ignition.

B. HAZARDS TO EMERGENCY RESPONDERS

This report has been prepared to identify the specific hazards to emergency responders and firefighters as related to the installation, operation, and maintenance of a PV solar facility. These hazards include the following:

1. Contact with the system components (including any conduit or components between the modules and disconnect/isolation switches).
2. During daylight hours, the panels in such a solar system are always producing energy, or are energized.
3. Incidences involving solar energy generating systems are unique in that components may remain energized within the system components, even after all power has been de-energized.
4. Depending on the level of damage to the solar energy system, the connection to "ground" may have been lost.
5. Electrical conductive tools create a hazard of electrical shock as the system may still be energized.
6. Burning of PV solar modules produces toxic vapors.
7. The inverters and combiner boxes are protected within the inverter structures and present hazardous conditions for emergency responders. The inverters convert the Direct Current (DC) produced by the solar units into Alternating Current (AC), which would be transferred from the inverters via underground gathering lines that ultimately connect to a utility pole. The power would then be transferred via overhead lines to the point of interconnect (POI). Depending on the design and manufacturer, these components could be located at various locations on the inverter structure.
8. Inadequate signage for emergency responders to enable location of the inverters, emergency access routes, and/or other essential controls.

C. PROTECTION OF THE PROJECT SITE FROM OFFSITE WILDLAND FIRE EXPOSURE

If a solar energy generation facility is identified as being located within a very high fire hazard severity zone, the project would need to be designed to provide fuel modification zones (FMZs), fire breaks, and/or separation from onsite or adjacent offsite vegetation.

Implementation of these design measures would reduce the risk of exposure resulting from wildland fires. In addition, vegetation within the solar array area should be maintained at a height of six inches or less to reduce the potential for wildfire to occur and/or provide fuel for the spread of wildfire. Lastly, setbacks should be designed to further reduce the potential from exposure to wildland fire occurring on offsite lands.

2. FIRE OPERATIONS AND TACTICS FOR SOLAR SYSTEMS

Following a size-up (visual assessment of site conditions) of a fire incident, the choice of a strategic mode should be made by the Incident Commander (IC) following normal fire department standard operating procedures (SOPs). The tactics used to implement the strategy should also be based upon normal SOPs for responding to an emergency incident for a solar energy generating facility.

A. STRATEGY

When a fire incident occurs in the vicinity of or within the boundaries of a solar field, CALFIRE requires that the following items be considered when developing a strategy:

1. Fire conditions found on arrival;
2. Whether the solar field itself is burning or if fire is confined to the surrounding vegetation;
3. Threatened exposures, including wildland areas; and,
4. Water and additional resources available.

Once the IC has completed a size-up, he/she should determine the strategy and assign tasks to the fire suppression resources assigned to the incident. Due to the hazards associated with solar energy generating facilities, the IC must adjust the strategy and potentially rearrange the order of the tactics to deal with the specific solar technology. If the IC chooses an offensive strategy, it needs to be supported as any other fire operation, with an emphasis on disabling all power sources to and from the solar energy generating facility.¹

¹ Fire Operations for Photovoltaic Emergencies. CAL FIRE - Office of the State Fire Marshal. November 2010.

B. TACTICS

With the increase in fire emergency responders to solar system emergencies, firefighters need to understand the hazards and related factors necessary for fire operations involving PV solar sites. CALFIRE encourages all emergency responders to be trained for the following:

- Ability to recognize solar energy generating systems
- Ability to identify system locations
- Ability to identify hazards with solar energy generating systems
- Ability to perform size-up
- Have knowledge of strategies and tactics

Operating at incidents where solar energy generating systems are present may require firefighters to adjust their actions somewhat; however, these adjustments should be similar to those that are necessary with many other types of electrical equipment or power generating sources.

The primary danger to firefighters working around a solar energy generating system is electrical shock. Following are the hazards and recommendations for firefighting tactics for a fire incident at a solar energy generation facility.

FIREFIGHTER ELECTRICAL SAFETY – INCIDENT PLAN

“Components are always hot!”

The single most critical message of emergency response personnel is to always consider PV fields and all of their components as electrically energized. The inability to power-down solar panels exposed to sunlight makes this an obvious hazard during the daytime.² All hazards should be appropriately marked or barricaded.

Ingress and Egress

Long-term primary access to the site would occur from Cole Grade Road. No offsite roadway improvements are required, other than widening of Cole Grade Road 24 feet in width at the Project entrance drive and constructing a driveway taper to provide adequate

² Fire Fighter Safety and Emergency Response for Solar Power Solar Farms. A DHS/Assistance to Firefighter Grants (AFG) Funded Study. Prepared by: Casey C. Grant, P.E. Fire Protection Research Foundation. The Fire Protection Research Foundation One Batterymarch Park Quincy, MA, USA 02169-7471. May 2010.

access. Taper transitions would be designed and constructed; a hammerhead turnaround is proposed at the entrance to provide a turn-around for emergency vehicles; refer to Figure 3A, Major Use Permit Plan.

Interior access would be provided by 24-foot wide access drives that would allow for adequate emergency access to all PV panel blocks and inverter stations. All fire access roads would be designed with an all-weather surface [decomposed granite (Class II Base) or gravel] and capable of supporting a minimum 75,000-pound fire apparatus bearing load. These drives would also be used for purposes of maintenance. The fire access roads would be constructed to facilitate a maximum fire hose pull of approximately 225 feet; however, County approval of a waiver (with concurrence by the VCFPD) would be required to allow the Project to exceed the established maximum fire hose pull length of 150 feet. Signage would be installed at the end of each fire access road onsite to identify those roadways intended for use by emergency vehicles. Additional 10-foot wide drive aisles running north-south would also be constructed within the field of solar arrays to provide access to maintenance purposes.

In order to control dust during the life of the Project, a non-toxic, biodegradable, permeable soil-binding agent or permeable rock material would be applied to all disturbed or exposed surface areas as follows: a) A permeable soil-binding agent suitable for both traffic and non-traffic areas shall be used. These agents shall be biodegradable, eco-safe, with liquid copolymers that stabilize and solidify soils or aggregates and facilitate dust suppression; or, b) Alternatively, a permeable rock material consisting of either river stone decomposed granite or gravel could be placed in a thin cover over all exposed surface area in-lieu of the binding agent referenced above. The binding agent would be reapplied approximately every two years for maintenance purposes.

A secured gate would be provided at the main access on Cole Grade Road. A gate is also proposed at the easterly end of the MUP boundary to allow fire department access to the existing residential structures in the eastern portion of the property. The gate would meet San Diego County Fire Code Section 96.1.503.6 requirements for automatic operation with battery back-up. The gates would open immediately upon emergency vehicle strobe light activation from either direction of approach and would include a Knox-box key-operation.

An illuminated directory sign would be located at the entrance of the facility and at each inverter station. The signage would depict the overall site plan and the locations of each numbered inverter structure and electrical grid disconnect and circuit breaker. Each inverter structure shall be numbered and signed to be plainly visible to the satisfaction of the Valley Center Fire Protection District (VCFPD).

Avoid Hazards

During the overall fire suppression and mop-up phases of an onsite fire, firefighters should avoid all potential electrical hazards until there is confirmation that the solar facilities no

longer pose an electric shock hazard. Firefighters must avoid inadvertently damaging solar components with their tools.³

Provide Ability for Electrical Solar Farm Isolation for Emergency Responders

A key task by emergency response personnel is the isolation or shutdown of electrical power. This is especially important for this commercial PV solar facility which would generate high levels of electricity and may therefore pose significant fire-fighting challenges. The inverters and DC combiner boxes are contained within the inverter structures. Switchgear for the Project would be housed onsite in combination with inverters/transformers on an approximately 8.4-foot by 7.5-foot platform. An override (or cut-off) switch will be provided that would be used to disconnect and disrupt all AC power leaving the inverter structures spaced throughout the site.

The solar arrays would be arranged in blocks with disconnects for each block of solar arrays located at the inverter structures. Though utilization of the disconnect would disrupt all AC power leaving the inverter structure, the solar arrays and all DC power lines would still be energized during the daytime. If a fire or emergency action is isolated to one block of inverter structures, this would not require de-energizing the entire solar field. It is important, however, to have a disconnect to quickly de-energize the entire solar field in the event that a fire or emergency action involves multiply panels/arrays within the site. An override (or cut-off) switch will be used to disconnect and disrupt all AC power leaving the inverter structures spaced throughout the site. A disconnect would also be provided for any other power source(s) that may be connected to the solar energy generating facilities.

Damaged solar panels/arrays should never be touched without verifying whether or not the solar panels/arrays are energized. Firefighters should never cut the wiring utilized for any component within the solar field. Specialized tools may be required for disconnecting the module wiring. Firefighters should consider controlling fires within a solar field rather than removal, due to the inherent electrical hazard. Solar modules, support structures, tracking assemblies, and conduit should not be disassembled, damaged, or removed by firefighters until all of the solar components are isolated or de-energized by a qualified technician or electrician.

The phone number of a responsible entity who can dispatch a local technician in a timely manner should be displayed on the lighted directory at the entrance and on each inverter structure. Firefighters should limit their activities to containment of the fire until it can be confirmed that the solar energy generating facilities are isolated or de-energized.

³ Fire Operations for Photovoltaic Emergencies. CAL FIRE - Office of the State Fire Marshal. November 2010.

In extraordinary circumstances, where all other tactics or options have been exhausted, solar panels must be removed. Care should be taken to use non-conductive tools since the modules and frames may still be energized. Damaged solar components should not be touched without verifying whether or not the Solar Farm is energized. Specialized tools may be required to disconnect wiring. Firefighters should consider containing fires within a solar field rather than removal due to the inherent hazard and limited electrical safety training afforded to firefighters.

Isolation of Inverters

Isolation of the inverters and disconnecting the solar field from the main electrical panel will be an important task. It is recommended that assistance from a local solar technician be utilized to disable and confirm that all the hazards have been mitigated.

At any incident where a solar energy generating facility is present, the IC should designate a "Utilities Group" early to aid in locating and disabling inverter structures and other solar energy generating components. This can greatly decrease the electric shock hazard to all crews operating on the fire ground. Firefighters must remember that all solar components must be considered "HOT" during daylight. Additionally, firefighters must be aware that if only a single array of multiple arrays is isolated, all of the other arrays would most likely remain energized. Care must be exercised when operating the other energized arrays.

Preparation of an emergency response plan identifying all tasks and the parties responsible for providing the electrical isolation for emergency responders is recommended.

Isolating the Fire

Another priority would be preventing further extension of a fire and isolating it to its area of origin. If components within the solar field are on fire, it must be assumed that such components are "hot" during daylight. Fire suppression crews should avoid physical contact with such components until it can be confirmed by a qualified solar technician or electrician that all power sources have been isolated. It may take time for the technician to respond and locate all of the associated controls.

Extinguishing Fires

CALFIRE recommends that dry chemical extinguishers be used to contain or extinguish electrical fires. Water should be used to extinguish any ordinary combustibles under or near the solar field, or if the volume of fire requires its use. If water is used, a 30° fog pattern from at least a 30-foot distance, at 100 pounds per square inch (psi) is recommended. Full PPE must be used, due to the potential toxic inhalation hazard if panels

are burning. Fire crews should position themselves upwind and out of any toxic atmosphere.⁴

CALFIRE also recommends that the IC request the assistance from a local solar technician to assist with disabling the solar energy generating components and confirmation that all of the hazards have been mitigated before the incident is terminated and the scene is turned over to the owner or responsible party.

Water for fire-fighting purposes for the Project would be provided via connection to an existing fire hydrant located within the Cole Grade Road right-of-way.

TRIP, SLIP OR FALL HAZARDS

Solar systems are comprised of metal, glass, conduit and cable, all of which are slippery when wet. As previously noted, firefighters should avoid contact with solar system components. In addition, firefighters should use caution if using narrow maintenance access ways for a fire incident onsite.

FIREFIGHTER INHALATION HAZARDS

Inhalation hazards from chemicals inherent in solar modules engulfed in a fire or explosion can be mitigated through the use of firefighters wearing Self Contained Breathing Apparatus (SCBA's) and personal protective equipment during firefighting and overhaul operations. It is the decision of the IC whether or not the emergency constitutes sheltering the population "in-place" downwind of the emergency. Fire or explosion emergencies involving large number of solar arrays, as in the proposed application, may necessitate evacuating downwind of the emergency.⁵

BATTERY HAZARDS

In some PV solar systems, batteries are used to store solar-generated electricity. Batteries are used most frequently in off-grid PV solar systems, although batteries are also used in grid-tied applications to have electricity available in the event of a power failure.⁶

The proposed solar energy generating facility does not include the use of batteries for the storage of electricity. Solar modules themselves have no storage capacity. Inverters have capacitors that do store energy; however, the energy within the capacitors is discharged soon after power to the inverters is disconnected.⁷

⁴ Ibid

⁵ Ibid

⁶ Ibid

⁷ Ibid

3. SUMMARY

CALFIRE recommends that the first line at attack in a fire incident, in which a PV solar system is involved, is ensuring that firefighters on the scene are trained in identifying such systems and the methods to control them. In addition, CALFIRE stresses that they must know how to adjust their assessment of the incident involving solar components to ensure appropriate actions are applied to the incident. In any incident, the desired outcome is to always mitigate and/or control the situation in a safe and efficient manner.⁸

The strategy and tactics firefighters choose are critical to both the outcome and the safety of all members working on the scene. CALFIRE indicates that the basics for ensuring safe, controlled, and mitigated incidents involving PV solar sites are as follows:

- Always wear protective clothing and SCBA
- Avoid wearing jewelry
- Use hand tools with insulated handles
- Locate battery storage area (if applicable)
- Be aware that biting and stinging insects could inhabit the module frame and electrical junction boxes
- Lock out/tag out system disconnects should be located and disconnected
- It is recommended that minimally, the fire emergency responders attend training entitled, "Fire Operations for Photovoltaic Emergencies," CALFIRE-Office of the State Fire Marshal, November 2010. The Fire Service Training and Education Program (FSTEP), provides this specific training need to local fire agencies in California.
- Proper signage must be installed at the site to accurately identify and locate project components (as appropriate) and potential hazards. Recommended signage requirements are as follows:
 - The phone number of a responsible entity with the authority and ability to dispatch a local technician in a timely manner should be displayed on the lighted directory at the entrance to the site and on each inverter structure.

⁸ Ibid

- Provision of signage at each disconnecting point to identify the location of the disconnecting point and the equipment it de-energizes.
- Numbering of each onsite inverter structure with a sign that is plainly visible and with numbers that contrast with their background, to the satisfaction of the VCFPD.
- A lighted directory located at the entrance to the site depicting the overall site plan and the locations of each numbered inverter structure (as shown on the plot plan) for the site. Access to the site would be from Cole Grade Road.
- Installation of signage at the end of each fire access road onsite to identify those roadways intended for use by emergency vehicles.
- The solar arrays would be arranged in blocks with disconnects for each block of solar arrays located at the inverter structures. Though the utilization of the disconnect would disrupt all AC power leaving an inverter structure, the solar arrays and all DC power lines would still be energized during the daytime.

The tactical approach to a fire incident near or within a solar field must be stressed with all fire suppression personnel (i.e., stay clear). Serious injury can occur with such solar developments on a sunny day, and the danger to fire service personnel is real.⁹

At the conclusion of an incident, emergency personnel should leave the property in the safest condition possible. A post-incident focused size-up and safety analysis should be conducted.

REFERENCES

Fire Behavior Analysis for Valley Center Photovoltaic Solar Farm, County of San Diego, California. Dudek. July 2015.

Fire Fighter Safety and Emergency Response for Solar Power Solar Farms. A DHS/Assistance to Firefighter Grants (AFG) Funded Study. Prepared by: Casey C. Grant, P.E. Fire Protection Research Foundation. The Fire Protection Research Foundation One Batterymarch Park Quincy, MA, USA 02169-7471. May 2010.

Fire Operations for Photovoltaic Emergencies. CAL FIRE - Office of the State Fire Marshal. November 2010.

⁹ Fire Fighter Safety and Emergency Response for Solar Power Solar Farms. A DHS/Assistance to Firefighter Grants (AFG) Funded Study. Prepared by: Casey C. Grant, P.E. Fire Protection Research Foundation. The Fire Protection Research Foundation One Batterymarch Park Quincy, MA, USA 02169-7471. May 2010.

Appendix B

Fire Behavior Computer Modeling

DUDEK

MAIN OFFICE
605 THIRD STREET
ENCINITAS, CALIFORNIA 92024
T 760.942.5147 T 800.450.1818 F 760.632.0164

August 3, 2015

Mr. Patrick Brown
Project Manager
NLP Valley Center Solar, LLC
17901 Von Karman Avenue, Suite 1050
Irvine, California 92614

Subject: Fire Behavior Analysis for Valley Center Photovoltaic Solar Farm, County of San Diego, California

Dear Mr. Brown,

This letter report presents the approach, methods, and results of Dudek's fire behavior modeling efforts for Valley Center Solar Farm (Project), located in within north-central San Diego County, California. To complete our scope of work, Dudek performed the following tasks:

- Reviewed applicable Project documents and maps;
- Retrieved, processed, and summarized fire weather data;
- Conducted fire behavior modeling runs using BehavePlus software.

This fire behavior analysis is a stand-alone document intended to support the preparation of the Project's fire protection plan (FPP), being prepared by RBF Consulting, a Michael Baker International Company. Dudek understands that the Project proponent is preparing an application for development and operation of a photovoltaic (PV) solar facility to be located on privately-held land. Project design and fire safety measures for the Major Use Permit (MUP) are described in the FPP. The Project site is located on a relatively flat valley within the community of Valley Center, east of Cole Grade Road and south of Via Valencia. The Project Area is situated in the U.S. Geological Survey (USGS) 7.5 minute Valley Center and Pala quadrangle maps in the east half of Section 6, Township 11 South, and Range 1 West.

The Project site is bounded on all sides by a mix of undeveloped land, rural residential properties, and agriculture, including orchards, a plant nursery business, and poultry farms. The proposed solar facilities would reside within County Assessor Parcel Numbers 188-120-09 and portion of 188-120-10, totaling approximately 66 acres (gross). The proposed MUP area for the Project includes approximately 25 acres of the 66 acres. The remainder of the two affected parcels would primarily remain in its existing state.

Mr. Patrick Brown

Subject: Fire Behavior Analysis for Valley Center Photovoltaic Solar Farm, County of San Diego, California

The following sections summarize the methods, data sources, and results associated with our scope of work.

FIRE BEHAVIOR MODELING

Prior to fire behavior modeling efforts, Dudek fire protection planners conducted a site evaluation on July 21, 2015, to confirm existing fuel conditions, which informed the overall fire modeling effort. Following field evaluations, site data was compiled and processed for inclusion in the BehavePlus fire model.

Fire behavior modeling was conducted to document the type and intensity of fire that would be expected on this site given characteristic site features such as topography, vegetation, and weather. The most commonly used modeling software packages (including BehavePlus 5.0.5) provide reliable estimates of flame length, fire intensity, and spread rate, among other fire behavior variables. Although fire behavior modeling has some limitations, it provides valuable estimated fire behavior predictions, which can be used as a tool in the decision-making process and fuel modification considerations. In order to make reliable estimates of fire behavior, and interpret fire spread models, one must understand the relationship of fuels to the fire environment and be able to recognize the variations in these fuels, and have experience with wildland fires or applicable knowledge of how fire reacts in similar fuels.

Fire behavior modeling conducted for the Project site includes a relatively high-level of detail and analysis which results in reasonably accurate representations of how wildfire may move through available fuels. Fire behavior calculations are based on site-specific fuel characteristics supported by fire science research that analyzes heat transfer related to specific fire behavior. To objectively predict flame lengths and intensities, this analysis incorporated predominant fuel characteristics, slope percentages, and representative fuel models documented adjacent to the Project site. The BehavePlus 5.0.5 fire behavior modeling system was used to analyze anticipated fire behavior in key areas just outside of proposed Project development areas.

Predicting wildland fire behavior is not an exact science. As such, the movement of a fire will likely never be fully predictable, especially considering the variations in weather and the limits of weather forecasting. Nevertheless, practiced and experienced judgment, coupled with a validated fire behavior modeling system, results in useful fire protection planning information. The following sections provide background on the various fire environment inputs utilized for the fire behavior modeling conducted for the Project site.

Mr. Patrick Brown

Subject: *Fire Behavior Analysis for Valley Center Photovoltaic Solar Farm, County of San Diego, California*

BehavePlus Model Inputs

Fuel Models

Vegetation is comprised of living and dead fuel. The type and quantity will depend upon the soil, climate, geographic features, and the fire history of the site. The major fuel groups of grass, shrub, trees and slash are defined by their constituent types and quantities of litter and duff layers, dead woody material, grasses and forbs, shrubs, regeneration, and trees. Fire behavior can be predicted largely by analyzing the characteristics of these fuels. Fire behavior is affected by topography (slope, aspect, and elevation), weather (wind, air temperature) and seven principal fuel characteristics: fuel loading, size and shape, compactness, horizontal continuity, vertical arrangement, moisture content and chemical properties.

The seven fuel characteristics help define the 13 standard fire behavior fuel models¹ and the more recent custom fuel models developed for Southern California². According to the model classifications, fuel models used for BehavePlus fire behavior modeling have been classified into four groups, based upon fuel loading (tons/acre), fuel height, and surface-to-volume ratio. Documentation of field conditions determines which fuel models should be applied in modeling efforts. The following describes the distribution of fuel models among general vegetation types for the standard 13 fuel models and the custom Southern California fuel models (SCAL):

Grasses	Fuel Models 1 through 3
Brush	Fuel Models 4 through 7, SCAL 14 through 18
Timber	Fuel Models 8 through 10
Logging Slash	Fuel Models 11 through 13

In addition, the aforementioned fuel characteristics were utilized in the recent development of 40 new fire behavior fuel models³ developed for use in the BehavePlus modeling system. These new models attempt to improve the accuracy of the 13 standard fuel models outside of severe fire season conditions, and to allow for the simulation of fuel treatment prescriptions. The following

¹ Anderson, Hal E. 1982. Aids to Determining Fuel Models for Estimating Fire Behavior. USDA Forest Service Gen. Tech. Report INT-122. Intermountain Forest and Range Experiment Station, Ogden, UT.

² Weise, D.R. and J. Regelbrugge. 1997. Recent chaparral fuel modeling efforts. Prescribed Fire and Effects Research Unit, Riverside Fire Laboratory, Pacific Southwest Research Station. 5p.

³ Scott, Joe H. and Robert E. Burgan. 2005. Standard fire behavior fuel models: a comprehensive set for use with Rothermel's surface fire spread model. Gen. Tech. Rep. RMRS-GTR-153. Fort Collins, CO: U.S. Department of Agriculture, Forest Service, Rocky Mountain Research Station. 72 p.

Mr. Patrick Brown

Subject: Fire Behavior Analysis for Valley Center Photovoltaic Solar Farm, County of San Diego, California

describes the distribution of fuel models among general vegetation types for the 40 more recently-developed fuel models:

Non-Burnable	Models NB1, NB2, NB3, NB8, NB9
Grass	Models GR1 through GR9
Grass Shrub	Models GS1 through GS4
Shrub	Models SH1 through SH9
Timber Understory	Models TU1 through TU5
Timber Litter	Models TL1 through TL9
Slash Blowdown	Models SB1 through SB4

Fuel models were assigned to vegetation types documented by Dudek's Fire Planners adjacent to the proposed Project site. Attachment 1 provides photographs showing the locations and representative fuel types that were used during fire modeling.

Weather

Weather and fuel moisture inputs incorporated into fire behavior modeling for the site were determined by utilizing the guidelines and standards presented by the County of San Diego, Department of Planning and Land Use.⁴ These guidelines identify acceptable fire weather inputs for extreme fire conditions during summer months and Santa Ana fire weather patterns. The County analyzed and processed fire weather from Remote Automated Weather Stations (RAWS) between April 15 to December 31 in order to represent the general limits of the fire season. Data provided by the County's analysis included temperature, relative humidity, and sustained wind speed and is categorized by weather zone, including Maritime, Coastal, Transitional, Interior, and Desert.

To evaluate potential fire behavior for the Project site, Dudek utilized the BehavePlus (v. 5.0.5) fire behavior modeling software package to determine fuel moisture values and expected fire behavior for the site. The temperature, relative humidity, and wind speed data for the Transitional⁵ weather zone were utilized for this fire behavior analysis based on the Project location. Reference fuel moistures were calculated in BehavePlus and were based on site-specific

⁴ County of San Diego Report Format and Content Requirements – Wildland Fire and Fire Protection (August 31, 2010). On-line at <http://www.sdcounty.ca.gov/dplu/docs/Fire-Report-Format.pdf>

⁵ <http://mappingsandiego.com/viewMap.html>

Mr. Patrick Brown

Subject: Fire Behavior Analysis for Valley Center Photovoltaic Solar Farm, County of San Diego, California

topographic data inputs. Fire behavior for the site was calculated in four different locations using worst-case fuels and topography (steepest slopes). Two of the modeling scenarios analyzed potential fire behavior along the western and southern edges (Scenarios 3 and 4) during summer fire weather conditions. The other two modeling scenarios (Scenarios 1 and 2) analyzed potential fire behavior along the eastern and northern edges of the development during Peak weather conditions. Table 1 presents the weather and fuel moisture input variables used for the fire behavior modeling.

Table 1
Fire Behavior Weather and Fuel Moisture Inputs

Model Variable	Summer Weather (Onshore Flow)	Peak Weather (Offshore/Santa Ana conditions)
1 h fuel moisture	5%	2%
10 h fuel moisture	7%	3%
100 h fuel moisture	10%	5%
Live herbaceous moisture	60%	30%
Live woody moisture	88%	60%
20 ft. wind speed (mph)	10-20 mph	30-40 mph (50 mph gusts)
Wind direction	upslope	Upslope/downslope
Slope steepness	variable by location	variable by location

Note: mph = miles per hour

Wind speed values derived from RAWS data represent 20-foot wind speeds. BehavePlus incorporates a wind adjustment factor to model mid-flame wind speeds. For this analysis, a wind speed adjustment factor of 0.4 was utilized to account for vertical differences in wind speed from the 20-foot recording height to mid-flame height prior to BehavePlus modeling efforts. A conservative wind adjustment factor of 0.4 indicates a fuel bed that is unsheltered from the wind with a fuel bed depth greater than 2.7 feet. It should be noted that mid-flame wind speeds may be only 10% of the wind speeds recorded or predicted at 20 feet, resulting in a conservative calculation.

Topography

Slope is a measure of angle in degrees from horizontal and can be presented in units of degrees or percent. Slope is important in fire behavior analysis as it affects the exposure of fuel beds. Additionally, fire burning uphill spreads faster than those burning on flat terrain or downhill as uphill vegetation is pre-heated and dried in advance of the flaming front, resulting in faster ignition rates. Slope values were measured from U.S. Geological Survey (USGS) topographic

Mr. Patrick Brown

Subject: *Fire Behavior Analysis for Valley Center Photovoltaic Solar Farm, County of San Diego, California*

maps and are presented in units of percent. The Project site and surrounding terrain within 300 feet of the Project site is generally flat to gentle slopes with gradients less than 10%.

BehavePlus Modeling Runs

Focused fire behavior modeling utilizing BehavePlus 5.0.5 was conducted for the Project. Based on slope and fuel conditions, four different fire scenarios were evaluated for the Project site, including:

- **Scenario 1:** Peak weather with off-shore, Santa Ana winds and a fall fire burning in well-maintained, citrus groves (offsite) and fuel modification around neighboring structures along the northern edge of the Project site. The onsite fuel types currently support a citrus grove with an understory of grasslands and ruderal species. The citrus trees, which are located within the MUP area as shown on the plot plan, will remain and the grove will be maintained in a healthy and less flammable state. The MUP area is relatively flat (5%) with potential ignition sources adjacent to residential area activities (i.e., weed whacking during fire season) or along nearby surface street (Cole Grade Road).
- **Scenario 2:** Peak weather with off-shore, Santa Ana winds and a fall fire burning in fallowed agricultural lands, ruderal species and grasslands growing between the rows in citrus groves or within a Coast live oak (*Quercus agrifolia*) woodlands on both sides of a narrow, water course that meanders near the eastern and southern edges of the Project site. This area gently slopes (10%) upward towards the northeast corner of the property with potential ignition sources from adjacent agricultural activities occurring outside the Project site or on the agricultural lands and rural residential properties bordering the east side of the property.
- **Scenario 3:** Summer weather with on-shore winds and a fire burning in fallowed agricultural lands along southeast corner of the Project site. The rest of the area south of the Project site is covered by ruderal species growing adjacent to or between rows of a citrus grove that is declining in health. The Project proposes to remove the first three rows of citrus trees, which would extend the fuel modification zone from 30 feet to approximately 50 feet in width. This area is relatively flat (5% slope) with potential ignition sources along nearby surface street (Cole Grade Road), or from adjacent rural residential areas and a poultry farm.
- **Scenario 4:** Summer weather with on-shore winds and a fire burning in maintained, rural residential landscapes and mowed grassland fuels along the western edge of the Project site. This area slopes uphill towards the site with gradients ranging from 5 to 10%.

Mr. Patrick Brown

Subject: *Fire Behavior Analysis for Valley Center Photovoltaic Solar Farm, County of San Diego, California*

Potential ignition sources occur along nearby surface street (Cole Grade Road) or from adjacent rural residential areas and orchards.

The unique terrain and fuel models used for BehavePlus modeling for the Project site are summarized in Table 2.

Table 2
Fire Behavior Model Variables

Scenario (Model Run)	Weather	Vegetation/Fuel Model	Slope	Aspect
1	Santa Ana (Peak)	Maintained grove/grassland (low fuel load) mix (gr2)	5%	flat to South
2	Santa Ana (Peak)	Grove/grasslands-ruderal spp./oak woodlands (gr2 & gr4)	5%-10%	flat to West
3	Summer	Grove/grassland/ruderal spp. (moderate fuel load) mix (gr4)	2%-5%	flat
4	Summer	Maintained Grassland-low fuel load (gr2)	2%-10%	South/Southwest

Note: gr = standard fire behavior fuel model for short grasslands (see footnote #3)

BehavePlus Fire Behavior Modeling Results

Three fire behavior variables were selected as outputs from the BehavePlus analysis conducted for the Project site, and include flame length (feet), rate of spread (mph), and fireline intensity (BTU/feet/second). The aforementioned fire behavior variables are an important component in understanding fire risk and fire agency response capabilities. Flame length, the length of the flame of a spreading surface fire within the flaming front, is measured from midway in the active flaming combustion zone to the average tip of the flames⁶. It is a somewhat subjective and non-scientific measure of fire behavior, but is extremely important to fireline personnel in evaluating fireline intensity and is worth considering as an important fire variable⁷. Fireline intensity is a measure of heat output from the flaming front, and also affects the potential for a surface fire to transition to a crown fire. Fire spread rate represents the speed at which the fire progresses through surface fuels and is another important variable in initial attack and fire suppression efforts. The information in Table 3 presents an interpretation of these fire behavior

⁶ Andrews, Patricia L., Collin D. Bevins, and Robert C. Seli. 2004. BehavePlus fire modeling system, version 3.0: User's Guide. Gen. Tech. Rep. RMRS-GTR-106 Ogden, Utah: Department of Agriculture, Forest Service, Rocky Mountain Research Station. 132p.

⁷ Rothermel, R.C. 1983. How to Predict the Spread and Intensity of Forest and Range Fires. USDA Forest Service Gen. Tech. Report INT-143. Intermountain Forest and Range Experiment, Ogden, Utah.

Mr. Patrick Brown

Subject: Fire Behavior Analysis for Valley Center Photovoltaic Solar Farm, County of San Diego, California

variables as related to fire suppression efforts. The results of fire behavior modeling efforts are presented in Table 4. Additionally, identification of modeling run locations is presented graphically in Attachment 2.

Table 3
Fire Suppression Interpretation

Flame Length (ft)	Fireline Intensity (Btu/ft/s)	Interpretations
Under 4 feet	Under 100 BTU/ft/s	Fires can generally be attacked at the head or flanks by persons using hand tools. Hand line should hold the fire.
4 to 8 feet	100-500 BTU/ft/s	Fires are too intense for direct attack on the head by persons using hand tools. Hand line cannot be relied on to hold the fire. Equipment such as dozers, pumpers, and retardant aircraft can be effective.
8 to 11 feet	500-1000 BTU/ft/s	Fires may present serious control problems -- torching out, crowning, and spotting. Control efforts at the fire head will probably be ineffective.
Over 11 feet	Over 1000 BTU/ft/s	Crowning, spotting, and major fire runs are probable. Control efforts at head of fire are ineffective.

Source: BehavePlus 5.0.5 fire behavior modeling program (Andrews, Bevins, and Seli 2004)

Table 4
BehavePlus Fire Behavior Modeling Results

Model Run	Flame Length (feet)	Fireline Intensity (Btu/ft/s)	Surface Rate of Spread (mph)
1	12.7 to 14.1	1,418 to 1,791	3.3 to 4.2
2	12.6 to 33.3	1,410 to 11,557	3.3 to 13.9
3	8.6 to 13.5	613 to 1,628	0.78 to 2.1
4	4.6 to 7.2	155 to 414	0.39 to 1.0

The results presented in Table 4 depict values based on inputs to the BehavePlus software and are not intended to capture changing fire behavior as it moves across a landscape. Changes in slope, weather, or pockets of different fuel types are not accounted for in this analysis. Additionally, fuel model assignments are based on site and aerial photograph evaluation. Model results should be used as a basis for planning only, as actual fire behavior for a given location will be affected by many factors, including unique weather patterns, small-scale topographic variations, or changing vegetation patterns.

Mr. Patrick Brown

Subject: Fire Behavior Analysis for Valley Center Photovoltaic Solar Farm, County of San Diego, California

Fire Potential Summary

Given the climatic, vegetation, and topographic characteristics of the analysis area, along with the fire behavior modeling results discussed herein, the Project site is considered potentially vulnerable to wildfire starting in, burning onto, or spotting onto the site. The fire behavior results described herein depict values based on inputs to the BehavePlus software. Localized changes in slope, weather, or pockets of different fuel types are not accounted for in this analysis, but assumed across the landscape. Further, this modeling analysis assumes a correlation between the available vegetation data and fuel model characteristics. Wildfire activity may temporarily alter fuel beds, but fire behavior modeling efforts conducted for this site assume natural succession of burned areas to more mature stand conditions, resulting in a conservative (near worst-case) estimate of fire behavior. Since fire behavior for a given location will be affected by many factors, including unique weather patterns, small-scale topographic variations, or changing vegetation patterns, modeling results are applicable as a basis for planning, but need to be considered in context with other site variables.

As presented, wildfire behavior under current fuel bed conditions for all sides of the Project site is expected to be of a low to moderate intensity fire. In all four fire scenarios, the primary carrier of fire is the non-maintained, grass-ruderal species fuel type. Ignition of these fuel beds typically results in a fast moving fire, but with lower intensity and flame lengths than a chaparral-dominated fuel bed as indicated in the fire modeling above. The exception would be for scenario #2 when a wildfire burns through the continuous, higher fuel loading in the grasslands-ruderal species under extreme weather conditions resulting in a more intense wildfire reaching flame lengths up to 33 feet, as modeled. All fire scenarios would be relatively short-duration as these vegetative fuels are consumed rapidly. As such, there would not be a sustained source of heat and or flame.

Note, two of the fire scenarios (#2 and #3), which were modeled, considered that the fuel beds were not provided maintenance. Scenarios #1 and #4 with low fuel loadings were modeled under conditions that included maintenance of the fuels within the citrus groves or on the adjoining rural residential properties. With the scheduled maintenance, the fire behavior would be less intense and extinguishable by firefighting resources on the ground. Additionally, removing three rows of citrus trees near the southeast corner of the Project would provide a wider fire buffer to distance the remaining fuels outside the fence line from the solar panels.

Flying embers from off-site fire may inundate the Valley Center Solar Project area during wind-driven fire events, but they would find few receptive fuel beds within the Project site. The site will be largely free combustible vegetation with only a ground cover of maintained vegetation adjacent and possibly beneath the solar panels.

Mr. Patrick Brown

Subject: Fire Behavior Analysis for Valley Center Photovoltaic Solar Farm, County of San Diego, California

If you have any questions regarding this Fire Behavior Analysis, please contact me at 619.992.9161.

Sincerely,

A handwritten signature in black ink, reading "Michael Huff", written over a horizontal line.

Michael Huff

Principal

Sr. Fire Protection Planner

*Att: Attachment 1, Photograph Log
Attachment 2, BehavePlus Fire Behavior Modeling Exhibit*


ATTACHMENT 1

Photograph Log


Attachment 1

Valley Center Solar Project

Site Photographs



Photograph 1. Photograph shows current condition of citrus groves on- and off-site. Fuel types are located on the north side of the property. Fuels (grasses and ruderal species) shown in the foreground of photograph will be removed during construction of the Project. Maintained citrus groves were modeled as fire run #1.



Photograph 2. Fuels near the eastern edge of the project site are fallowed agricultural lands, ruderal species, and oak woodlands. These fuels were modeled for fire run #2. Photograph was taken on Project site facing east.


Attachment 1

Valley Center Solar Project

Site Photographs



Photograph 3. View looking at fuel type and fuel load underneath oak woodland canopy.




Photograph 4. The majority of the fuel types to the southwest and south of the Project site consist of grasslands, fallowed agricultural lands with non-maintained, citrus trees, and ruderal species. These fuel types were modeled in fire run #3.


Attachment 1

Valley Center Solar Project

Site Photographs



Photograph 5. Additional photograph of terrain and fallowed agricultural lands that were modeled in fire run #3.



Photograph 6. The majority of the fuel types to the southwest and west of the Project site consist of rural residential properties. The grass (low load) fuel type was modeled in fire run #4.

ATTACHMENT 2
Fire Behavior Analysis Exhibit

Modeling Inputs:

Summer Weather - Onshore flow (RUN 3 & 4):
1h Fuel Moisture: 3%
10h Fuel Moisture: 5%
100h Fuel Moisture: 7%
Live Herbaceous Moisture: 60%
Live Woody Moisture: 90%
20-foot Wind Speed: 10,20 mph
Wind Adjustment Factor: 0.4

Peak Weather - Offshore/Santa Ana Condition (RUN 1 & 2):
1h Fuel Moisture: 2%
10h Fuel Moisture: 3%
100h Fuel Moisture: 5%
Live Herbaceous Moisture: 30%
Live Woody Moisture: 50%
20-foot Wind Speed: 30-40 mph (50 mph gusts)
Wind Adjustment Factor: 0.4


Run 1
Slope: 5%
Fuel Model: Grasslands (gr2)
Flame Length: 12.7 feet to 14.1 feet
Fireline Intensity: 1,415 to 1,791 Btu/ft/s
Spread Rate: 3.3 to 4.2 mph

Run 2
Slope: 5 -10%
Fuel Model: Grasslands (gr2 and gr4)
Flame Length: 12.6 to 33.3 feet
Fireline Intensity: 1,410, to 11,557 Btu/ft/s
Spread Rate: 3.3 to 13.9 mph

Run 4
Slope: 2 - 10%
Fuel Model: Grasslands, (gr2)
Flame Length: 4.6 to 7.2 feet
Fireline Intensity: 155 to 414 Btu/ft/s
Spread Rate: 0.39 to 1.0 mph

Run 3
Slope: 2 - 5%
Fuel Model: Grasslands, (gr4)
Flame Length: 8.6 to 13.5 feet
Fireline Intensity: 613 to 1,628 Btu/ft/s
Spread Rate: 0.78 to 2.1 mph

MUP Boundary
Property Line



DUDEK

9120

VALLEY CENTER SOLAR PROJECT

Image courtesy of USGS © 2015 Microsoft Corporation © 2015 HERE © AND