

Appendix P
Water System Analysis

**WATER SYSTEM ANALYSIS
FOR THE
EAST OTAY MESA
SPECIFIC PLAN AMENDMENT**

September 23, 2015



**Prepared by:
Dexter Wilson Engineering, Inc.
2234 Faraday Avenue
Carlsbad, CA 92008**

Job No. 701-012

DEXTER WILSON ENGINEERING, INC.

DEXTER S. WILSON, P.E.
ANDREW M. OVEN, P.E.
STEPHEN M. NIELSEN, P.E.
NATALIE J. FRASCHETTI, P.E.

September 23, 2015

701-012

Sunroad Enterprises
4445 Eastgate Mall, Suite 400
San Diego, CA 92121

Attention: Andrea Rosati, Vice President

Subject: Water System Analysis for the East Otay Mesa Specific Plan Amendment

Introductions

This letter-report summarizes our efforts to evaluate the potable water system requirements for the proposed East Otay Mesa Specific Plan Amendment (Project). The project is within the Otay Water District (OWD) for potable and recycled water service. This study provides information on planning criteria, projected water demands, existing facilities, and proposed facilities associated with serving the project. This study provides recommended water facilities specific to the needs of the East Otay Mesa Specific Plan Amendment, but takes into account Otay Water District regional planning for the area.

Project Overview

The Project is 220.3 acres in size and is located along the north side of Otay Mesa Road just east of State Route 125. Figure 1 provides a location map for the project. The project proposes up to 3,158 residential dwelling units, 1,389,564 square feet of technology park, and 84,842 square feet of commercial development.

\\ARPA01D\DWG\700012\FIGURES\FIGURE 1.DWG 09-12-15 08:52:17 LAYOUT: A LAYOUT1




FIGURE 1

VICINITY MAP

DEXTER WILSON ENGINEERING, INC.
CONSULTING ENGINEERS
(760) 438-4422

EAST OTAY MESA SPECIFIC PLAN AMENDMENT

Purpose of Study

The purpose of this study is to provide the required potable water improvements that will be necessary to serve the proposed Specific Plan Amendment for the East Otay Mesa property. This report will also serve as supporting documentation for the Project's environmental report for the Specific Plan Amendment.

Planning Criteria

The planning criteria used in this study are in accordance with the October 2008 Otay Water District Water Resources Master Plan, last amended April 2013. The criteria pertinent to this study are summarized below. OWD has recently determined that it is not feasible to supply recycled water to the East Otay Mesa area and the demand factors reflect that all demands will be met with potable water.

- Minimum Pressure, Static = 60 psi
- Maximum Pressure, Static = 200 psi (120 psi desired)
- Minimum Pressure, Peak Hour = 40 psi
- Minimum Pressure, Max Day plus Fire = 20 psi
- Commercial Demand Factor = 1,785 gpd/acre
- Industrial Demand Factor = 893 gpd/acre
- High Density Residential Demand Factor (>8 DU/ac) = 300 gpd/DU
- Maximum Velocity, Peak Hour = 6 fps
- Maximum Velocity, Max Day plus Fire = 10 fps
- Hazen Williams "C", 12-inch diameter and less = 120
- Hazen Williams "C", greater than 12-inch diameter = 130

In order to determine maximum day demand and peak hour demand, Figure 4-2 and Figure 4-3 from the OWD Master Plan were used, respectively. These figures are included in Appendix A. For industrial and commercial land uses, OWD uses a fire flow requirement of 3,500 gpm for planning purposes. For residential land uses, OWD uses a fire flow requirement of 1,500 gpm and 2,500 gpm for single-family and multi-family residences, respectively. The actual fire flow requirements will need to be confirmed with the fire department once building footprints and construction materials are known.

Projected Water Demands

Table 1 summarizes the projected average total water demands for the project. A detailed projection of water demand by land use area is included with the hydraulic analysis in Appendix B.

| TABLE 2 EAST OTAY MESA SPECIFIC PLAN AMENDMENT PROJECTED WATER DEMAND | | | | |
|--|--------------|--------------|----------------------|--------------------|
| Land Use | Area | Units | Demand Factor | Demand, gpd |
| Residential | 110.9 | 3,158 | 300 gpd/DU | 947,400 |
| Industrial Park | 47.7 | -- | 893 gpd/acre | 42,596 |
| Commercial | 7.8 | -- | 1,785 gpd/acre | 13,923 |
| Open Space | 53.9 | -- | -- | 0 |
| TOTAL | 220.3 | 3,158 | | 1,003,919 |

The maximum day demand and peak hour demand peaking factors are 2.5 and 5.0, respectively, resulting in a maximum day demand of 2,509,798 gpd (1,743 gpm) and peak hour demand of 5,019,595 gpd (3,486 gpm).

Existing Facilities

The project can be served by supplying potable water to the project in an existing 24-inch line in Otay Mesa Road directly adjacent to the project and a north-south 21-inch line that crosses through the project. Both lines are part of the 870 Zone water system that serves the entire Otay Mesa Area. An 11.0 million gallon 870 Zone Reservoir is located northeast of the project, adjacent to the East Mesa Detention Facility. From this reservoir, transmission lines in Alta Road convey water to the Otay Mesa area. Figure 2 provides the location of existing potable water facilities in the vicinity of the project.

Proposed Water Facilities

To provide potable water service to the project, it is proposed to expand the 870 Zone system by connecting to the existing 24-inch line in Otay Mesa Road at three locations. The project will also connect to the 21-inch pipeline that runs from north to south through the proposed project and relocate a section of this line to Vann Centre Boulevard. The project proposes to construct 12-inch water lines throughout the project. Smaller diameter pipelines could satisfy the District's criteria in some areas of the project, but, due to the potential higher fire flows once building data is known, 12-inch piping is recommended in the backbone streets throughout the Project.

Static pressures on the project are expected to range from 112 to 142 psi. The maximum static pressure is greater than the desired maximum pressure of 120 psi, but within the District limit of 200 psi. Figure 3 provides the proposed water system requirements for the system.

Hydraulic Analysis

Analysis using the KYPIPE computer software developed by the University of Kentucky determined residual pressures throughout the proposed water system. This computer software utilizes the Hazen-Williams equation for determining headloss in pipes. The Hazen-Williams "C" value used for pipe sizes 12 inches in diameter or less is 120, and for all pipe sizes greater than 12 inches in diameter is 130.

The system was modeled under multiple flow scenarios. For all flow scenarios the hydraulic gradeline available in the vicinity of the project was assumed to be 840 feet. The proposed system meets all design criteria except for the proposed 12-inch in Lone Star Road. The velocity in this line is 10.34 fps during a maximum day demand plus fire flow condition which is greater than the District's maximum of 10 fps.

Appendix B provides the computer modeling output for the hydraulic analysis and Exhibit A provides the corresponding node and pipe diagram.

Andrea Rosati
September 23, 2015

If you have any questions, please let us know.

Dexter Wilson Engineering, Inc.



Stephen M. Nielsen, P.E.

SMN:pjs





APPENDIX A

MAXIMUM DAY DEMAND AND PEAK HOUR DEMAND PEAKING FACTOR CURVES

Figure 4-2. MDD Peaking Factor Curve





Figure 4-3. Peak Hour Peaking Curve



APPENDIX B

HYDRAULIC ANALYSIS

**EASTY OTAY MESA SPECIFIC PLAN AMENDMENT
PROJECTED WATER DEMAND
BY PLANNING AREA**

| Planning Area | Land Use | Area, acres | Units | Denisty, units/acre | Demand Factor | Demand, gpd |
|----------------------|-----------------|------------------------|--------------|--------------------------------|--------------------------|------------------------|
| A | Residential | 10.1 | 303 | 30 | 300 gpd/DU | 90,900 |
| | Tech Park | 15.2 | -- | -- | 893 gpd/ac | 13,574 |
| | Open Space | 0.2 | -- | -- | -- | 0 |
| B | Residential | 18.3 | 586 | 32 | 300 gpd/DU | 175,800 |
| | Tech Park | 1 | -- | -- | 893 gpd/ac | 893 |
| | Open Space | 2.1 | -- | -- | -- | 0 |
| C | Residential | 17.1 | 548 | 32 | 300 gpd/DU | 164,400 |
| | Tech Park | 0.9 | -- | -- | 893 gpd/ac | 804 |
| | Open Space | 0.3 | -- | -- | -- | 0 |
| D | Residential | 16.9 | 540 | 32 | 300 gpd/DU | 162,000 |
| | Tech Park | 0.4 | -- | -- | 893 gpd/ac | 357 |
| | Commercial | 0.5 | -- | -- | 1,785 gpd/ac | 893 |
| E | Residential | 4 | 79 | 20 | 300 gpd/DU | 23,700 |
| | Tech Park | 0.6 | -- | -- | 893 gpd/ac | 536 |
| | Commercial | 6.8 | -- | -- | 1,785 gpd/ac | 12,138 |
| F | Residential | 7.4 | 148 | 20 | 300 gpd/DU | 44,400 |
| | Tech Park | 11.1 | -- | -- | 893 gpd/ac | 9,912 |
| G | Residential | 10 | 200 | 20 | 300 gpd/DU | 60,000 |
| | Commercial | 0.5 | -- | -- | 1,785 gpd/ac | 893 |
| H | Residential | 20.6 | 624 | 30 | 300 gpd/DU | 187,200 |
| | Tech Park | 1.1 | -- | -- | 893 gpd/ac | 982 |
| I | Tech Park | 4 | -- | -- | 893 gpd/ac | 3,572 |
| J | Residential | 6.5 | 130 | 20 | 300 gpd/DU | 39,000 |
| | Tech Park | 9.8 | -- | -- | 893 gpd/ac | 8,751 |
| K | Tech Park | 3.6 | -- | -- | 893 gpd/ac | 3,215 |
| M | Open Space | 51.3 | -- | -- | -- | 0 |
| TOTAL | | 220.3 | 3,158 | | | 1,003,919 |

KYPIPE
HYDRAULIC ANALYSES

1. Average Day Demand
2. Peak Hour Demand
3. Maximum Day Demand plus 3,500 gpm Fire Flow at Node 32
4. Maximum Day Demand plus 3,500 gpm Fire Flow at Node 28
5. Maximum Day Demand plus 3,500 gpm Fire Flow at Node 8

East Otay Mesa Specific Plan Amendment
Public Water System Analysis

Job No. 701-012
File Name: 701012A1
September 21, 2015

FLOWRATE IS EXPRESSED IN GPM AND PRESSURE IN PSIG

A SUMMARY OF THE ORIGINAL DATA FOLLOWS

| PIPE NO. | NODE NOS. | LENGTH (FEET) | DIAMETER (INCHES) | ROUGHNESS | MINOR LOSS K | FIXED GRADE |
|----------|-----------|------------------|----------------------|-----------|--------------|-------------|
| 101 | 0 4 | 600.0 | 12.0 | 120.0 | .00 | 840.00 |
| 105 | 4 8 | 850.0 | 12.0 | 120.0 | .00 | |
| 107 | 4 24 | 800.0 | 12.0 | 120.0 | .00 | |
| 109 | 0 16 | 650.0 | 21.0 | 130.0 | .00 | 840.00 |
| 113 | 12 16 | 1000.0 | 21.0 | 130.0 | .00 | |
| 117 | 0 12 | 525.0 | 21.0 | 130.0 | .00 | 840.00 |
| 121 | 16 20 | 900.0 | 12.0 | 120.0 | .00 | |
| 125 | 20 24 | 1000.0 | 12.0 | 120.0 | .00 | |
| 129 | 24 28 | 1150.0 | 12.0 | 120.0 | .00 | |
| 133 | 28 32 | 1750.0 | 12.0 | 120.0 | .00 | |
| 137 | 0 36 | 1650.0 | 24.0 | 130.0 | .00 | 840.00 |
| 141 | 36 40 | 650.0 | 12.0 | 120.0 | .00 | |
| 145 | 40 44 | 550.0 | 12.0 | 120.0 | .00 | |
| 149 | 44 48 | 1100.0 | 12.0 | 120.0 | .00 | |
| 153 | 48 32 | 1550.0 | 12.0 | 120.0 | .00 | |
| 157 | 20 40 | 800.0 | 12.0 | 120.0 | .00 | |
| 161 | 24 44 | 700.0 | 12.0 | 120.0 | .00 | |
| 165 | 28 48 | 1050.0 | 12.0 | 120.0 | .00 | |
| 169 | 36 52 | 1400.0 | 24.0 | 130.0 | .00 | |
| 173 | 52 48 | 1500.0 | 12.0 | 120.0 | .00 | |

| JUNCTION NUMBER | DEMAND | ELEVATION | CONNECTING PIPES |
|-----------------|--------|-----------|------------------|
| 4 | .00 | 596.00 | 101 105 107 |
| 8 | 57.40 | 612.00 | 105 |
| 12 | .00 | 574.00 | 113 117 |
| 16 | 4.70 | 575.00 | 109 113 121 |
| 20 | 82.00 | 562.00 | 121 125 157 |
| 24 | 86.50 | 580.00 | 107 125 129 161 |
| 28 | 175.40 | 590.00 | 129 133 165 |
| 32 | 134.00 | 538.00 | 133 153 |
| 36 | .00 | 551.00 | 137 141 169 |
| 40 | 29.20 | 557.00 | 141 145 157 |
| 44 | 33.70 | 566.00 | 145 149 161 |
| 48 | 69.30 | 586.00 | 149 153 165 173 |
| 52 | 25.30 | 538.00 | 169 173 |

OUTPUT SELECTION: ALL RESULTS ARE OUTPUT EACH PERIOD

THIS SYSTEM HAS 20 PIPES WITH 13 JUNCTIONS , 4 LOOPS AND 4 FGNS

East Otay Mesa Specific Plan Amendment
Public Water System Analysis

Job No. 701-012
File Name: 701012A1
September 21, 2015

THE RESULTS ARE OBTAINED AFTER 6 TRIALS WITH AN ACCURACY = .00449

OTAY MESA SPECIFIC PLAN AMENDMENT WATER ANALYSIS

AVERAGE DAY DEMAND

| PIPE NO. | NODE NOS. | FLOWRATE | HEAD LOSS | PUMP HEAD | MINOR LOSS | VELOCITY | HL/1000 |
|----------|-----------|----------|-----------|-----------|------------|----------|---------|
| 101 | 0 4 | 182.75 | .08 | .00 | .00 | .52 | .13 |
| 105 | 4 8 | 57.40 | .01 | .00 | .00 | .16 | .01 |
| 107 | 4 24 | 125.35 | .05 | .00 | .00 | .36 | .06 |
| 109 | 0 16 | 101.51 | .00 | .00 | .00 | .09 | .00 |
| 113 | 12 16 | 64.10 | .00 | .00 | .00 | .06 | .00 |
| 117 | 0 12 | 64.10 | .00 | .00 | .00 | .06 | .00 |
| 121 | 16 20 | 160.91 | .09 | .00 | .00 | .46 | .10 |
| 125 | 20 24 | 90.94 | .03 | .00 | .00 | .26 | .03 |
| 129 | 24 28 | 129.25 | .08 | .00 | .00 | .37 | .07 |
| 133 | 28 32 | 44.44 | .02 | .00 | .00 | .13 | .01 |
| 137 | 0 36 | 349.14 | .02 | .00 | .00 | .25 | .01 |
| 141 | 36 40 | 168.11 | .07 | .00 | .00 | .48 | .11 |
| 145 | 40 44 | 126.87 | .04 | .00 | .00 | .36 | .06 |
| 149 | 44 48 | 93.71 | .04 | .00 | .00 | .27 | .04 |
| 153 | 48 32 | 89.56 | .05 | .00 | .00 | .25 | .03 |
| 157 | 20 40 | -12.03 | .00 | .00 | .00 | -.03 | .00 |
| 161 | 24 44 | .54 | .00 | .00 | .00 | .00 | .00 |
| 165 | 28 48 | -90.58 | -.04 | .00 | .00 | -.26 | -.03 |
| 169 | 36 52 | 181.03 | .01 | .00 | .00 | .13 | .00 |
| 173 | 52 48 | 155.73 | .14 | .00 | .00 | .44 | .09 |

| JUNCTION NUMBER | DEMAND | GRADE LINE | ELEVATION | PRESSURE |
|-----------------|--------|------------|-----------|----------|
| 4 | .00 | 839.92 | 596.00 | 105.70 |
| 8 | 57.40 | 839.91 | 612.00 | 98.76 |
| 12 | .00 | 840.00 | 574.00 | 115.27 |
| 16 | 4.70 | 840.00 | 575.00 | 114.83 |
| 20 | 82.00 | 839.91 | 562.00 | 120.43 |
| 24 | 86.50 | 839.87 | 580.00 | 112.61 |
| 28 | 175.40 | 839.80 | 590.00 | 108.25 |
| 32 | 134.00 | 839.78 | 538.00 | 130.77 |
| 36 | .00 | 839.98 | 551.00 | 125.22 |
| 40 | 29.20 | 839.91 | 557.00 | 122.59 |
| 44 | 33.70 | 839.87 | 566.00 | 118.68 |
| 48 | 69.30 | 839.83 | 586.00 | 109.99 |
| 52 | 25.30 | 839.97 | 538.00 | 130.86 |

THE NET SYSTEM DEMAND = 697.50

SUMMARY OF INFLOWS (+) AND OUTFLOWS (-) FROM FIXED GRADE NODES

| PIPE NUMBER | FLOWRATE |
|-------------|----------|
| 101 | 182.75 |
| 109 | 101.51 |
| 117 | 64.10 |
| 137 | 349.14 |

THE NET FLOW INTO THE SYSTEM FROM FIXED GRADE NODES = 697.50

THE NET FLOW OUT OF THE SYSTEM INTO FIXED GRADE NODES = .00

A SUMMARY OF CONDITIONS SPECIFIED FOR THE NEXT SIMULATION FOLLOWS

THE DEMANDS ARE CHANGED FROM ORIGINAL VALUES BY A FACTOR = 5.00

THE RESULTS ARE OBTAINED AFTER 2 TRIALS WITH AN ACCURACY = .00003

PEAK HOUR DEMAND

| PIPE NO. | NODE NOS. | FLOWRATE | HEAD LOSS | PUMP HEAD | MINOR LOSS | VELOCITY | HL/1000 |
|----------|-----------|----------|-----------|-----------|------------|----------|---------|
| 101 | 0 4 | 913.75 | 1.49 | .00 | .00 | 2.59 | 2.49 |
| 105 | 4 8 | 287.00 | .25 | .00 | .00 | .81 | .29 |
| 107 | 4 24 | 626.75 | .99 | .00 | .00 | 1.78 | 1.24 |
| 109 | 0 16 | 507.70 | .03 | .00 | .00 | .47 | .05 |
| 113 | 12 16 | 320.36 | .02 | .00 | .00 | .30 | .02 |
| 117 | 0 12 | 320.36 | .01 | .00 | .00 | .30 | .02 |
| 121 | 16 20 | 804.55 | 1.77 | .00 | .00 | 2.28 | 1.97 |
| 125 | 20 24 | 454.72 | .68 | .00 | .00 | 1.29 | .68 |
| 129 | 24 28 | 646.27 | 1.51 | .00 | .00 | 1.83 | 1.31 |
| 133 | 28 32 | 222.17 | .32 | .00 | .00 | .63 | .18 |
| 137 | 0 36 | 1745.70 | .40 | .00 | .00 | 1.24 | .24 |
| 141 | 36 40 | 840.53 | 1.39 | .00 | .00 | 2.38 | 2.13 |
| 145 | 40 44 | 634.36 | .70 | .00 | .00 | 1.80 | 1.27 |
| 149 | 44 48 | 468.57 | .79 | .00 | .00 | 1.33 | .72 |
| 153 | 48 32 | 447.83 | 1.03 | .00 | .00 | 1.27 | .66 |
| 157 | 20 40 | -60.17 | -.01 | .00 | .00 | -.17 | -.02 |
| 161 | 24 44 | 2.70 | .00 | .00 | .00 | .01 | .00 |
| 165 | 28 48 | -452.91 | -.71 | .00 | .00 | -1.28 | -.68 |
| 169 | 36 52 | 905.17 | .10 | .00 | .00 | .64 | .07 |
| 173 | 52 48 | 778.67 | 2.78 | .00 | .00 | 2.21 | 1.85 |

| JUNCTION NUMBER | DEMAND | GRADE LINE | ELEVATION | PRESSURE |
|-----------------|--------|------------|-----------|----------|
| 4 | .00 | 838.51 | 596.00 | 105.09 |
| 8 | 287.00 | 838.26 | 612.00 | 98.05 |
| 12 | .00 | 839.99 | 574.00 | 115.26 |
| 16 | 23.50 | 839.97 | 575.00 | 114.82 |
| 20 | 410.00 | 838.20 | 562.00 | 119.69 |
| 24 | 432.50 | 837.52 | 580.00 | 111.59 |
| 28 | 877.00 | 836.01 | 590.00 | 106.60 |
| 32 | 670.00 | 835.69 | 538.00 | 129.00 |
| 36 | .00 | 839.60 | 551.00 | 125.06 |
| 40 | 146.00 | 838.21 | 557.00 | 121.86 |
| 44 | 168.50 | 837.52 | 566.00 | 117.66 |
| 48 | 346.50 | 836.72 | 586.00 | 108.65 |
| 52 | 126.50 | 839.50 | 538.00 | 130.65 |

THE NET SYSTEM DEMAND = 3487.50

East Otay Mesa Specific Plan Amendment
Public Water System Analysis

Job No. 701-012
File Name: 701012A1
September 21, 2015

SUMMARY OF INFLOWS(+) AND OUTFLOWS(-) FROM FIXED GRADE NODES

| PIPE NUMBER | FLOWRATE |
|-------------|----------|
| 101 | 913.75 |
| 109 | 507.70 |
| 117 | 320.36 |
| 137 | 1745.70 |

THE NET FLOW INTO THE SYSTEM FROM FIXED GRADE NODES = 3487.50
THE NET FLOW OUT OF THE SYSTEM INTO FIXED GRADE NODES = .00

A SUMMARY OF CONDITIONS SPECIFIED FOR THE NEXT SIMULATION FOLLOWS

THE DEMANDS ARE CHANGED FROM ORIGINAL VALUES BY A FACTOR = 2.50

THE FOLLOWING SPECIFIC DEMAND CHANGES ARE MADE :

| JUNCTION NUMBER | DEMAND |
|-----------------|---------|
| 32 | 3835.00 |

THE RESULTS ARE OBTAINED AFTER 3 TRIALS WITH AN ACCURACY = .00084

MAXIMUM DAY DEMAND PLUS 3500 GPM FIRE FLOW AT NODE 32

| PIPE NO. | NODE NOS. | FLOWRATE | HEAD LOSS | PUMP HEAD | MINOR LOSS | VELOCITY | HL/1000 |
|----------|-----------|----------|-----------|-----------|------------|----------|---------|
| 101 | 0 4 | 1269.91 | 2.75 | .00 | .00 | 3.60 | 4.58 |
| 105 | 4 8 | 143.50 | .07 | .00 | .00 | .41 | .08 |
| 107 | 4 24 | 1126.41 | 2.93 | .00 | .00 | 3.20 | 3.67 |
| 109 | 0 16 | 714.81 | .06 | .00 | .00 | .66 | .09 |
| 113 | 12 16 | 451.04 | .04 | .00 | .00 | .42 | .04 |
| 117 | 0 12 | 451.04 | .02 | .00 | .00 | .42 | .04 |
| 121 | 16 20 | 1154.10 | 3.45 | .00 | .00 | 3.27 | 3.84 |
| 125 | 20 24 | 848.69 | 2.17 | .00 | .00 | 2.41 | 2.17 |
| 129 | 24 28 | 1527.78 | 7.41 | .00 | .00 | 4.33 | 6.45 |
| 133 | 28 32 | 1801.89 | 15.32 | .00 | .00 | 5.11 | 8.75 |
| 137 | 0 36 | 2808.00 | .97 | .00 | .00 | 1.99 | .59 |
| 141 | 36 40 | 1174.39 | 2.57 | .00 | .00 | 3.33 | 3.96 |
| 145 | 40 44 | 1201.80 | 2.27 | .00 | .00 | 3.41 | 4.13 |
| 149 | 44 48 | 1348.61 | 5.63 | .00 | .00 | 3.83 | 5.12 |
| 153 | 48 32 | 2033.11 | 16.97 | .00 | .00 | 5.77 | 10.95 |
| 157 | 20 40 | 100.41 | .03 | .00 | .00 | .28 | .04 |
| 161 | 24 44 | 231.06 | .14 | .00 | .00 | .66 | .20 |
| 165 | 28 48 | -712.61 | -1.65 | .00 | .00 | -2.02 | -1.57 |
| 169 | 36 52 | 1633.61 | .30 | .00 | .00 | 1.16 | .22 |
| 173 | 52 48 | 1570.36 | 10.18 | .00 | .00 | 4.45 | 6.78 |

| JUNCTION NUMBER | DEMAND | GRADE LINE | ELEVATION | PRESSURE |
|-----------------|--------|------------|-----------|----------|
| 4 | .00 | 837.25 | 596.00 | 104.54 |
| 8 | 143.50 | 837.18 | 612.00 | 97.58 |

East Otay Mesa Specific Plan Amendment
Public Water System Analysis

Job No. 701-012
File Name: 701012A1
September 21, 2015

| | | | | |
|----|---------|--------|--------|--------|
| 12 | .00 | 839.98 | 574.00 | 115.26 |
| 16 | 11.75 | 839.94 | 575.00 | 114.81 |
| 20 | 205.00 | 836.49 | 562.00 | 118.95 |
| 24 | 216.25 | 834.32 | 580.00 | 110.21 |
| 28 | 438.50 | 826.91 | 590.00 | 102.66 |
| 32 | 3835.00 | 811.59 | 538.00 | 118.56 |
| 36 | .00 | 839.03 | 551.00 | 124.81 |
| 40 | 73.00 | 836.46 | 557.00 | 121.10 |
| 44 | 84.25 | 834.18 | 566.00 | 116.21 |
| 48 | 173.25 | 828.55 | 586.00 | 105.11 |
| 52 | 63.25 | 838.73 | 538.00 | 130.32 |

THE NET SYSTEM DEMAND = 5243.75

SUMMARY OF INFLOWS(+) AND OUTFLOWS(-) FROM FIXED GRADE NODES

| PIPE NUMBER | FLOWRATE |
|-------------|----------|
| 101 | 1269.91 |
| 109 | 714.81 |
| 117 | 451.04 |
| 137 | 2808.00 |

THE NET FLOW INTO THE SYSTEM FROM FIXED GRADE NODES = 5243.75

THE NET FLOW OUT OF THE SYSTEM INTO FIXED GRADE NODES = .00

A SUMMARY OF CONDITIONS SPECIFIED FOR THE NEXT SIMULATION FOLLOWS

THE DEMANDS ARE CHANGED FROM ORIGINAL VALUES BY A FACTOR = 2.50

THE FOLLOWING SPECIFIC DEMAND CHANGES ARE MADE :

| JUNCTION NUMBER | DEMAND |
|-----------------|---------|
| 28 | 3938.50 |

THE RESULTS ARE OBTAINED AFTER 4 TRIALS WITH AN ACCURACY = .00237

MAXIMUM DAY DEMAND PLUS 3500 GPM FIRE FLOW AT NODE 28

| PIPE NO. | NODE NOS. | FLOWRATE | HEAD LOSS | PUMP HEAD | MINOR LOSS | VELOCITY | HL/1000 |
|----------|-----------|----------|-----------|-----------|------------|----------|---------|
| 101 | 0 4 | 1308.68 | 2.90 | .00 | .00 | 3.71 | 4.84 |
| 105 | 4 8 | 143.50 | .07 | .00 | .00 | .41 | .08 |
| 107 | 4 24 | 1165.18 | 3.12 | .00 | .00 | 3.31 | 3.90 |
| 109 | 0 16 | 729.90 | .06 | .00 | .00 | .68 | .09 |
| 113 | 12 16 | 460.56 | .04 | .00 | .00 | .43 | .04 |
| 117 | 0 12 | 460.56 | .02 | .00 | .00 | .43 | .04 |
| 121 | 16 20 | 1178.71 | 3.59 | .00 | .00 | 3.34 | 3.99 |
| 125 | 20 24 | 891.53 | 2.38 | .00 | .00 | 2.53 | 2.38 |
| 129 | 24 28 | 1840.71 | 10.47 | .00 | .00 | 5.22 | 9.10 |
| 133 | 28 32 | -622.52 | -2.14 | .00 | .00 | -1.77 | -1.22 |
| 137 | 0 36 | 2744.61 | .93 | .00 | .00 | 1.95 | .56 |

East Otay Mesa Specific Plan Amendment
Public Water System Analysis

Job No. 701-012
File Name: 701012A1
September 21, 2015

| | | | | | | | | |
|-----|----|----|----------|-------|-----|-----|-------|-------|
| 141 | 36 | 40 | 1215.54 | 2.74 | .00 | .00 | 3.45 | 4.22 |
| 145 | 40 | 44 | 1224.72 | 2.35 | .00 | .00 | 3.47 | 4.28 |
| 149 | 44 | 48 | 1140.22 | 4.13 | .00 | .00 | 3.23 | 3.75 |
| 153 | 48 | 32 | 957.52 | 4.21 | .00 | .00 | 2.72 | 2.71 |
| 157 | 20 | 40 | 82.18 | .02 | .00 | .00 | .23 | .03 |
| 161 | 24 | 44 | -.25 | .00 | .00 | .00 | .00 | .00 |
| 165 | 28 | 48 | -1475.27 | -6.35 | .00 | .00 | -4.18 | -6.04 |
| 169 | 36 | 52 | 1529.07 | .27 | .00 | .00 | 1.08 | .19 |
| 173 | 52 | 48 | 1465.82 | 8.96 | .00 | .00 | 4.16 | 5.97 |

| JUNCTION NUMBER | DEMAND | GRADE LINE | ELEVATION | PRESSURE |
|-----------------|---------|------------|-----------|----------|
| 4 | .00 | 837.10 | 596.00 | 104.47 |
| 8 | 143.50 | 837.03 | 612.00 | 97.51 |
| 12 | .00 | 839.98 | 574.00 | 115.26 |
| 16 | 11.75 | 839.94 | 575.00 | 114.81 |
| 20 | 205.00 | 836.35 | 562.00 | 118.89 |
| 24 | 216.25 | 833.97 | 580.00 | 110.05 |
| 28 | 3938.50 | 823.50 | 590.00 | 101.18 |
| 32 | 335.00 | 825.64 | 538.00 | 124.64 |
| 36 | .00 | 839.07 | 551.00 | 124.83 |
| 40 | 73.00 | 836.33 | 557.00 | 121.04 |
| 44 | 84.25 | 833.97 | 566.00 | 116.12 |
| 48 | 173.25 | 829.85 | 586.00 | 105.67 |
| 52 | 63.25 | 838.81 | 538.00 | 130.35 |

THE NET SYSTEM DEMAND = 5243.75

SUMMARY OF INFLOWS (+) AND OUTFLOWS (-) FROM FIXED GRADE NODES

| PIPE NUMBER | FLOWRATE |
|-------------|----------|
| 101 | 1308.68 |
| 109 | 729.90 |
| 117 | 460.56 |
| 137 | 2744.61 |

THE NET FLOW INTO THE SYSTEM FROM FIXED GRADE NODES = 5243.75

THE NET FLOW OUT OF THE SYSTEM INTO FIXED GRADE NODES = .00

A SUMMARY OF CONDITIONS SPECIFIED FOR THE NEXT SIMULATION FOLLOWS

THE DEMANDS ARE CHANGED FROM ORIGINAL VALUES BY A FACTOR = 2.50

THE FOLLOWING SPECIFIC DEMAND CHANGES ARE MADE :

| JUNCTION NUMBER | DEMAND |
|-----------------|---------|
| 8 | 3643.50 |

THE RESULTS ARE OBTAINED AFTER 4 TRIALS WITH AN ACCURACY = .00140

MAXIMUM DAY DEMAND PLUS 3500 GPM FIRE FLOW AT NODE 8

East Otay Mesa Specific Plan Amendment
Public Water System Analysis

Job No. 701-012
File Name: 701012A1
September 21, 2015

| PIPE NO. | NODE NOS. | FLOWRATE | HEAD LOSS | PUMP HEAD | MINOR LOSS | VELOCITY | HL/1000 |
|----------|-----------|----------|-----------|-----------|------------|----------|---------|
| 101 | 0 4 | 2334.50 | 8.48 | .00 | .00 | 6.62 | 14.14 |
| 105 | 4 8 | 3643.50 | 27.41 | .00 | .00 | 10.34 | 32.24 |
| 107 | 4 24 | -1309.00 | -3.87 | .00 | .00 | -3.71 | -4.84 |
| 109 | 0 16 | 596.80 | .04 | .00 | .00 | .55 | .06 |
| 113 | 12 16 | 376.57 | .03 | .00 | .00 | .35 | .03 |
| 117 | 0 12 | 376.57 | .01 | .00 | .00 | .35 | .03 |
| 121 | 16 20 | 961.62 | 2.46 | .00 | .00 | 2.73 | 2.74 |
| 125 | 20 24 | 834.90 | 2.11 | .00 | .00 | 2.37 | 2.11 |
| 129 | 24 28 | -62.05 | -.02 | .00 | .00 | -.18 | -.02 |
| 133 | 28 32 | -37.28 | -.01 | .00 | .00 | -.11 | -.01 |
| 137 | 0 36 | 1935.88 | .49 | .00 | .00 | 1.37 | .29 |
| 141 | 36 40 | 1023.61 | 2.00 | .00 | .00 | 2.90 | 3.07 |
| 145 | 40 44 | 872.33 | 1.26 | .00 | .00 | 2.47 | 2.28 |
| 149 | 44 48 | 159.77 | .11 | .00 | .00 | .45 | .10 |
| 153 | 48 32 | 372.28 | .73 | .00 | .00 | 1.06 | .47 |
| 157 | 20 40 | -78.28 | -.02 | .00 | .00 | -.22 | -.03 |
| 161 | 24 44 | -628.30 | -.87 | .00 | .00 | -1.78 | -1.24 |
| 165 | 28 48 | -463.27 | -.74 | .00 | .00 | -1.31 | -.71 |
| 169 | 36 52 | 912.27 | .10 | .00 | .00 | .65 | .07 |
| 173 | 52 48 | 849.02 | 3.26 | .00 | .00 | 2.41 | 2.17 |

| JUNCTION NUMBER | DEMAND | GRADE LINE | ELEVATION | PRESSURE |
|-----------------|---------|------------|-----------|----------|
| 4 | .00 | 831.52 | 596.00 | 102.06 |
| 8 | 3643.50 | 804.11 | 612.00 | 83.25 |
| 12 | .00 | 839.99 | 574.00 | 115.26 |
| 16 | 11.75 | 839.96 | 575.00 | 114.82 |
| 20 | 205.00 | 837.50 | 562.00 | 119.38 |
| 24 | 216.25 | 835.39 | 580.00 | 110.67 |
| 28 | 438.50 | 835.41 | 590.00 | 106.34 |
| 32 | 335.00 | 835.42 | 538.00 | 128.88 |
| 36 | .00 | 839.51 | 551.00 | 125.02 |
| 40 | 73.00 | 837.52 | 557.00 | 121.56 |
| 44 | 84.25 | 836.26 | 566.00 | 117.11 |
| 48 | 173.25 | 836.15 | 586.00 | 108.40 |
| 52 | 63.25 | 839.41 | 538.00 | 130.61 |

THE NET SYSTEM DEMAND = 5243.75

SUMMARY OF INFLOWS(+) AND OUTFLOWS(-) FROM FIXED GRADE NODES

| PIPE NUMBER | FLOWRATE |
|-------------|----------|
| 101 | 2334.50 |
| 109 | 596.80 |
| 117 | 376.57 |
| 137 | 1935.88 |

THE NET FLOW INTO THE SYSTEM FROM FIXED GRADE NODES = 5243.75
THE NET FLOW OUT OF THE SYSTEM INTO FIXED GRADE NODES = .00

\\ARTIC\DWG\701012\FIGURES\WATER\EXHIBIT A.DWG 09-22-15 08:52:56 LAYOUT: LAYOUT

WATER SYSTEM NODE
AND PIPE DIAGRAM

EXHIBIT A

LEGEND

- PROJECT BOUNDARY
- EXISTING WATER LINE
- PROPOSED WATER LINE
- PROPOSED FIRE HYDRANT
- COMPUTER MODEL NODE NUMBER
- COMPUTER MODEL PIPE NUMBER
- LAND USE AREA

EXHIBIT A
WATER SYSTEM NODE
AND PIPE DIAGRAM

EAST OTAY MESA SPECIFIC PLAN AMENDMENT

DEXTER WILSON ENGINEERING, INC.
CONSULTING ENGINEERS
(760) 438-4422

SCALE: 1" = 400'

