



County of San Diego, Planning & Development Services

Self- Certification Frequently Missed Items (SFD GR)

BUILDING DIVISION

1. Legend is missing or incomplete.
2. Dimension between edge of pad and proposed foundation of structure.
3. Size of rip rap is missing.
4. 15-ft. max. spacing of plantings on the faces of all cut and fill slope is missing or incomplete.
5. Brow ditch at the top of all cut slopes, (County Grading Ordinance 87.414), and dimensioned brow ditch detail or County Standard brow ditch detail D-75.
6. Berm at the top of all fill slopes, (County Grading Ordinance 87.414), and dimensioned berm detail or County Standard berm detail DS-10.
7. Stormwater BMP feature SS-10 / D-40 RIP RAP energy dissipater where water flow is concentrated.
8. Driveway surface material is not indicated.
9. Driveway slope is not indicated.
10. Missing DEH stamp.
11. Missing Fire stamp.
12. Missing proof of water source.
13. Missing engineer retention letter.
14. Missing owner signature.

5510 OVERLAND AVE., SUITE 110, SAN DIEGO, CA 92123 • (858) 565-5920 • (888) 336-7553

[HTTP://WWW.SDCPDS.ORG](http://www.sdcpds.org)