

**From:** [Pine, James](#)  
**To:** [Avalos, Tona](#)  
**Cc:** [Brown, Bronwyn](#)  
**Subject:** RE: JVR Solar - PDS2018-GPA-18-010  
**Date:** Wednesday, February 06, 2019 12:54:32 PM

---

Hi Tona,

Yes, we concur that the gated entrances should be per DS-17, 18 or 19. For the onsite access roads, we could support D.G. or Class II base, but gravel or native soil would not be acceptable.

Best Regards,

**JAMES PINE | Asst. Fire Marshal**  
***San Diego County Fire Authority***

5510 Overland Ave., Suite 250  
San Diego, CA 92123  
T: 858.495.5434  
*Office Hrs.: M-Th, 7:00-5:30*



*Improving Fire and Emergency Medical  
Services in Unincorporated San Diego County*  
[www.sdcountyfire.org](http://www.sdcountyfire.org)

*Please take a moment to complete this brief customer service survey. Your input and comments are important to us as we strive to serve you better: <https://www.surveymonkey.com/r/psg-sdcfa-feedback>*

CONFIDENTIALITY NOTICE: This email message, including any attachments, is for the sole use of the intended recipient(s) and may contain information protected from disclosure by applicable laws and regulations. If you are not an intended recipient, you may not review, use, copy, disclose or distribute this message or any of the information contained in this message to anyone. If you are not the intended recipient, please contact the sender by reply email and destroy all copies of this message and any attachments. Unintended transmission shall not constitute waiver of any applicable legal protection afforded to this email and any attached documents.

---

**From:** Avalos, Tona <Tona.Avalos@sdcounty.ca.gov>  
**Sent:** Wednesday, February 6, 2019 12:44 PM  
**To:** Pine, James <James.Pine@sdcounty.ca.gov>  
**Cc:** Brown, Bronwyn <Bronwyn.Brown@sdcounty.ca.gov>  
**Subject:** JVR Solar - PDS2018-GPA-18-010

Hi James,

We had a meeting with the applicant today and they had some questions on LD comments. I wanted

to check your input for these items:

1. We had commented that the gated driveway entrances must follow San Diego County Design Standard Drawings DS-17, DS-18, or DS-19 (with 38' turnaround radius). Will this be required by Fire?
2. For onsite access roads throughout the site, they are proposing Gravel or DG. Is this acceptable by Fire for this site? Some of the details in their plan showed compacted native soil, which I told them is not acceptable.

Let me know if you want to discuss.

Thanks!

***Tona Avalos, PE***

Civil Engineer

[Planning & Development Services](#)

County of San Diego

[tona.avalos@sdcounty.ca.gov](mailto:tona.avalos@sdcounty.ca.gov)

(858) 495-5284