

Hi Trey,

The Jacumba Valley Ranch is classified as a Transient Non-Community (TNC) water system. TNCs are required to submit minimal water quality results on a regular basis:

- Bacterial results - Quarterly
- Nitrate - Annual
- Nitrite – Every 3 years
- Inorganics/General Mineral/General Physical – One time ever

Jacumba Valley Ranch last tested for General Mineral/Physical in 1989 and Inorganics in 1987.

My file shows a total of 7 connections (3 ranch homes, 2 gas stations and 2 fire hydrants). Let me see if I can locate production numbers from their electronic annual report.

Jamelle K. McCullough, MPH, REHS

County of San Diego
Department of Environmental Health
Small Drinking Water Systems
5500 Overland Avenue, Suite 210
San Diego, Ca 92123
(858) 694-3113 phone
(858) 694-3670 fax

From: Trey Driscoll [<mailto:tdriscoll@dudek.com>]
Sent: Wednesday, April 08, 2015 11:29 AM
To: McCullough, Jamelle
Cc: Bennett, Jim
Subject: Ketchum Ranch Water Company Jacumba hot Springs

Hi Jamelle,

I am completing a Groundwater Resources Investigation Report for Jacumba Community Services District in cooperation with the County (Jim Bennett). I last completed a file review of the Jacumba Valley Ranch (Ketchum Water Company) in 2011 and the file contained limited water quality data.

Does your updated file contain any water production information or indicate how many connections the system serves?

My understanding is that the system serves up to 5 residential dwelling units and 2 service stations.

Cheers,
Trey

TREY DRISCOLL, PG #8511, CHG #936
SENIOR HYDROGEOLOGIST

DUDEK
ENGINEERING + ENVIRONMENTAL

605 THIRD STREET
ENCINITAS, CALIFORNIA 92024
T 760.479.4154 F 760.942.5206 C 760.415.1425